

ISO/PRF 12460-2:2023(E)

© ISO 2023

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: + 41 22 749 01 11
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Formatted: Font: 11 pt, Bold, Font color: Auto

Formatted: Font: 11 pt, Bold, Font color: Auto

Formatted: Font: Bold

Formatted: Left: 1.9 cm, Right: 1.9 cm, Bottom: 1 cm, Gutter: 0 cm, Header distance from edge: 1.27 cm, Footer distance from edge: 0.5 cm

Commented [eXtyles1]: The reference is to a withdrawn standard which has been replaced

ISO 20344, Personal protective equipment — Test methods for footwear

Formatted: Default Paragraph Font

Formatted: Default Paragraph Font

Formatted: Adjust space between Latin and Asian text, Adjust space between Asian text and numbers

Formatted: French (Switzerland)

Formatted: French (Switzerland)

Formatted: French (Switzerland)

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

ISO/PRF 12460-2

<https://standards.iteh.ai/catalog/standards/sist/bb49ef7d-10f9-4394-bbd6-cc9f659417bd/iso-prf-12460-2>

Contents

Foreword x

1 Scope 1

2 Normative references 1

3 Terms and definitions 1

4 General 2

5 Significance and use 2

6 Interferences 3

7 Apparatus 3

7.1 Test chamber 3

7.1.1 General 3

7.1.2 Air exchange rate 3

7.1.3 Air circulation 3

7.1.4 Make-up air 3

7.1.5 Equipment for monitoring of test conditions 3

7.1.6 Air sampling port 4

7.2 Air sampling system 4

7.2.1 Sampling system for wet-chemistry analysis 4

7.2.2 Direct sampling 5

8 Sample material handling and specimen conditioning 5

8.1 Handling 5

8.2 Test specimen 5

8.3 Conditioning 7

8.4 Sealing of test piece edges 7

9 Procedure 7

9.1 Test conditions 7

9.2 Test procedure for materials 7

9.3 Air sampling 8

9.4 Analysis of air samples 8

9.4.1 General 8

9.4.2 Equivalence of analytical procedures – General requirements 8

10 Calculation 8

11 Determination of air exchange rate 9

12 Test report 10

Annex A (informative) Test chambers 12

Annex B (informative) Conversion of formaldehyde test results 25

Annex C (normative) Analytical procedure of formaldehyde determination 30

Formatted: Font: 11 pt, Bold, Font color: Auto

Formatted: Font: 11 pt, Bold, Font color: Auto

Formatted: Font: Bold

Formatted: Left

Formatted: Font: 11 pt

Formatted: Space After: 0 pt, Line spacing: single, Tab stops: Not at 25 cm

Annex D (informative) Establishing of a correlation..... 61
Bibliography..... 81

Foreword — ix
1 — Scope — 1
2 — Normative references — 1
3 — Terms and definitions — 1
4 — General — 2
5 — Significance and use — 2
6 — Interferences — 2
7 — Apparatus — 3
7.1 — Test chamber — 3
7.1.1 — General — 3
7.1.2 — Air exchange rate — 3
7.1.3 — Air circulation — 3
7.1.4 — Make up air — 3
7.1.5 — Equipment for monitoring of test conditions — 3
7.1.6 — Air sampling port — 3
7.2 — Air sampling system — 3
7.2.1 — Sampling system for wet chemistry analysis — 3
7.2.2 — Direct sampling — 4
8 — Sample material handling and specimen conditioning — 4
8.1 — Handling — 4
8.2 — Test specimen — 4
8.3 — Conditioning — 6
8.4 — Sealing of test piece edges — 6
9 — Procedure — 6
9.1 — Test conditions — 6
9.2 — Test procedure for materials — 6
9.3 — Air sampling — 6
9.4 — Analysis of air samples — 7
9.4.1 — General — 7
9.4.2 — Equivalence of analytical procedures — General requirements — 7
10 — Calculation — 7
11 — Determination of air exchange rate — 8
12 — Test report — 9
Annex A (informative) Test chambers — 10

Formatted: Font: 11 pt, Bold, Font color: Auto

Formatted: Font: 11 pt, Bold, Font color: Auto

Formatted: Font: Bold

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[ISO/PRF 12460-2](https://standards.iteh.ai/catalog/standards/sist/bb49ef7d-10f9-4394-bbd6-cc9f659417bd/iso-prf-12460-2)

A.1 General 10

A.2 Example 1: 1 m³ test chamber 10

A.2.1 Chamber volume and operation 10

A.2.2 Construction principle 10

A.2.3 Test pieces 11

A.3 Example 2: 0,225 m³ test chamber 13

A.3.1 Chamber volume and operation 13

A.3.2 Construction principle 13

A.3.3 Test pieces 14

A.4 Example 3: 0,045 m³ test chamber 15

A.4.1 Chamber volume and operation 15

A.4.2 Construction principle 15

A.4.3 Test pieces 16

A.5 Example 4: 0,004 m³ test chamber 18

A.5.1 Chamber volume and operation 18

A.5.2 Construction principle 18

A.5.3 Test pieces 19

A.5.3.1 Preparation of test pieces 19

A.5.3.2 Selection of test pieces for factory production control 19

Annex B (informative) Conversion of formaldehyde test results 22

B.1 General 22

B.2 Re-calculation of temperature using Berge et al. formula 22

B.3 Re-calculation of relative humidity using Berge et al. formula 23

B.4 Re-calculation of temperature, relative humidity, loading ratio and air exchange rate using Andersen Equation 24

B.5 Calculation of formaldehyde release - WKI calculation models 25

B.5.1 General 25

B.5.2 Linear model 25

B.5.3 Exponential model - 2014 25

B.5.4 Exponential model - 2022 25

Annex C (normative) Analytical procedure of formaldehyde determination 26

C.1 General 26

C.2 Acetylacetone method - Calibration curve and sampling 26

C.2.1 General 26

C.2.2 Hazards 26

C.2.3 Equipment for chemical analysis 26

C.2.4 Reagents 27

C.2.4.1 General 27

Formatted: Font: 11 pt, Bold, Font color: Auto

Formatted: Font: 11 pt, Bold, Font color: Auto

Formatted: Font: Bold

Formatted: Left

iTeh Standards

(<https://standards.itih.ai>)

Document Preview

ISO/PRF 12460-2

<https://standards.itih.ai/catalog/standards/sist/bb49ef7d-10f9-4394-bbd6-cc9f659417bd/iso-prf-12460-2>

Formatted: Font: 11 pt

Formatted: Space After: 0 pt, Line spacing: single, Tab stops: Not at 25 cm

ISO/PRF 12460-2:2023(E)

C.2.4.2 Acetylacetone solution 27
C.2.4.3 Ammonium acetate solution 27
C.2.5 Calibration curve 27
C.2.5.1 General 27
C.2.5.2 Formaldehyde standard solution 27
C.2.5.2.1 Reagents 27
C.2.5.2.2 Determination of formaldehyde concentration 27
C.2.5.3 Formaldehyde calibration solution 28
C.2.5.4 Determination of the calibration curve 28
C.2.6 Sampling 29
C.2.7 Analytical Procedure 30
C.2.7.1 General 30
C.2.7.2 Absorption solution: Distilled water 30
C.2.7.3 Absorption solution: Mixed reagent 30
C.2.8 Calculation of the amount of absorbed formaldehyde 30
C.2.9 Calculation of the formaldehyde emission 30
C.2.10 Performance characteristic 31
C.2.11 Interferences 31
C.3 Chromotropic acid method – Calibration curve and sampling 32
C.3.1 General 32
C.3.2 Hazards 32
C.3.3 Equipment for chemical analysis 32
C.3.4 Reagents 33
C.3.5 Calibration curve 33
C.3.5.1 General 33
C.3.5.2 Formaldehyde standard solution 33
C.3.5.2.1 Reagents 33
C.3.5.2.2 Determination of formaldehyde concentration 33
C.3.5.2.2.1 Formaldehyde standard solution A (content: 1,0 mg/ml) 33
C.3.5.2.2.2 Formaldehyde standard solution B (content 0,01 mg/ml) 34
C.3.5.3 Determination of the calibration curve 34
C.3.6 Analytical Procedure 35
C.3.7 Sampling 36
C.3.8 Calculation of the amount of absorbed formaldehyde 36
C.3.9 Calculation of the formaldehyde emission 36
C.3.10 Interferences 37
C.4 DNPH method – Calibration curve and sampling 37
C.4.1 General 37

Formatted: Font: 11 pt, Bold, Font color: Auto

Formatted: Font: 11 pt, Bold, Font color: Auto

Formatted: Font: Bold

iteh Standards
(<https://standards.iteh.ai>)
Document Preview

ISO/PRF 12460-2

C.4.2 Hazards — 37

C.4.3 Equipment for chemical analysis — 37

C.4.4 Reagents — 38

C.4.5 Calibration Curve — 39

C.4.5.1 General — 39

C.4.5.2 Formaldehyde standard calibration solution — 39

C.4.6 Determination of the calibration curve — 41

C.4.7 HPLC System — 42

C.4.8 Sampling/Test duration — 43

C.4.8.1 General — 43

C.4.8.2 Calculation of the formaldehyde emission — 44

C.4.8.3 Process blanks — 45

C.4.8.4 Sample desorption — 45

C.4.9 Precision and uncertainty — 46

C.5 Laser Absorption Spectroscopy (LAS) — 46

C.5.1 Measurement principle — 46

C.5.2 Hazards — 47

C.5.3 Equipment for chemical analysis — 47

C.5.4 Reagents — 47

C.5.5 Calibration — 47

C.5.6 Sampling — 48

C.5.7 Test duration — 49

C.5.8 Calculation of the formaldehyde emission — 49

C.5.9 Performance characteristic — 49

C.5.10 Interferences — 49

C.5.11 Equivalence — 49

C.6 Chemical sensor — 49

C.6.1 Measurement principle — 49

C.6.2 Hazards — 50

C.6.3 Equipment for chemical analysis — 50

C.6.4 Reagents — 51

C.6.5 Calibration — 51

C.6.5.1 General — 51

C.6.5.2 Sample based calibration procedure — 51

C.6.5.3 Calculation of the calibration factor — 51

C.6.6 Sampling — 51

C.6.7 Test duration — 51

C.6.8 Calculation of the formaldehyde emission — 51

Formatted: Font: 11 pt, Bold, Font color: Auto

Formatted: Font: 11 pt, Bold, Font color: Auto

Formatted: Font: Bold

Formatted: Left

iTeh Standards
(<https://standards.itih.ai>)
Document Preview

ISO/PRF 12460-2

Formatted: Font: 11 pt

Formatted: Space After: 0 pt, Line spacing: single, Tab stops: Not at 25 cm

C.6.9	Performance characteristic	52
C.6.10	Interferences	52
C.6.11	Equivalence	52
Annex D (informative) Establishing of a correlation 53		
D.1	General	53
D.2	Terms and definitions	53
D.3	Sampling and sample preparation	54
D.3.1	General	54
D.3.2	Side Matching	55
D.3.3	Product test data	55
D.3.4	Factory production control procedures	55
D.4	Test methods	55
D.4.1	Reference chamber test method	55
D.4.2	Derived test methods	56
D.5	Establishing the correlation	57
D.5.1	General context	57
D.5.2	Selection of data	57
D.5.3	Options to establish a correlation	58
D.5.3.1	General	58
D.5.3.2	Option 1	59
D.5.3.3	Option 2	61
D.5.3.3.1	General	61
D.5.3.3.2	Option 2.1	62
D.5.3.3.3	Option 2.2	62
D.5.3.4	Option 3	63
D.5.4	Data analysis	65
D.5.4.1	Analysis of cluster including range of data	65
D.5.4.2	Test of normal distribution	65
D.5.4.2.1	Normal distribution test according to Shapiro-Wilk	65
D.5.4.2.2	Rank normal distribution test according to Kolmogorov Smirnov	66
D.5.4.3	Calculation of regression	67
D.5.4.3.1	General	67
D.5.4.3.2	Calculation of regression according to option 2.2	67
D.5.4.4	Calculation of the correlation coefficient	68
D.5.4.4.1	Correlation coefficient according to Pearson	68
D.5.4.4.2	Rank correlation according to Spearman	69
D.5.4.4.3	Correction of correlation coefficient using option 2.2	69
D.5.4.4.4	F statistic	70

Formatted: Font: 11 pt, Bold, Font color: Auto

Formatted: Font: 11 pt, Bold, Font color: Auto

Formatted: Font: Bold

iTeh Standards
(<https://standards.itih.ai>)
Document Preview

ISO/PRF 12460-2

<https://standards.itih.ai/catalog/standards/sist/bb49ef7d-10f9-4394-bbd6-cc9f659417bd/iso-prf-12460-2>

D.5.4.4.5 Quality criteria for correlations — 70

D.5.5 Calculation of limit values — 70

D.5.5.1 Quality control limit (QCL) — 70

D.5.5.2 Excursion limit value — 71

D.5.5.3 Target operating level (TOL) — 71

D.5.5.4 Shipping quality control limit value (SQCL) — 71

D.5.6 Review of the correlation (annually and following a production process change) — 71

Bibliography — 73

Formatted: Font: 11 pt, Bold, Font color: Auto

Formatted: Font: 11 pt, Bold, Font color: Auto

Formatted: Font: Bold

Formatted: Left

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

ISO/PRF 12460-2

<https://standards.iteh.ai/catalog/standards/sist/bb49ef7d-10f9-4394-bbd6-cc9f659417bd/iso-prf-12460-2>

Formatted: Font: 11 pt

Formatted: Space After: 0 pt, Line spacing: single, Tab stops: Not at 25 cm

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

ISO draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). ISO takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, ISO had not received notice of (a) patent(s) which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at www.iso.org/patents. ISO shall not be held responsible for identifying any or all such patent rights.

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 89, *Wood-based panels*.

This second edition cancels and replaces the first edition (ISO 12460-2:2018), which has been technically revised.

The main changes are as follows:

- implementation of different chamber sizes, analytical procedures, re-calculation of results to other standard parameters and establish a correlation between reference chamber method and the method used for factory production control.

A list of all parts in the ISO 12460 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

Formatted: Font: 11 pt, Bold, Font color: Auto

Formatted: Font: 11 pt, Bold, Font color: Auto

Formatted: Font: Bold

Formatted: Adjust space between Latin and Asian text, Adjust space between Asian text and numbers

Field Code Changed

Field Code Changed

Formatted: Default Paragraph Font (1-2)

Formatted: Default Paragraph Font

Formatted: Default Paragraph Font

Formatted: Default Paragraph Font

Formatted: Adjust space between Latin and Asian text, Adjust space between Asian text and numbers, Tab stops: Not at 0.7 cm + 1.4 cm + 2.1 cm + 2.8 cm + 3.5 cm + 4.2 cm + 4.9 cm + 5.6 cm + 6.3 cm + 7 cm

Commented [eXtyles2]: Invalid reference: "ISO 12460 series"

Formatted: Default Paragraph Font

Formatted: Default Paragraph Font

Formatted: Default Paragraph Font

Formatted: Adjust space between Latin and Asian text, Adjust space between Asian text and numbers

Field Code Changed

Wood-based panels — Determination of formaldehyde release —

Part 2: Small-scale chamber method

1 Scope

This document specifies a procedure for a chamber test with different options of chamber sizes to measure the formaldehyde concentrations in air from wood products under defined test conditions of temperature, relative humidity, loading and air exchange rate.

Results obtained from this small-scale chamber test method can be used for quality control (factory production control - 'FPC') based on correlation established by reference chamber test methods according to ISO, EN or ASTM standards. The establishment of a correlation is described in [Annex D](#).

2 Normative references

There are no normative references in this document.

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <https://www.electropedia.org/>

3.1 *N* air exchange rate

quotient of air volume Q passing through the chamber per hour (m^3/h) and the chamber volume (m^3) expressed in (h^{-1})

3.2 *L* loading ratio

total exposed surface area, excluding panel edges, of the product being tested divided by the test chamber's volume (m^2/m^3)

3.3 *Q* make-up airflow

quantity of conditioned and filtered air fed into the chamber per unit time, in m^3/h

3.4 *Q/A* ratio

ratio of air flow through the chamber (Q) to sample surface area (A), in $\text{m}^3/\text{h m}^2$

Formatted: Left: 1.9 cm, Right: 1.9 cm, Bottom: 1 cm, Gutter: 0 cm, Header distance from edge: 1.27 cm, Footer distance from edge: 0.5 cm

Formatted: Main Title 2, Space After: 0 pt, Adjust space between Latin and Asian text, Adjust space between Asian text and numbers

Formatted: Adjust space between Latin and Asian text, Adjust space between Asian text and numbers

Formatted: Adjust space between Latin and Asian text, Adjust space between Asian text and numbers, Tab stops: Not at 0.7 cm + 1.4 cm + 2.1 cm + 2.8 cm + 3.5 cm + 4.2 cm + 4.9 cm + 5.6 cm + 6.3 cm + 7 cm

Formatted: Adjust space between Latin and Asian text, Adjust space between Asian text and numbers

3.5
sample surface area

A
total area of all sample faces exposed in the chamber, in m²

3.6
measured concentration

C
formaldehyde concentration (expressed in mg/m³ and/or ppm rounded to 2 decimal places) under the defined environmental test parameters of this method. In the case of a establishing a correlation, it can be advantageous to round the results to 3 decimal places

3.7
chamber volume

V
interior volume of the test chamber, in m³

4 General

This document specifies the measurement to quantify the amount of formaldehyde in an air sample from a test chamber accepted in a range of sizes (examples are described in Annex A) and as determined by different analytical methods as specified in Annex C. Other analytical procedures may be used to determine the quantity of formaldehyde in the air sample provided that such methods give equivalent results. The test report shall include full description of the analytical procedure employed.

The values stated in SI units are the standard values. Any values given in parentheses are for information only.

NOTE This document does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user to establish appropriate health and safety practices and determine the applicability of regulatory limitations prior to use.

5 Significance and use

5.1 Various national and regional regulations on formaldehyde emission levels have been established for wood panels. This international test method was adapted from chamber test methods specified in different EN, ISO and ASTM standards. This test method provides a means of testing smaller samples and reduces the time required for testing compared with a reference chamber method.

5.2 Formaldehyde concentration levels obtained by this small-scale chamber method can differ from expected in full-scale indoor environments. Variations in product loading, temperature, relative humidity, and air exchange will affect formaldehyde emission rates and thus likely indoor air formaldehyde concentrations.

5.3 This test method is applicable for the use of a chambers from 0,004 m³ to 1 m³ in volume (see examples in Annex A) to evaluate the formaldehyde concentration in air using the following controlled conditions which are defined within this standard method:

- a) conditioning of specimens prior to testing;
- b) exposed surface area of the specimens in the test chamber;
- c) edge sealing;

Formatted: Font: 11 pt, Bold, Font color: Auto

Formatted: Font: 11 pt, Bold, Font color: Auto

Formatted: Font: Bold

Formatted: Adjust space between Latin and Asian text, Adjust space between Asian text and numbers, Tab stops: Not at 0.7 cm + 1.4 cm + 2.1 cm + 2.8 cm + 3.5 cm + 4.2 cm + 4.9 cm + 5.6 cm + 6.3 cm + 7 cm

Formatted: Adjust space between Latin and Asian text, Adjust space between Asian text and numbers

Formatted: Adjust space between Latin and Asian text, Adjust space between Asian text and numbers, Tab stops: Not at 0.7 cm + 1.4 cm + 2.1 cm + 2.8 cm + 3.5 cm + 4.2 cm + 4.9 cm + 5.6 cm + 6.3 cm + 7 cm

d) ~~d)~~ test chamber temperature and relative humidity;

e) ~~e)~~ the Q/A ratio;

f) ~~f)~~ air exchange rate within the chamber.

6 Interferences

Interferences of the used analytical methods should be determined by reference to other applicable standard test methods.

7 Apparatus

7.1 Test chamber

7.1.1 General

The interior volume of the small chamber shall be between 0,004 m³ and 1 m³ (examples see [Annex A](#)–[Annex A](#)). The interior of the test chamber shall be free of refrigeration coils that condense water and items such as humidifiers with water reservoirs since water has the potential for collecting formaldehyde and thus influencing test results. The interior surfaces of the small chamber, including any sample support system, shall be a non-absorbent material. For example, stainless steel, ~~aluminum~~aluminium, and polytetrafluoroethylene (PTFE) have been found appropriate as chamber lining materials. All joints except for doors used for loading and unloading specimens should be sealed. Doors shall be self-sealing.

7.1.2 Air exchange rate

The clean and conditioned air supply to the chamber shall either be monitored ~~continuously~~continuously or frequently during testing.

The air exchange rate shall not vary by more than ±5 %.

The effective air exchange shall be regularly checked, by using e.g. either a calibrated gas meter, or the tracer gas procedure (see [Clause 11](#)–[Clause 11](#)).

7.1.3 Air circulation

Low speed mixing fans or multi-port inlet and outlet diffusers are two techniques that have been used successfully to ensure mixing of the chamber air over all sample surfaces. If the air exchange is higher than 10/h mixing fans are not necessary.

7.1.4 Make-up air

The make-up air should come from a filtered dust-free environment and contain no more than 0,006 mg/m³ of formaldehyde. Make-up air for the chamber shall pass through a calibrated air flow measuring device. If the make-up air is taken from a conditioning environment it should contain no more than 0,012 mg/m³.

7.1.5 Equipment for monitoring of test conditions

Measuring equipment and recording facilities capable of continuous or frequent monitoring of the specified test conditions with an error limit as follows:

- ~~—~~Temperature: 0,1 K;
- ~~—~~Relative humidity: 2 %;

Formatted: Font: 11 pt, Bold, Font color: Auto

Formatted: Font: 11 pt, Bold, Font color: Auto

Formatted: Font: Bold

Formatted: Left

Formatted: Adjust space between Latin and Asian text, Adjust space between Asian text and numbers

Formatted: Adjust space between Latin and Asian text, Adjust space between Asian text and numbers, Tab stops: Not at 0.71 cm

Formatted: Adjust space between Latin and Asian text, Adjust space between Asian text and numbers, Tab stops: Not at 0.71 cm + 0.99 cm + 1.27 cm

Formatted: Adjust space between Latin and Asian text, Adjust space between Asian text and numbers

Formatted: Adjust space between Latin and Asian text, Adjust space between Asian text and numbers, Tab stops: Not at 0.71 cm + 0.99 cm + 1.27 cm

Formatted: Adjust space between Latin and Asian text, Adjust space between Asian text and numbers

Formatted: Adjust space between Latin and Asian text, Adjust space between Asian text and numbers, Tab stops: Not at 0.71 cm + 0.99 cm + 1.27 cm

Formatted: Adjust space between Latin and Asian text, Adjust space between Asian text and numbers

Formatted: Adjust space between Latin and Asian text, Adjust space between Asian text and numbers, Tab stops: Not at 0.71 cm + 0.99 cm + 1.27 cm

Formatted: Adjust space between Latin and Asian text, Adjust space between Asian text and numbers

Formatted: Adjust space between Latin and Asian text, Adjust space between Asian text and numbers, Tab stops: Not at 0.71 cm + 0.99 cm + 1.27 cm

Formatted: Adjust space between Latin and Asian text, Adjust space between Asian text and numbers

Formatted: Adjust space between Latin and Asian text, Adjust space between Asian text and numbers, Tab stops: Not at 0.7 cm + 1.4 cm + 2.1 cm + 2.8 cm + 3.5 cm + 4.2 cm + 4.9 cm + 5.6 cm + 6.3 cm + 7 cm

Formatted: Font: 11 pt

Formatted: Space After: 0 pt, Line spacing: single, Tab stops: Not at 25 cm

— Air exchange rate: 0,03/h.

7.1.6 Air sampling port

The exhaust flow (that is, chamber outlet) is normally used as the sampling point, although separate sampling ports in the chamber can be used. The sampling system shall be constructed of a material to minimize absorption (for example, glass or stainless steel), and the system should be maintained at the same temperature as the test chambers.

7.2 Air sampling system

7.2.1 Sampling system for wet-chemistry analysis

7.2.1.1 General

Figure 1 shows the principle of a sampling system for the determination of the formaldehyde concentration in the chamber air. The sampling tube shall be placed either in the air outlet, or inside the chamber, close to the air outlet.

Other sampling systems may be used based on the requirements of the analytical procedure used.

The numbers in brackets refer to the numbers in Figure 1.

7.2.1.2 sampling tube (1).

7.2.1.3 one or two 30 ml up to 100 ml gas washing bottle(s) (2), with inserts like impinger or Muenke or frits, containing between 8 ml to 40 ml absorber solution, or DNPH cartridges for absorption and subsequent determination of formaldehyde.

7.2.1.4 silica absorber for drying the air (3).

7.2.1.5 gas flow valve (4).


7.2.1.6 gas sampling pump (5).

7.2.1.7 gas flow meter (6).

7.2.1.8 gas meter (including a thermometer) for measuring the volume of air (7).

7.2.1.9 air pressure meter (8).

12460-2_ed2fig1.EPS



Key table with 2 columns: 1 sampling tube, 2 gas washing bottle, 3 silica absorber, 4 gas flow valve, 5 gas sampling pump, 6 gas flow meter, 7 gas meter, 8 air pressure meter.

Formatted: Font: 11 pt, Bold, Font color: Auto

Formatted: Font: 11 pt, Bold, Font color: Auto

Formatted: Font: Bold

Formatted: Adjust space between Latin and Asian text, Adjust space between Asian text and numbers, Tab stops: Not at 0.71 cm + 0.99 cm + 1.27 cm

Formatted: Adjust space between Latin and Asian text, Adjust space between Asian text and numbers

Formatted: Adjust space between Latin and Asian text, Adjust space between Asian text and numbers, Tab stops: Not at 0.71 cm

Formatted: Adjust space between Latin and Asian text, Adjust space between Asian text and numbers, Tab stops: Not at 0.71 cm + 0.99 cm + 1.27 cm

Formatted: Adjust space between Latin and Asian text, Adjust space between Asian text and numbers, Tab stops: Not at 0.7 cm + 1.4 cm + 2.1 cm + 2.8 cm + 3.5 cm + 4.2 cm + 4.9 cm + 5.6 cm + 6.3 cm + 7 cm

Formatted: Adjust space between Latin and Asian text, Adjust space between Asian text and numbers

Formatted: Adjust space between Latin and Asian text, Adjust space between Asian text and numbers, Tab stops: Not at 0.7 cm + 1.4 cm + 2.1 cm + 2.8 cm + 3.5 cm + 4.2 cm + 4.9 cm + 5.6 cm + 6.3 cm + 7 cm

Formatted: Adjust space between Latin and Asian text, Adjust space between Asian text and numbers, Tab stops: Not at 0.7 cm + 1.4 cm + 2.1 cm + 2.8 cm + 3.5 cm + 4.2 cm + 4.9 cm + 5.6 cm + 6.3 cm + 7 cm

Formatted Table

Formatted: Adjust space between Latin and Asian text, Adjust space between Asian text and numbers, Tab stops: Not at 0.7 cm + 1.4 cm + 2.1 cm + 2.8 cm + 3.5 cm + 4.2 cm + 4.9 cm + 5.6 cm + 6.3 cm + 7 cm