
**Hydraulic spin-on filters with finite
lives — Method for verifying the rated
fatigue life and the rated static burst
pressure of the pressure-containing
envelope**

*Filtres hydrauliques à visser ayant une durée de vie spécifiée —
Méthode de vérification de la durée de vie nominale en fatigue et de la
pression statique d'éclatement nominale de l'enveloppe sous pression*

(<https://standards.iteh.ai>)
Document Preview

[ISO/PRF 12829](https://standards.iteh.ai/catalog/standards/sist/4796c3da-fedb-4079-a2bf-d4a0ef1c647e/iso-prf-12829)

<https://standards.iteh.ai/catalog/standards/sist/4796c3da-fedb-4079-a2bf-d4a0ef1c647e/iso-prf-12829>

PROOF / ÉPREUVE



Reference number
ISO 12829:2023(E)

© ISO 2023

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

ISO/PRF 12829

<https://standards.iteh.ai/catalog/standards/sist/4796c3da-fedb-4079-a2bf-d4a0ef1c647e/iso-prf-12829>



COPYRIGHT PROTECTED DOCUMENT

© ISO 2023

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Contents

| | Page |
|--|-----------|
| Foreword..... | iv |
| Introduction..... | v |
| 1 Scope..... | 1 |
| 2 Normative references..... | 1 |
| 3 Terms and definitions..... | 1 |
| 4 Samples..... | 2 |
| 5 Cyclic endurance test to verify the rated fatigue life at a rated fatigue pressure..... | 2 |
| 5.1 Apparatus..... | 2 |
| 5.2 Test conditions..... | 3 |
| 5.3 Test procedure..... | 3 |
| 5.4 Failure criteria..... | 4 |
| 5.5 Calculation of rated fatigue life at rated fatigue pressure..... | 4 |
| 5.6 Verification..... | 5 |
| 6 Burst test to verify the rated static burst pressure..... | 5 |
| 6.1 Apparatus..... | 5 |
| 6.2 Test conditions..... | 5 |
| 6.3 Test procedure..... | 5 |
| 6.4 Failure criteria..... | 6 |
| 6.5 Calculation of rated static burst pressure..... | 6 |
| 6.6 Verification..... | 6 |
| 7 Presentation of data..... | 6 |
| 8 Verification of rated fatigue life, rated fatigue pressure and rated static burst pressure by similarity..... | 7 |
| 9 Similarity between filters under test and production components..... | 7 |
| 10 Identification statement (reference to this document)..... | 7 |
| Annex A (informative) Results of the round robin test program conducted to verify the procedure specified in this document..... | 8 |
| Bibliography..... | 10 |

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO document should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

ISO draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). ISO takes no position concerning the evidence, validity, or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, ISO had not received notice of (a) patent(s) which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at www.iso.org/patents. ISO shall not be held responsible for identifying any or all such patent rights.

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 131, *Fluid power systems*, Subcommittee SC 6, *Contamination control*.

This second edition cancels and replaces the first edition (ISO 12829:2016), of which has been technically revised.

The main changes are as follows:


- a key was added to [Figure 1](#);
- test fluid was revised;
- [Figure 2](#) was revised.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

Introduction

In hydraulic fluid power systems, power is transmitted and controlled through a liquid under pressure within an enclosed circuit. A basic requirement of hydraulic fluid power components is that they should be capable of adequately containing the pressurized fluid.

The pressure to which an individual component can normally be subjected has a relationship with the rated fatigue pressure and minimum burst pressure. This relationship can be estimated and used as a basis of total life expectancy for the component in an individual application. Such an estimate is applied by the user. Factors such as shock, heat, misuse, etc., are to be judged by the user in each application. Selection of a specific pressure and life expectancy for a component in a particular application can be based upon the rated fatigue pressure and burst pressure as described in [Figure 1](#). This finite life pressure rating test procedure differs from the (NFPA)T2.6.1 R2 infinite life pressure rating document (which is referred to in ISO/TR 10771-2) and can be visualized from the S-N diagram in [Figure 1](#). (NFPA) T2.6.1 R2 is a rating system along the vertical axis, with its fatigue strength distribution and assurance level in the vertical direction at a defined life. The finite life method described in this document is a rating system along the horizontal axis, with its fatigue life distribution and assurance level in the horizontal direction at a defined stress (pressure).



Key

| | | | |
|---|-----------------------------|---|-------------------------------------|
| X | cycles | 5 | applied pressure |
| Y | pressure | 6 | verified safe range |
| 1 | burst point | 7 | fatigue life/rated fatigue pressure |
| 2 | rated static burst pressure | 8 | rated fatigue pressure |
| 3 | fatigue failure range | 9 | life expectancy |
| 4 | unverified safe range | | |

Figure 1 — Possible S-N curve method for estimating finite life rating

Because the service life of the element container for a finite life spin-on hydraulic filter is relatively short, a fatigue life of 100 000 cycles is judged sufficient for common industrial ratings. Ratings at levels other than 100 000 cycles are permitted; this document may be applied for those cases. The method of rating includes both pressure and minimum life. The pressure rating of the filter head or mounting base can be subjected to the full 10^6 fatigue cycles established by (NFPA)T2.6.1 R2.

The spin-on housing, because of its construction, can be tested and evaluated as an elastic body with specific pressure cycle test times and pressure rise rate conditions.

This document deals only with verifying the pressure ratings of spin-on filters. Separate from this verification procedure, manufacturers have the continuing responsibility to use managerial controls necessary to test spin-on filters that are representative of production.

