



**International
Standard**

ISO 18501

**Performance rating of positive
displacement refrigerant
compressor**

*Détermination des performances des compresseurs frigorifiques à
déplacement positif*

First edition

iTech Standards
(<https://standards.iteh.ai>)
Document Preview

[ISO/PRF 18501](https://standards.iteh.ai/catalog/standards/iso/aacc8a84-9c86-498d-a2a4-10da6451da11/iso-prf-18501)

<https://standards.iteh.ai/catalog/standards/iso/aacc8a84-9c86-498d-a2a4-10da6451da11/iso-prf-18501>

PROOF/ÉPREUVE

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[ISO/PRF 18501](https://standards.iteh.ai/catalog/standards/iso/aacc8a84-9c86-498d-a2a4-10da6451da11/iso-prf-18501)

<https://standards.iteh.ai/catalog/standards/iso/aacc8a84-9c86-498d-a2a4-10da6451da11/iso-prf-18501>



COPYRIGHT PROTECTED DOCUMENT

© ISO 2025

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

PROOF/ÉPREUVE

© ISO 2025 – All rights reserved

Contents

Page

Foreword	iv
1 Scope	1
2 Normative references	1
3 Terms and definitions	1
4 Rating requirements	4
4.1 General requirements.....	4
4.2 Rating conditions.....	4
5 Published rating	5
5.1 General requirements.....	5
5.2 Individual published rating.....	6
5.3 Number of individual published ratings requirement.....	6
5.4 Polynomial equations.....	6
5.4.1 Ten-coefficient polynomial equation.....	6
5.5 Published data.....	7
5.6 Application envelope.....	8
6 Tolerance	9
7 Marking provisions	10
Annex A (informative) Method to handle zeotropic mixtures	11
Annex B (informative) Superheat correction	13
Bibliography	14

ITeH Standards
 (https://standards.iteh.ai)
 Document Preview

ISO/PRF 18501

<https://standards.iteh.ai/catalog/standards/iso/aacc8a84-9c86-498d-a2a4-10da6451da11/iso-prf-18501>

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO document should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

ISO draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). ISO takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, ISO had not received notice of (a) patent(s) which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at www.iso.org/patents. ISO shall not be held responsible for identifying any or all such patent rights.

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 86, *Refrigeration and air-conditioning*, Subcommittee SC 4, *Testing and rating of refrigerant compressors*.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

ISO/PRF 18501

<https://standards.iteh.ai/catalog/standards/iso/aacc8a84-9c86-498d-a2a4-10da6451da11/iso-prf-18501>

Performance rating of positive displacement refrigerant compressor

1 Scope

This document specifies normative references, terms and definitions, rating requirements, published rating, tolerance and marking provisions of positive displacement refrigerant compressors. This document applies to positive displacement refrigerant compressors and their performance in air-conditioning, heating, refrigeration and dehumidification applications. Single stage, two-stage and refrigerant-injected compressors without intermediate temperature load (only one evaporator) are included in this document. Subcritical operation and transcritical operation are also included in this document.

Compressors for other applications, compression types and operations can also refer to this document. The manufacturer is solely responsible for the determination of values to be used in the published product information.

This document is intended as guidance for the industry, including manufacturers, engineers, installers and service contractors. It defines the minimum amount of information in a standard form to enable the evaluation and comparison of different compressors for use in an application.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 18976, *Testing of refrigerant compressors*

ISO 817, *Refrigerants — Designation and safety classification*

IEC 60038, *IEC standard voltages*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 18976 and the following apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <https://www.electropedia.org/>

3.1

positive displacement refrigerant compressor

machine that increases the pressure of a refrigerant vapour by reducing the compression chamber volume

3.2

fixed displacement compressor

compressor with only one displacement capacity

3.3

modulating compressor

compressor with more than one displacement capacity, either continuous or discrete modulating capacities

3.3.1

continuous modulating compressor

compressor with more than four displacement capacities or infinitely variable displacement capacities

Note 1 to entry: This includes but is not limited to variable speed, continuously variable mechanical unloading or cyclic modulation of discrete.

3.3.2

discrete modulating compressor

compressor with two to four discrete displacement capacities

3.4

subcooling

difference between the bubble point temperature of the refrigerant corresponding to its pressure and the temperature of the liquid refrigerant

3.5

superheat

difference between the temperature of the vapour refrigerant and its dew-point temperature corresponding to its pressure

3.6

refrigerating capacity

product of the refrigerant mass flow at the compressor inlet port and the difference between the specific refrigerant enthalpy at the compressor inlet port and the specific enthalpy of fluid entering the evaporator expansion device

3.7

heating capacity

product of the refrigerant mass flow leaving the compressor discharge port and the difference of the specific refrigerant enthalpy at the discharge port and the outlet of the condenser or gas cooler

3.8

power input

time rate of energy usage of the compressor plus any accessories required to sustain operation of the compressor at the rating condition

<https://standards.iteh.ai/catalog/standards/iso/aacc8a84-9c86-498d-a2a4-10da6451da11/iso-prf-18501>

3.9

refrigerating coefficient of performance

ratio of the refrigerating capacity to the power input

3.10

heating coefficient of performance

ratio of heating thermal capacity to the power input

3.11

intermediate port

inlet port for vapour or liquid within a compression chamber at a pressure between suction and discharge pressure

3.12

interstage port

inlet port for vapour or liquid between two stages of compression

3.13

economizer

heat exchanger or flash tank that is used to lower the liquid specific enthalpy of the refrigerant entering the evaporator while producing vapour that is reintroduced to the compression process

iTeh Standards

Document Preview

ISO/PRF 18501

3.14

economized operation

system operation mode which reduces the specific enthalpy of the refrigerant entering the evaporator and produces vapour which is injected into the compression process

Note 1 to entry: For economized operation with heat exchanger economizer, partial high-pressure liquid refrigerant is throttled to intermediate pressure to subcool the remaining refrigerant. The vapourized refrigerant can be piped to the intermediate port or interstage port of the compressor.

Note 2 to entry: For economized operation with flash tank economizer, all refrigerant at outlet condenser is throttled to intermediate pressure in the flash tank. The saturated liquid goes to evaporator loop and saturated vapour can be piped to the intermediate port or interstage port of the compressor.

3.15

variable frequency drive

VFD

power electronic device supplying an electric motor with a variable frequency and voltage

3.16

subcritical operation

operating condition with discharge pressure below the critical pressure of the refrigerant

3.17

transcritical operation

operating condition with discharge pressure above and the suction pressure below the critical pressure

3.18

liquid injection

injection of high-pressure side liquid refrigerant into the compressor

3.19

step

level of modulation achieved by changing the displacement capacity

EXAMPLE Compressor operating frequency, compressor rotation speed, frequency of variable frequency drive and mechanical unloading setting.

[ISO/PRF 18501](https://standards.iteh.ai/iso/prf-18501)

[s://standards.iteh.ai/catalog/standards/iso/aacc8a84-9c86-498d-a2a4-10da6451da11/iso-prf-18501](https://standards.iteh.ai/catalog/standards/iso/aacc8a84-9c86-498d-a2a4-10da6451da11/iso-prf-18501)

maximum step

step producing the highest displacement capacity of the modulating compressor defined by the manufacturer

3.19.2

minimum step

step producing the lowest displacement capacity of the modulating compressor defined by the manufacturer

3.19.3

reduced step

step producing less displacement capacity than the maximum step of the modulating compressor

3.20

fluid

liquid, gas or vapour including the state of appearance close to and above the critical pressure

3.21

publish

transfer information to any entity decided by the manufacturer

4 Rating requirements

4.1 General requirements

All published ratings shall be based on tests conducted in accordance with ISO 18976.

Published ratings shall be established with an ambient temperature around the compressor and its accessories of 35 °C. If rating at ambient temperatures other than 35 °C, the actual ambient temperature used to establish the rating shall be stated by the manufacturer.

Published ratings shall be established using the nameplate rated voltage and frequency. For dual nameplate voltage ratings, published ratings shall be established using both voltages, or using the higher of the two voltages, if only a single rating is to be published. For compressors with a voltage range, the rated voltage should be published.

For liquid-injected compressors, the manufacturer shall report the controlled discharge temperature.

For economized compressors, refrigerating capacity including the increased refrigeration effect by the subcooling or gas cooling provided by economizer operation shall be reported.

For economized operation compressors with manufacturer mounted or specified heat exchanger, the liquid temperature leaving the heat exchanger shall be stated, if the refrigerant leaving at intermediate pressure is not fully evaporated.

For economized operation compressors without a manufacturer specified intermediate heat exchanger, the liquid refrigerant leaving the economizer shall be 5 K above the refrigerant temperature corresponding to the pressure at the intermediate port or interstage port of the compressor and the specific enthalpy at the outlet of the condenser.

For economized operation compressors with flash tank, liquid temperature leaving the flash tank shall be equal to the bubble point temperature corresponding to the pressure at the intermediate port or interstage port of the compressor.

4.2 Rating conditions

Rating conditions shown in [Table 1](#) are provided for manufacturers to publish performance for the ease of comparing with other compressors. If there is no applicable application or type, the manufacturer can specify the rating conditions.

Table 1 — Rating conditions^{a,b}

Compression cycle			Low side		High side	
Application	Rating test point	Cycle type	Suction dew point temperature, °C	Suction gas superheat ^c , K (or return gas temperature, °C)	Discharge dew point temperature, °C	Subcooling ^d at outlet of the condenser, K
Air conditioning	Cooling	Subcritical	10	10(20)	45	0
	Heating	Subcritical	3	10(13)	49	0
	Low temperature heating	Subcritical	-15	10 (-5)	35	0
Heat pump water heater	Nominal	Subcritical	10	10 (20)	60	0
Refrigeration	High	Subcritical	5	10 (20 ^g)	50	0
		Subcritical (NH ₃)		5 (10)	50	0
		Transcritical (CO ₂)		10 (15)	100 ^e	40 ^f
	Medium	Subcritical	-10	10 (20 ^g)	45	0
		Subcritical (NH ₃)		5 (-5)	45	0
		Transcritical (CO ₂)		10 (0)	90 ^e	35 ^f
	Low	Subcritical	-35	10 (20 ^g)	40	0
		Subcritical (NH ₃)		5 (-30)	40	0
		Transcritical (CO ₂)		10 (-25)	90 ^e	35 ^f
		Cascade/Booster		10 (20 ^g)	-10	0
Household refrigerator and freezer	Nominal	Subcritical	-25	57(32)	55	0
Dehumidifier	Nominal	Subcritical	12	12(24)	45	0

Key

- ^a If airflow across the compressor or other external methods of cooling are used to determine ratings, they shall be specified by the compressor manufacturer.
- ^b Refer to [Annex A](#) about method to handle zeotropic mixtures.
- ^c Return gas temperature entering the compressor is assumed to be useful superheat for capacity calculation. The compressor manufacturer shall specify if the superheat is not the value in the table.
- ^d The compressor manufacturer shall specify if the subcooling is not the value in the table.
- ^e For transcritical type, this is the discharge pressure, expressed in bar.
- ^f For transcritical type, this is the temperature at the outlet of the gas cooler, expressed in °C.
- ^g Return gas temperature intentionally deviates from the dew point plus superheat, representing an alternative operating condition.

5 Published rating

5.1 General requirements

A published rating is one or more individual published rating that represents the compressor’s performance. The rating shall be published by single points under the rating conditions given in [4.2](#) or polynomial equation given in [5.4](#).

5.2 Individual published rating

The individual published rating of the compressor shall consist of parameters that are established through the rating conditions given in 4.2 or coefficients used in the polynomial equation given in 5.4, tested as specified in 4.1. The number of individual published ratings requirement for different modulating compressor is specified in 5.3. An individual published rating consists of data or coefficients for power input, refrigeration capacity or heating capacity, refrigerant mass flow rate, and current.

5.3 Number of individual published ratings requirement

The following requirements apply to individual published ratings used in the polynomial equation.

a) Fixed displacement compressor

The published rating of a fixed displacement compressor shall consist of an individual published rating at its single step.

b) Discrete modulating compressor

The published rating of a discrete modulating compressor shall be provided at every discrete step to comprise each set of individual published rating.

c) Continuous modulating compressor

The published rating of a continuous modulating compressor shall be provided at maximum and minimum step.

If the minimum step is greater than or equal to 40 % of the maximum step, at least one additional step of the compressor at an evenly spaced step (or steps) between the maximum and minimum step should be rated.

If the minimum step is less than 40 % of the maximum step, at least two additional steps of the compressor at evenly spaced steps between the maximum and minimum step should be rated.

Each step shall be evenly spaced between the maximum rated step and minimum rated step within ± 5 %.

5.4 Polynomial equations

ISO/PRF 18501

5.4.1 Ten-coefficient polynomial equation

<https://www.iso.org/standard/71010/aacc8a84-9c86-498d-a2a4-10da6451d111/iso-prf-18501>

A polynomial equation shall be used to present the individual published ratings, such as [Formula \(1\)](#), which is a third-degree equation of ten coefficients:

$$X = C_1 + C_2 \cdot T_S + C_3 \cdot T_D + C_4 \cdot T_S^2 + C_5 \cdot (T_S \cdot T_D) + C_6 \cdot T_D^2 + C_7 \cdot T_S^3 + C_8 \cdot (T_S \cdot T_D) + C_9 \cdot (T_S \cdot T_D^2) + C_{10} \cdot T_D^3 \quad (1)$$

where

- X is the power input, refrigerant mass flow, refrigerating capacity (or heating capacity);
- T_D is the discharge dew point temperature in subcritical cycles, expressed in °C, or the discharge pressure in transcritical cycles, expressed in bar;
- T_S is the suction dew point temperature, expressed in °C;
- C_1 through C_{10} are the regression coefficients provided by the manufacturer.