



FINAL DRAFT International Standard

ISO/FDIS 19880-2

Gaseous hydrogen — Fuelling stations —

Part 2:

Dispensers and dispensing systems

ISO/TC 197

Secretariat: **SCC**

Voting begins on:
2024-10-09

Voting terminates on:
2024-12-04

Standards
(<https://standards.iteh.ai>)
Document Preview

<https://standards.iteh.ai>
ISO/FDIS 19880-2

<https://standards.iteh.ai/catalog/standards/iso/e91ff714-6d6f-4c67-8ba8-d87308d0fd26/iso-fdis-19880-2>

RECIPIENTS OF THIS DRAFT ARE INVITED TO SUBMIT, WITH THEIR COMMENTS, NOTIFICATION OF ANY RELEVANT PATENT RIGHTS OF WHICH THEY ARE AWARE AND TO PROVIDE SUPPORTING DOCUMENTATION.

IN ADDITION TO THEIR EVALUATION AS BEING ACCEPTABLE FOR INDUSTRIAL, TECHNOLOGICAL, COMMERCIAL AND USER PURPOSES, DRAFT INTERNATIONAL STANDARDS MAY ON OCCASION HAVE TO BE CONSIDERED IN THE LIGHT OF THEIR POTENTIAL TO BECOME STANDARDS TO WHICH REFERENCE MAY BE MADE IN NATIONAL REGULATIONS.

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[ISO/FDIS 19880-2](https://standards.iteh.ai/catalog/standards/iso/e91ff714-6d6f-4c67-8ba8-d87308d0fd26/iso-fdis-19880-2)

<https://standards.iteh.ai/catalog/standards/iso/e91ff714-6d6f-4c67-8ba8-d87308d0fd26/iso-fdis-19880-2>



COPYRIGHT PROTECTED DOCUMENT

© ISO 2024

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Contents

	Page
Foreword	v
Introduction	vi
1 Scope	1
2 Normative references	1
3 Terms and definitions	2
4 General	7
5 Requirements	8
5.1 General material requirements.....	8
5.2 Construction and assembly requirements.....	9
5.2.1 General construction and assembly.....	9
5.2.2 Housings and cabinets.....	10
5.3 Dispenser hydrogen systems.....	10
5.4 Piping and fittings.....	11
5.5 Overpressure protection devices.....	12
5.6 Filters.....	12
5.7 Valves.....	13
5.8 Venting.....	13
5.9 Dispenser fuelling assembly.....	13
5.10 Breakaway devices.....	14
5.11 Instruments for gaseous hydrogen systems.....	14
5.12 Metering.....	15
5.13 Precoolers and precooling control.....	15
5.14 Electrical equipment and wiring.....	15
5.14.1 General electrical requirements.....	15
5.14.2 Bonding and grounding.....	15
5.14.3 Safety instrumented systems.....	15
5.14.4 Illumination.....	16
5.14.5 Payment terminals or fuelling authorizing systems.....	16
5.14.6 Electromagnetic compatibility and interference (EMC).....	16
5.15 Emergency shutdown system (ESS).....	16
6 Dispensing requirements	17
6.1 Control of dispensing.....	17
6.2 Dispensing temperature, pressure and flow rate.....	17
6.3 Pressure integrity check (leak check).....	17
6.4 Fuelling protocol and process limits.....	18
6.5 Post dispensing.....	18
7 Dispenser fault management	18
8 Marking	18
8.1 General requirements.....	18
8.2 Dispenser name plate.....	19
8.3 Self-serve dispenser instructions.....	19
9 Qualification tests	19
9.1 General.....	19
9.2 Standard test conditions.....	19
9.3 Proof pressure test.....	20
9.3.1 Acceptance criteria.....	20
9.3.2 Test method.....	20
9.4 Leakage test.....	20
9.4.1 Acceptance criteria.....	20
9.4.2 Test method.....	20
9.5 Impact test.....	20

ISO/FDIS 19880-2:2024(en)

9.5.1	Acceptance criteria	20
9.5.2	Test method	21
9.6	Dispenser shutdown test	21
9.6.1	Acceptance criteria	21
9.6.2	Test method	21
9.7	Hose rupture	22
9.7.1	General	22
9.7.2	Acceptance criteria	22
9.7.3	Test method	22
9.8	Hose breakaway test	23
9.8.1	Acceptance criteria	23
9.8.2	Test method	23
9.9	Prevention of electrostatic discharge	23
9.9.1	Acceptance criteria	23
9.9.2	Test method	23
9.10	Dispenser ground continuity test	24
9.10.1	Acceptance criteria	24
9.10.2	Test method	24
9.11	Dielectric voltage-withstand test	24
9.11.1	Acceptance criteria	24
9.11.2	Test method	24
9.12	Dispenser cabinet test	25
9.12.1	Acceptance criteria	25
9.12.2	Test method	25
9.13	Marking material adhesion and legibility test	25
9.13.1	Acceptance criteria	25
9.13.2	Test method	25
10	Routine tests	26
11	Product literature	26
11.1	General	26
11.2	Installation	26
11.3	Maintenance and service	26
11.4	Operation	27
Annex A	(Informative) Dispenser system types	28
Annex B	(Informative) Examples of hazardous area classification	30
Annex C	(Normative) Marking class requirements	33
	Bibliography	35

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO document should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

ISO draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). ISO takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, ISO had not received notice of (a) patent(s) which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at www.iso.org/patents. ISO shall not be held responsible for identifying any or all such patent rights.

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 197, *Hydrogen technologies*.

A list of all parts in the ISO 19880 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

[ISO/FDIS 19880-2](https://standards.iteh.ai/catalog/standards/iso/e91ff714-6d6f-4c67-8ba8-d87308d0fd26/iso-fdis-19880-2)

<https://standards.iteh.ai/catalog/standards/iso/e91ff714-6d6f-4c67-8ba8-d87308d0fd26/iso-fdis-19880-2>

Introduction

The purpose of this document is to promote the implementation of hydrogen-powered land vehicles through the creation of performance-based safety and testing requirements for compressed hydrogen fuel dispensers. The successful commercialization of hydrogen land vehicle technologies requires codes and standards pertaining to fuelling stations, vehicle fuel system components and the global homologation of standards requirements for technologies with the same end use. This will allow manufacturers to achieve economies of scale in production through the ability to manufacture one product for global use.

This document is a part of the ISO 19880 series for hydrogen fuelling stations with its scope limited to compressed hydrogen dispensers for land vehicles that use hydrogen as fuel. Dispensers are a major component of hydrogen fuelling stations, without which hydrogen vehicles will not become a significant element of mobility in the future. This document includes requirements for manufacture, commissioning and routine maintenance of dispensers in order to ensure the safe operation of dispensing hydrogen to vehicles.

Note [Annex A](#) has additional information about the range of options for dispenser systems.

iTeh Standards (<https://standards.iteh.ai>) Document Preview

[ISO/FDIS 19880-2](#)

<https://standards.iteh.ai/catalog/standards/iso/e91ff714-6d6f-4c67-8ba8-d87308d0fd26/iso-fdis-19880-2>

Gaseous hydrogen — Fuelling stations —

Part 2: Dispensers and dispensing systems

1 Scope

This document specifies safety requirements and test methods for the components and systems that enable the transfer of compressed hydrogen to a hydrogen vehicle, as addressed in ISO 19880-1, by a hydrogen dispenser with dispensing pressures up to the H70 pressure class designation.

This document applies to a hydrogen dispensing system, referred to as a “dispenser”; the configuration of the dispenser can range from:

- a) a dispenser cabinet, located in the fuelling area, that can perform all of the functionality needed to deliver hydrogen to a vehicle, to
- b) a minimum set of components mounted in or on (as applicable) a dispenser cabinet or other supporting structure as appropriate, with the remaining functionality provided elsewhere in the hydrogen fuelling station.

A dispensing system includes the user and vehicle interface and can include components starting from the hydrogen supply, such as a connection to the banking system, a cooling unit, a dispenser control system, a flow meter, a pressure sensor, a fuel temperature sensor, an ambient temperature sensor, user interface and a fuelling hose assembly. Not all dispensing system equipment has to be physically housed within the enclosure at the dispensing area, as long as the specification of component design or type and location are adequate to ensure that the overall process meets the requirements in this document.

This document specifies the requirements for hydrogen dispensers and can provide specific references to other standards for individual components included in the hydrogen dispenser, such as valves (ISO 19880-3) and hoses (ISO 19880-5).

This document specifies general requirements for supporting the fuelling protocol and directs the user to ISO 19880-1 for additional requirements and the test methods required to verify proper fuelling protocol implementation.

This document does not specify the accuracy of flow meters that can be used to meter dispensed fuel.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 3601-1, *Fluid power systems — O-rings — Part 1: Inside diameters, cross-sections, tolerances and designation codes*

ISO 3601-2, *Fluid power systems — O-rings — Part 2: Housing dimensions for general applications*

ISO 3601-3, *Fluid power systems — O-rings — Part 3: Quality acceptance criteria*

ISO 3864-2, *Graphical symbols — Safety colours and safety signs — Part 2: Design principles for product safety labels*

ISO 4126 (all parts), *Safety devices for protection against excessive pressure*

ISO/FDIS 19880-2:2024(en)

ISO 80079-36, *Explosive atmospheres — Part 36: Non-electrical equipment for explosive atmospheres — Basic method and requirements*

ISO 80079-37, *Explosive atmospheres — Part 37: Non-electrical equipment for explosive atmospheres — Non-electrical type of protection constructional safety "c", control of ignition sources "b", liquid immersion "k"*

ISO 14687, *Hydrogen fuel quality – Product specification*

ISO 15649, *Petroleum and natural gas industries — Piping*

ISO 17268, *Gaseous hydrogen land vehicle refuelling connection devices*

ISO 19880-1:2020, *Gaseous hydrogen — Fuelling stations — Part 1: General requirements*

ISO 19880-3, *Gaseous hydrogen — Fuelling stations — Part 3: Valves*

ISO 19880-5, *Gaseous hydrogen – Fuelling stations – Part 5: Dispenser hoses and hose assemblies*

IEC 60079 (all parts), *Explosive atmospheres*

IEC 60204-1, *Safety of machinery – Electrical equipment of machines – Part 1: General requirements*

IEC 60364, *Low-voltage electrical installations*

IEC 60529, *Degrees of protection provided by enclosures (IP Code)*

SAE J2600, *Compressed Hydrogen Surface Vehicle Fuelling Connection Devices*

SAE J2601, *Fuelling Protocols for Light Duty Gaseous Hydrogen Surface Vehicles*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

— ISO Online browsing platform: available at <https://www.iso.org/obp>

— IEC Electropedia: available at <https://www.electropedia.org/>

3.1

breakaway device

device on the *fuelling hose* (3.11) that disconnects the hose from the *dispenser* (3.5) when a tension limit is exceeded and blocks the flow of hydrogen from the *dispenser* (3.5), e.g. if the vehicle moves away with the *fuelling hose* (3.11) connected to the vehicle

[SOURCE: ISO 19880-1:2020, 3.50]

3.2

component pressure rating

maximum pressure at which it is permissible to operate a component as specified by the *manufacturer* (3.15) at a specified temperature

Note 1 to entry: Components designed with a maximum allowable pressure per the European PED represent the component pressure rating by the *manufacturer* (3.15) as indicated by the value of “PS”.

Note 2 to entry: See Annex E of ISO 19880-1 for discussion of pressure terminology and its application to *dispensing systems* (3.6).

Note 3 to entry: Unless otherwise specified, the pressure in this document is expressed in gauge pressure.

[SOURCE: ISO 19880-1:2020, 3.10 modified – Notes 2 to 4 to entry deleted with Note 5 to entry of the source definition renumbered as Note 2 to entry.]

3.3

control system

system which responds to input signals from the process and/or from an operator and generates output signals causing the process to operate in the desired manner

[SOURCE: ISO 19880-1:2020, 3.11 modified – Note 1 to entry deleted.]

3.4

flow coefficient

C_v

coefficient to represent the flow rate of fluid that a *valve* (3.28) is capable of handling

Note 1 to entry: C_v is the flow coefficient of a *valve* (3.28) with the fluid at 15,56 °C under a pressure difference of 6 894 N/m² (= Pa)

3.5

dispenser

equipment in the *dispensing system* (3.6), including the dispenser cabinet(s) and supporting structure, that is physically located in the fuelling area

Note 1 to entry: The hydrogen dispenser typically includes, as a minimum, the *fuelling assembly* (3.10), required temperature and pressure instrumentation, filters and the user interface to conduct vehicle fuelling.

Note 2 to entry: The *manufacturer* (3.15) of the hydrogen dispenser can elect to include additional equipment in the dispenser, including the possibility of all equipment in the *dispensing system* (3.6).

[SOURCE: ISO 19880-1:2020, 3.13]

3.6

dispensing system

system downstream of the hydrogen supply system comprising all equipment necessary to carry out the vehicle fuelling operation, through which the compressed hydrogen is supplied to the vehicle

[SOURCE: ISO 19880-1:2020, 3.17]

3.7

emergency shutdown system

ESS system which responds to automatic and/or manually activated emergency shutdown devices to stop hazardous movements and operations such as the flow of hydrogen gas to the *dispenser* (3.5) and vehicle

3.8

enclosure

structure, *protective housing* (3.13), container, machine cabinet, etc., which encloses or partially encloses equipment of a station that may have access for maintenance but is not intended to be occupied

Note 1 to entry: In this document the enclosure of the *dispenser* (3.5) is defined as a “dispenser cabinet”.

Note 2 to entry: Some hydrogen station *manufacturers* (3.15) may build an all-in-one *fuelling station* (3.12) where the dispenser components are built into one side or end of the equipment enclosure without using a separate dispenser cabinet.

Note 3 to entry: The use of an enclosure could be to protect equipment from the environment, provide noise attenuation or provide safety to the areas surrounding the equipment.

[SOURCE: ISO 19880-1:2020, 3.18 modified – Notes 1 and 2 to entry are newly inserted, the original Note 1 to entry is renumbered as Note 3 to entry and the original Note 2 to entry deleted.]

**3.9
fitting**

part or design feature on a component used to join (i.e., connect) any pressure-retaining components in the system

[SOURCE: ISO 19880-1:2020, 3.24]

**3.10
fuelling assembly**

part of the *dispenser* (3.5) providing the interface between the hydrogen *fuelling station* (3.12) and the vehicle — an assembly consisting of a *breakaway device* (3.1), a hose(s), a *nozzle* (3.19) and connections between these components

Note 1 to entry: The fuelling assembly can include, or not include, a nozzle vent line (with hose *breakaway device* (3.1) and hose) depending on the type of *nozzle* (3.19), and communications, if used.

[SOURCE: ISO 19880-1:2020, 3.26]

**3.11
fuelling hose**

flexible conduit used for dispensing gaseous hydrogen to vehicles through a fuelling *nozzle* (3.19)

[SOURCE: ISO 19880-1:2020, 3.27]

**3.12
fuelling station**

facility for the dispensing of compressed hydrogen vehicle fuel, often referred to as a hydrogen refuelling station (HRS) or hydrogen filling station, including the supply of hydrogen, and hydrogen compression, storage and *dispensing systems* (3.6)

[SOURCE: ISO 19880-1:2020, 3.29]

**3.13
housing**

guard or *enclosure* (3.8) for operating parts, control mechanisms, or other components, that need not be accessible during normal operation

Note 1 to entry: Housing may be synonymous with: *enclosure* (3.8), cabinet or frame.

[SOURCE: ISO 19880-1:2020, 3.40]

**3.14
hydrogen service level
HSL**

pressure level in MPa used to characterize the hydrogen service of the *dispensing system* (3.6) based on the NWP rating of the vehicle

Note 1 to entry: The numerical value of HSL also matches the number after the “H” in *pressure class* (3.20) (see Table 1 in ISO 19880-1).

Note 2 to entry: See Annex E of ISO 19880-1 for application of pressure terminology to hydrogen-dispensing systems and vehicles.

[SOURCE: ISO 19880-1:2020, 3.42]

**3.15
manufacturer**

person or organization responsible for the design and manufacturer of the equipment and components

3.16

maximum allowable working pressure

MAWP

maximum pressure permissible in a system at the temperature specified for the pressure

Note 1 to entry: The maximum allowable working pressure can also be defined as the design pressure, the maximum allowable operating pressure, the maximum permissible working pressure or the maximum allowable pressure for the rating of pressure vessels and equipment manufactured in accordance with national pressure vessel codes.

Note 2 to entry: See Annex E of ISO 19880-1 for a discussion of pressure terminology and the application to *dispensing systems* (3.6) and *fuelling stations* (3.12) in general.

[SOURCE: ISO 19880-1:2020, 3.45]

3.17

maximum operating pressure

MOP

highest pressure that is expected for a component or system during normal operation, including anticipated transients

Note 1 to entry: In the case of the *dispensing system* (3.6), the MOP is equivalent to the maximum fuelling pressure of the vehicle.

Note 2 to entry: See Annex E of ISO 19880-1 for a discussion of pressure terminology and the application to *dispensing systems* (3.6) and *fuelling stations* (3.12) in general.

[SOURCE: ISO 19880-1:2020, 3.47]

3.18

nominal working pressure

NWP

pressure of a vehicle compressed hydrogen storage system (CHSS) at 100 % SOC (3.27) at a gas temperature of 15 °C

Note 1 to entry: For further guidance on pressure terminology and associated equipment ratings, see Annex E of ISO 19880-1.

[SOURCE: ISO 19880-1:2020, 3.51 modified – Notes 1 to 4 to entry deleted and new Note 1 to entry inserted.]

3.19

nozzle

device connected to a fuel *dispensing system* (3.6) which permits the quick connect and disconnect of fuel supply to the *receptacle* (3.22) of the vehicle or storage system

[SOURCE: ISO 17268: 2012, 3.11]

3.20

pressure class

non-dimensional rating of components designed to dispense hydrogen to road vehicles at the required pressure

Note 1 to entry: The numbers following “H” in the pressure class are numerically the same as HSL, but the HSL identifies only the level of the dispensing service whereas the pressure class designation shows that the component is fully capable of meeting the pressure and temperature requirements for dispensing hydrogen at the indicated service level.

Note 2 to entry: See Annex E of ISO 19880-1 for a discussion of pressure terminology and its application to *dispensing systems* (3.6) and *fuelling stations* (3.13) in general.

[SOURCE: ISO 19880-1:2020, 3.58 modified – Note 3 to entry deleted]

3.21

pressure relief device

PRD

safety device that releases gases or liquids above a specified pressure value in cases of emergency or abnormal conditions

Note 1 to entry: PRDs can be activated by pressure or another parameter, such as temperature, and can be either re-closing devices (such as *valves* (3.28)) or non-re-closing devices (such as rupture disks and fusible plugs). Common designations for these specific types of PRDs are as follows:

- Pressure Safety Valve (PSV) – pressure-activated *valve* (3.28) that opens at a specified set point to protect a system from overpressure and re-closes when the pressure falls below the set point requirements for PRVs used in *dispensing systems* (3.6) can be found in 8.2.2.3 of ISO 19880-1. PSVs protecting the *dispensing system* (3.6) can re-close above the *MOP* (3.17).
- Thermally-activated Pressure Relief Device (TPRD) – a PRD that opens at a specified temperature to protect a system from rupture and remains open.

Note 2 to entry: See Annex E of ISO 19880-1 for discussion of pressure terminology and its application to pressure protection of the dispensing system and *fuelling stations* (3.12) in general.

[SOURCE: ISO 19880-1:2020, 3.59]

3.22

receptacle

device connected to a vehicle storage system which receives the *nozzle* (3.19)

Note 1 to entry: This can also be referred to as a fuelling inlet or gas filling port in other documents.

[SOURCE: ISO 17268: 2020, 3.15]

3.23

risk assessment

determination of quantitative or qualitative value of risk related to a specific situation and a recognized threat (also called hazard)

Note 1 to entry: Based on national requirements, a review of a risk analysis or a safety concept by third party is sometimes required.

<https://standards.iteh.ai/catalog/standards/iso/e91ff714-6d6f-4c67-8ba8-d87308d0fd26/iso-fdis-19880-2>

[SOURCE: ISO 19880-1:2020, 3.66]

3.24

safety function

function to be implemented by a safety-instrumented system, which is intended to achieve or maintain a safe state for the process, with respect to a specific hazardous situation

Note 1 to entry: Other technologies or risk reduction measures have a safety function not achieved through a safety-instrumented system, however validation of these measures is equally important.

[SOURCE: ISO 19880-1:2020, 3.71]

3.25

safety instrumented system

SIS

instrumented system used to implement one or more safety instrumented functions

Note 1 to entry: A safety instrumented system (SIS) is composed of any combination of sensors, logic solvers, and final elements.

Note 2 to entry: A separate safety-instrumented system (SIS), typically with a greater reliability than the more basic process control system, can be required, according to the *manufacturer's* (3.15) *risk assessment* (3.23), to respond solely to safety critical alarms. Further information is provided by IEC 61508 and IEC 61511.

[SOURCE: ISO 19880-1:2020, 3.72]