

2023-12-18

ISO/~~DIS~~FDIS 13351:2023(E)

ISO/TC 117

Secretariat:-BSI

Date: 2024-05-14

Fans — Dimensions

Ventilateurs — Dimensions

iTeh Standards
(<https://standards.iteh.ai>)

FDIS stage

ISO/FDIS 13351

<https://standards.iteh.ai/catalog/standards/iso/e495b5cc-3da8-4b3b-bb66-c38f77d9e99f/iso-fdis-13351>

~~Edited DIS -~~
~~MUST BE USED~~
~~FOR FINAL~~
~~DRAFT~~

© ISO ~~2023~~2024

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11

~~Fax: +41 22 749 09 47~~

~~Email~~E-mail: copyright@iso.org
Website: ~~www.iso.org~~www.iso.org

Published in Switzerland

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

ISO/FDIS 13351

<https://standards.iteh.ai/catalog/standards/iso/e495b5cc-3da8-4b3b-bb66-c38f77d9e99f/iso-fdis-13351>

Contents—Page

Foreword.....iv

Introduction.....v

1 Scope.....1

2 Normative references.....1

3 Terms, definitions and symbols1

3.1 Terms and definitions.....1

3.2 Symbols4

4 Requirements.....5

4.1 General.....5

4.2 Circular flanges.....5

4.3 Rectangular flanges.....10

4.4 Designation of fan size16

Bibliography18

Foreword.....iv

Introduction.....v

1 Scope.....1

2 Normative references.....1

3 Terms, definitions and symbols1

4 Requirements.....3

4.1 General.....3

4.2 Circular flanges.....4

4.3 Rectangular flanges.....7

4.4 Designation of fan size12

Bibliography13

~~Edited DIS -~~
~~MUST BE USED~~
~~FOR FINAL~~
~~DRAFT~~

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO document should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

ISO draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). ISO takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, ISO ~~had~~/had not ~~received~~ notice of (a) patent(s) which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at www.iso.org/patents. ISO shall not be held responsible for identifying any or all such patent rights.

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 117, *Fans*, in collaboration with the European Committee for Standardization (CEN) Technical Committee CEN/TC 156, *Ventilation for buildings*, in accordance with the Agreement on technical cooperation between ISO and CEN (Vienna Agreement).

This third edition cancels and replaces the second edition (ISO 13351:2009), which has been technically revised.

The main changes are as follows:

- ~~added~~ added to the sizes of the heavy-duty fans in ~~Table 3~~ [Table 3](#);
- ~~aligned~~ aligned definitions and symbols to ISO 13349-1;
- ~~clarified~~ [Figure 3](#) for mixed flow fan.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

Introduction

This document gives dimensional details of circular and rectangular flanges of fans in addition to specifying the fan size designation. For circular flanges, the values specified in ISO 6580¹⁾ have been retained for light-duty fans, in parallel with those values given in ~~Tables 3~~**Tables 3** and ~~4~~**4** for medium- and heavy-duty fans.

While it does not constrain the manufacturer's choice of flange details, this document facilitates interchangeability, thereby helping reduce technical barriers to trade.

Throughout this document, the principal dimensions are based on the rounded values of preferred numbers given in ISO 497.

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

ISO/FDIS 13351

<https://standards.iteh.ai/catalog/standards/iso/e495b5cc-3da8-4b3b-bb66-c38f77d9e99f/iso-fdis-13351>

~~Edited DIS -~~
~~MUST BE USED~~
~~FOR FINAL~~
~~DRAFT~~

¹⁾ Cancelled and replaced by ISO 13351

Fans — Dimensions

1 Scope

This document specifies the dimensions of the circular and rectangular flanges of general-purpose fans, as well as the fan size designations. It is not applicable to cross-flow fans or to fan appliances used for individual household or similar applications.

For circular flanges, it provides for three different flange series: one for light-duty casing thicknesses, another for medium-duty fans and the third for heavy-duty fans as used on sea-going vessels or in heavy industry.

In order not to restrict fan design unduly, only the pitch diameter, hole numbers and hole diameters are specified. Flange thickness, as well as internal and external flange diameters, can be chosen freely within the limits of good engineering practice.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 3, *Preferred numbers — Series of preferred numbers*

ISO 13349-1, *Fans — Vocabulary and definitions of categories — Part 1: Vocabulary*

ISO 13349-2, *Fans — Vocabulary and definitions of categories — Part 2: Categories*

3 Terms, definitions and symbols

For the purposes of this document, the terms and definitions given in ISO 13349-1, ISO 13349-2 and the following apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <https://www.electropedia.org/>

3.1 Terms and definitions

3.1.1

light-duty fan

fan suitable for air that is non-toxic, not saturated, non-corrosive, non-flammable, free from abrasive particles, and not exceeding a temperature of 80 °C, or 40 °C if the motor or the fan bearings are in the air stream, and for pressures up to 2 kPa

Note 1 — See Table 1.

3.1.2

medium-duty fan

fan designed for pressures up to 10 kPa.

Note: ~~applications 1 to entry: Applications~~ that require a robust design can be referred to as "medium duty"~~-~~, such as in marine applications.

3.1.3

heavy~~-~~duty fan

fan designed for pressures up to 40~~-~~kPa.

Note: ~~applications 1 to entry: Applications~~ that require a more robust design can be referred to as "heavy duty"~~-~~, such as in marine applications.

3.1.4


nominal impeller tip diameter

D

diameter of the impeller tip on which the design of the fan is based


Note ~~1 to entry:~~ See ~~Figures 1~~ **Figures 1** to ~~3.3.~~

-




- ^b D may be smaller than, larger than or equal to D_R .

Figure 1 — Impeller — Centrifugal fan



- ^b D may be smaller than, larger than or equal to D_R .

Figure 2 — Impeller — Axial-flow fan



^b D may be smaller than, larger than or equal to D_R .

Figure 3 — Impeller — Mixed-flow fan

3.2 Symbols

Symbol	Parameter	Unit
D	nominal impeller tip diameter	mm
D_R	impeller tip diameter ^a	mm (see Figures 1 to 3) mm (see Figures 1 to 3)
d_0	internal duct diameter	mm
d_1	pitch circle diameter	mm
d_2	hole diameter	mm
d_3	bolt diameter	mm