



Designation: ~~C302 – 95 (Reapproved 2007)~~ C302 – 13

Standard Test Method for Density and Dimensions of Preformed Pipe-Covering-Type Thermal Insulation¹

This standard is issued under the fixed designation C302; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

This standard has been approved for use by agencies of the U.S. Department of Defense.

1. Scope

1.1 This test method covers the determination of the dimensions and density, after conditioning, of preformed pipe insulation.

1.1.1 Procedure A is applicable to sections of one-piece pipe covering or to sections of segmental pipe covering that can be joined together concentrically and measured as one-piece.

1.1.2 Procedure B is applicable to segmental pipe covering where each section of material is measured.

1.1.3 Procedure C is applicable to sections of one-piece pipe covering, such as soft foam or mineral wool materials, where it is possible to penetrate the material.

1.2 The values stated in inch-pound units are to be regarded as the standard. The values given in parentheses are for information only.

1.3 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

2. Referenced Documents

2.1 *ASTM Standards:*²

[C167 Test Methods for Thickness and Density of Blanket or Batt Thermal Insulations](#)

[C168 Terminology Relating to Thermal Insulation](#)

[C670 Practice for Preparing Precision and Bias Statements for Test Methods for Construction Materials](#)

[C870 Practice for Conditioning of Thermal Insulating Materials](#)

[E691 Practice for Conducting an Interlaboratory Study to Determine the Precision of a Test Method](#)

3. Terminology

3.1 *Definitions*—See Terminology [C168](#).

4. Summary of Test Method

4.1 The material to be tested is conditioned to constant weight. The density of the pipe insulation is calculated from the conditioned mass and measured dimensions.

5. Significance and Use

5.1 Density measurements of preformed pipe insulation are useful in determining compliance of a product with specification limits and in providing a relative gage of product weights. For any one kind of insulation some important physical and mechanical properties, such as thermal conductivity, heat capacity, strength, etc., bear a specific relationship with its density; however, on a density basis, these properties are not directly comparable with those for other kinds of material.

¹ This test method is under the jurisdiction of ASTM Committee [C16](#) on Thermal Insulation and is the direct responsibility of Subcommittee [C16.32](#) on Mechanical Properties.

Current edition approved ~~March 1, 2007~~ Nov. 1, 2013. Published ~~April 2007~~ December 2013. Originally approved in 1952. Last previous edition approved in ~~2004~~ 2007 as C302 – 95 (Reapproved 2007). ¹—DOI: [10.1520/C0302-95R07](#); [10.1520/C0302-13](#).

² For referenced ASTM standards, visit the ASTM website, [www.astm.org](#), or contact ASTM Customer Service at [service@astm.org](#). For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

5.2 The physical dimensions of preformed pipe insulation are important quantities not only for determining the density of the pipe insulation but also for determining the conformance to specifications. The use of multilayer insulations is common, and the dimensions are necessary to ensure proper nesting of the layers.

6. Apparatus

- 6.1 *Flexible Steel Rule*, graduated in $\frac{1}{32}$ -in. or 1.0-mm intervals.
- 6.2 *Scale*, with sufficient capacity to weigh the specimen to within 0.01 lb or 5 g.
- 6.3 *Pin Probe*, as defined in Test Methods C167.
- 6.4 *Steel Rule*, graduated in $\frac{1}{32}$ -in. or 1.0-mm intervals.
- 6.5 *Stainless Steel Shim Stock*, 2 in. (75 mm) wide, longer than the circumference of the pipe insulation, and 0.010 in. (0.25 mm) thick.
- 6.6 *Pi Tape*, graduated to read a diameter directly to the nearest $\frac{1}{32}$ in. or 1.0 mm.
- 6.7 *Pieces of Pipe*, on which to install the pipe insulation under test (only required for Procedure 3).

7. Test Specimen

- 7.1 The test specimen shall be of a commercial size.
- 7.2 If sectional pipe segments are to be used for Procedures 1 or 3, the sections shall be joined together to form a hollow cylinder.

8. Conditioning

- 8.1 Remove any jacket on the specimen unless it is of a type that would cause disintegration of the specimen upon removal.
- 8.2 Condition the specimen to constant mass in accordance with Practice C870.

9. Procedures

- 9.1 *One-Piece Pipe Section:*
 - 9.1.1 Weigh the conditioned pipe section to the nearest 0.01 lb or 5 g.
 - 9.1.2 Measure the length of the specimen in six locations, uniformly spaced around its circumference, to the nearest $\frac{1}{32}$ in. or 1.0 mm.