
Sistemi za zaščito pred eksplozijo - 2. del: Ugotavljanje eksplozijskih karakteristik gorljivih plinov v zraku

Explosion protection systems - Part 2 : Determination of explosion indices of combustible gases in air (ISO 6184-2:1985)

Explosions-Schutzsysteme - Teil 2 : Bestimmung der Explosionskenngößen von brennbaren Gasen in Luft (ISO 6184-2:1985)

Systemes de protection contre les explosions - Partie 2 : Détermination des indices d'explosion des gaz combustibles dans l'air (ISO 6184-2:1985)

<https://standards.iteh.ai/catalog/standards/sist/200440e1-4be2-48de-bea8-3694701bb836/sist-en-26184-2-1996>

Ta slovenski standard je istoveten z: EN 26184-2:1991

ICS:

13.230 Varstvo pred eksplozijo Explosion protection

SIST EN 26184-2:1996 en

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 26184-2:1996

<https://standards.iteh.ai/catalog/standards/sist/200440e1-4be2-48de-bea8-3694701bb836/sist-en-26184-2-1996>

EUROPEAN STANDARD

EN 26 184

NORME EUROPEENNE

Part 2

EUROPAISCHE NORM

January 1991

UDC 614.835:614.833.4

Key words: Explosions, explosion proofing, burning gases, tests, explosion index

English version

Explosion protection systems - Part 2:
Determination of explosion indices of combustible
gases in air (ISO 6184-2:1985)Systèmes de protection contre les
explosions - Partie 2: Détermination
des indices d'explosion des gaz
combustibles dans l'air (ISO
6184-2:1985)Explosions-Schutzsysteme - Teil 2:
Bestimmung der Explosionskenngrößen
von brennbaren Gasen in Luft (ISO
6184-2:1985)

This European Standard was accepted by CEN on 1990-10-05 and is identical to the ISO standard as referred to.

CEN members are bound to comply with the requirements of the CEN/CENELEC Common Rules which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN Central Secretariat or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to CEN Central Secretariat has the same status as the official versions.

CEN members are the national standards organizations of Austria, Belgium, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and United Kingdom.

CEN

European Committee for Standardization
Comité Européen de Normalisation
Europäisches Komitee für Normung

Central Secretariat: rue Bréderode 2, B-1000 Brussels

(c) CEN 1991 Copyright reserved to all CEN members

Ref. No. EN 26184-2:1991 E

Page 2
EN 26184-2:1991

FOREWORD

Based on the positive result of the Formal Vote procedure, the International Standard:

ISO 6184-2:1985 "Explosion protection systems - Part 2: Determination of explosion indices of combustible gases in air"

is adopted as a European Standard.

In accordance with the Common CEN/CENELEC Rules, the following countries are bound to implement this standard:

Austria, Belgium, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and United Kingdom.

(standards.iteh.ai)

SIST EN 26184-2:1996

[https://standards.iteh.ai/catalog/standards/sist/200440e1-4be2-48de-bea8-](https://standards.iteh.ai/catalog/standards/sist/200440e1-4be2-48de-bea8-3694701bb836/sist-en-26184-2-1996)

[3694701bb836/sist-en-26184-2-1996](https://standards.iteh.ai/catalog/standards/sist/200440e1-4be2-48de-bea8-3694701bb836/sist-en-26184-2-1996)

ENDORSEMENT NOTICE

The text of the International Standard ISO 6184-2, edition 1985 was approved by CEN as a European Standard without any modification.

International Standard



6184/2

INTERNATIONAL ORGANIZATION FOR STANDARDIZATION • МЕЖДУНАРОДНАЯ ОРГАНИЗАЦИЯ ПО СТАНДАРТИЗАЦИИ • ORGANISATION INTERNATIONALE DE NORMALISATION

Explosion protection systems — Part 2: Determination of explosion indices of combustible gases in air

Systèmes de protection contre les explosions — Partie 2: Détermination des indices d'explosion des gaz combustibles dans l'air

First edition — 1985-11-15

iteh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN 26184-2:1996](https://standards.iteh.ai/catalog/standards/sist/200440e1-4be2-48de-bea8-3694701bb836/sist-en-26184-2-1996)

<https://standards.iteh.ai/catalog/standards/sist/200440e1-4be2-48de-bea8-3694701bb836/sist-en-26184-2-1996>

UDC 614.835

Ref. No. ISO 6184/2-1985 (E)

Descriptors : explosion proofing, burning gases, tests, explosion index.

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work.

Draft International Standards adopted by the technical committees are circulated to the member bodies for approval before their acceptance as International Standards by the ISO Council. They are approved in accordance with ISO procedures requiring at least 75 % approval by the member bodies voting.

International Standard ISO 6184/2 was prepared by Technical Committee ISO/TC 21, *Equipment for fire protection and fire fighting*.

Users should note that all International Standards undergo revision from time to time and that any reference made herein to any other International Standard implies its latest edition, unless otherwise stated.

Explosion protection systems — Part 2: Determination of explosion indices of combustible gases in air

0 Introduction

0.1 The assessment of measures required to provide protection against explosion hazards involving combustible gas/air mixtures requires prior determination of the potential explosion severity of such mixtures, by the measurement of explosion indices. Conversely, the measurement of the effectiveness and performance of explosion protection systems requires that they should be tested against explosions of known severity.

The severity of a combustible gas explosion is a function of the following:

- a) the chemical properties of the combustible gas;
- b) the concentration of the combustible gas in the gas/air mixture;
- c) the homogeneity and turbulence of the combustible gas/air mixture;
- d) the type, energy, and location of the ignition source;
- e) the geometry of the container;
- f) the temperature, and pressure of the combustible gas/air mixture.

0.2 This part of ISO 6184 is one of a series dealing with explosion protection systems. The other parts are as follows:

Part 1: Determination of explosion indices of combustible dusts in air.

Part 3: Determination of explosion indices of fuel/air mixtures other than dust/air and gas/air mixtures.

Part 4: Determination of efficacy of explosion suppression systems.

0.3 The interpretation of explosion indices determined by the method specified in this part of ISO 6184 and their relation to the development of explosions in commonly encountered ex-

plosion hazards should be recognized. In particular, the degree of turbulence can influence the hazard significantly. In practice, the link between a given degree of turbulence and a specific type of hazard is the responsibility of specialists in the fields of explosions and explosion protection.

Two extremes of turbulence commonly encountered in industrial plants are:

- a) quiescent conditions prevailing in storage vessels;
- b) high turbulence conditions prevailing in the region of an extraction fan.

It should be realized that turbulence can arise in two ways:

- a) turbulence intrinsic to the plant, under normal operating conditions, as a consequence of perturbations to the air-flow;
- b) turbulence induced by obstructions within an installation on a gas which expands as the result of an explosion.

1 Scope

This part of ISO 6184 specifies a method for the determination of the explosion indices of combustible gases with air in an enclosed space. It gives the criteria by which results obtained using other test procedures can be correlated to yield explosion indices as determined by the method specified in this part of ISO 6184.

2 Field of application

This part of ISO 6184 is applicable only to the determination of explosion indices pertaining to the development of contained gas/air explosions after ignition of reactants. It does not apply to indices pertaining to the conditions necessary to cause

ISO 6184/2-1985 (E)

ignition of the reactants. If the specified experimental procedure for the determination of explosion indices does not result in ignition of the gas/air mixture, it should not be concluded that the gas in question cannot explode. The interpretation of such cases should be left to specialists in the field of explosions and explosion protection.

3 Definitions

For the purpose of this part of ISO 6184 the following definitions apply.

3.1 explosion: Propagation of a flame in a pre-mixture of combustible gases, suspended dust(s), combustible vapour(s), mist(s), or mixtures thereof, in a gaseous oxidant such as air, in a closed, or substantially closed, vessel.

3.2 explosion index: Numerical term, determined in accordance with the test methods specified in this part of ISO 6184, which characterizes the contained explosion of a specified concentration of reactants in a vessel having a volume of 1 m³.

NOTE — Figure 1 shows the pressure/time curve, expressed in bars¹⁾ and seconds respectively, of a typical explosion.

3.2.1 explosion index p_m : Maximum overpressure relative to the pressure in the vessel at the time of ignition attained during an explosion.

3.2.2 explosion index p_{max} : Maximum value of the explosion index p_m determined by tests over a wide range of reactant concentrations.

3.2.3 explosion index K : Constant defining the maximum rate of pressure rise with time $(dp/dt)_m$ of an explosion in a volume V , according to the equation

$$K = \left(\frac{dp}{dt} \right)_m \times V^{1/3}$$

NOTE — Under certain circumstances, this equation is not valid for vessels with a length to diameter ratio greater than 2 : 1 or with a volume of less than 1 m³.

3.2.4 explosion index K_{max} : Maximum value of the explosion index K determined by tests over a wide range of reactant concentrations. The violence of an explosion is evaluated from the value of K_{max} .

3.3 turbulence index: Numerical term which characterizes the degree of turbulence in the experimental conditions under which the explosion indices are determined.

3.3.1 turbulence index t_v (ignition delay): Experimental parameter defined as the time interval between the initiation of a gas/air injection procedure in an experimental apparatus, and the activation of the ignition source. It characterizes the degree of turbulence prevailing at the moment of ignition.

3.3.2 turbulence index T_u : Ratio of the explosion index $K_{max, turbulent}$ determined as specified in this part of ISO 6184 to the explosion index $K_{max, quiescent}$ of the quiescent reactants. It is given by the equation

$$T_u = \frac{K_{max, turbulent}}{K_{max, quiescent}}$$




Figure 1

1) 1 bar = 10⁵ Pa

4 Test method

4.1 General

The experimental apparatus described in this part of ISO 6184 is chosen as an example, and is suitable for the evaluation of explosion indices of combustible gases in air.

4.2 Apparatus

The apparatus consists essentially of a cylindrical explosion chamber with a volume of 1 m³ and an aspect ratio nominally of 1 : 1, as shown in figure 2.

A container of approximately 5 l capacity is attached to the explosion chamber and is capable of being pressurized with air to 20 bar. This container is fitted with a 19 mm (3/4 in) quick-opening valve which allows injection of the contents of the container within 10 ms of opening the valve. The container is connected to the explosion chamber by means of a 19 mm (3/4 in) internal diameter tube which is formed into a perforated (4 to 6 mm hole diameter) semicircular spray pipe. The number of holes in the pipe shall be chosen such that their total cross-sectional area is approximately 300 mm².

Combustible gas/air mixtures, quiescent or turbulent, shall be ignited with an electric spark with an ignition energy greater than the minimum ignition energy for the material being tested.

For example, a suitable ignition source is a series of induction sparks sustained for 0,5 s.

NOTE — A suitable ignition source is produced by using a high voltage transformer (approximately 300 VA) with an output of 15 kV (effective value).

The spark gap should normally be 3 to 5 mm and shall be located in the geometric centre of the test apparatus.

The apparatus is arranged so that the ignition delay (turbulence index t_v) can be varied if necessary from test to test.

A pressure transducer is fitted to measure explosion chamber pressure, this being linked to a recorder.

NOTE — If a very high ignition energy is chosen, it is possible that the results will deviate from those obtained using a low energy ignition source, such as described above.

4.3 Procedure

4.3.1 Quiescent gas explosion test

Prepare the gas/air mixture in the 1 m³ chamber by, for example, the method of partial pressures, the resultant mixture being at atmospheric pressure. It is important that the correctness and the homogeneity of the required gas/air mixture is verified. Ensure that the mixture is allowed to become quiescent. Start the pressure recorder and then activate the ignition source. Upon completion of each test, purge the explosion chamber with air.




Figure 2