

# SLOVENSKI STANDARD SIST EN 1568-3:2001

01-marec-2001

# ; Ug]`U!`DYb]`U!` "XY`.`8 c`c ]`UnUdYb]`UnUhYÿ\_c`dYbc`nUdcjfý]bg\_c`i dcfUVc`df] hY\_c ]bU\ žbYhcdb]\ 'j 'j cX]

Fire extinguishing media - Foam concentrates - Part 3: Specification for low expansion foam concentrates for surface application to water-immiscible liquids

Feuerlöschmittel - Schaummittel - Teil 3: Anforderungen an Schaummittel zur Erzeugung von Schwerschaum zum Aufgeben auf nicht-polare Flüssigkeiten

Agents extincteurs - Emulseurs - Partie 3: Spécifications pour les émulseurs bas foisonnement destinés a une application a la surface des liquides n'ayant pas d'affinité pour l'eau

Ta slovenski standard je istoveten z: EN 1568-3:2000

ICS:

13.220.10 Gašenje požara Fire-fighting

SIST EN 1568-3:2001 en

# iTeh STANDARD PREVIEW (standards.iteh.ai)

# EUROPEAN STANDARD NORME EUROPÉENNE EUROPÄISCHE NORM

EN 1568-3

October 2000

ICS 13.220.10

#### English version

# Fire extinguishing media - Foam concentrates - Part 3 : Specification for low expansion foam concentrates for surface application to water-immiscible liquids

Agents extincteurs - Emulseurs - Partie 3 : Spécifications pour les émulseurs bas foisonnement destinés à une application à la surface des liquides n'ayant pas d'affinité pour l'eau Feuerlöschmittel - Schaummittel - Teil 3 : Anforderungen an Schaummittel zur Erzeugung von Schwerschaum zum Aufgeben auf nicht-polare Flüssigkeiten

This European Standard was approved by CEN on 13 November 1999.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION COMITÉ EUROPÉEN DE NORMALISATION EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: rue de Stassart, 36 B-1050 Brussels

© 2000 CEN

All rights of exploitation in any form and by any means reserved worldwide for CEN national Members.

Ref. No. EN 1568-3:2000 E

# **Contents**

	Page
Foreword	3
Introduction	4
1 Scope	5
2 Normative references	5
3 Terms and definitions	6
4 Sediment in the foam concentrate	7
5 Viscosity of the foam concentrate	7
6 pH of the foam concentrate	8
7 Surface tension of the foam solution	8
8 Spreading coefficient of the foam solutions	8
9 Expansion and drainage of foam	8
10 Test fire performance	9
11 Container marking	10
Annex A (informative) Grades of foam concentrate and performance	12
Annex B (normative) Preliminary sampling of foam concentrates	14
Annex C (normative) Determination of percentage sediment	15
Annex D (normative) Viscosity determination for pseudoplastic foam concentrate	16
Annex E (normative) Temperature conditioning of foam concentrates	18
Annex F (normative) Determination of surface tension and spreading coefficient	20
Annex G (normative) Determination of expansion and drainage time	21
Annex H (normative) Determination of test fire performance	26
Annex I (informative) Small scale fire test	31
Annex J (informative) Description of a radiation measurement method	41
Annex K (informative) A-Deviations	45
Bibliography	48

# iTeh STANDARD PREVIEW (standards.iteh.ai)

## **Foreword**

This European Standard has been prepared by Technical Committee CEN/TC 191 "Fixed firefighting systems", the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by April 2001, and conflicting national standards shall be withdrawn at the latest by April 2001.

This European Standard is one of the series specifying requirements for fire extinguishing media in common use. This series includes the following:

Fire protection - Fire extinguishing media - Carbon dioxide (ISO 5923:1989)
Fire protection - Fire extinguishing media - Halogenated hydrocarbons -
Part 1: Specification for halon 1211 and halon 1301 (ISO 7201-1:1989)
Fire protection - Fire extinguishing media - Halogenated hydrocarbons -
Part 2: Code of practice for safe handling and transfer procedures (ISO
7201-2:1991)
Fire protection - Fire extinguishing media - Specification for powder
(other than Class D powders)

This standard is Part 3 of EN 1568 which has the general title "Fire extinguishing media - Foam concentrates". The other parts are, or will be:

- Part 1 Specification for medium expansion foam concentrates for surface application to water-immiscible liquids.
- Part 2 Specification for high expansion foam concentrates for surface application to water-immiscible liquids.
- Part 4 Specification for low expansion foam concentrates for surface application to water-miscible liquids.

As fire fighting foams are chemical preparations EC Directives 67/548/EEC, 76/464/EEC and 88/379/EEC apply and should be taken into account en. at

The annexes A, I, J are informative, the annexes B, O,D, E, F, G, H are normative.

Annex K is an A-Deviation for National Regulations applicable in Denmark and in Germany and is informative.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and the United Kingdom.

## Introduction

Classes of fire are defined in EN 2:1992 as follows:

- Class A: fires involving solid materials, usually of an organic nature, in which combustion normally takes place with the formation of glowing

embers;

- Class B: fires involving liquids or liquefiable solids;

- Class C: fires involving gases;

- Class D: fires involving metals.

Fire fighting foams are widely used to control and extinguish Class B fires and to inhibit reignition. These foams can also be used for prevention of ignition of flammable liquids and, in certain conditions, to extinguish Class A fires.

Foams can be used in combination with other extinguishing media, particularly gaseous media and powders, which are the subject of other European Standards (see Foreword).

These specifications have been designed to ensure that fire extinguishing media have the minimum useful fire fighting capability. The user should ensure that the foam concentrates are used accurately at the concentration recommended by the manufacturer. Fire performances indicated by this standard can not replicate practical fire situations.

Foam concentrates of different types and manufacture should not be mixed.

It should be noted that some combinations of extinguishing powder and foam can lead to unacceptable loss of efficiency, caused by unfavourable interaction of the chosen media when applied simultaneously or successively to the fire.

It is extremely important that the foam concentrate after dilution with water to the recommended concentration should not in normal usage present a significant toxic hazard to life in relation to the environment. The current versions of EC Directives 67/548/EEC, 76/464/EEC and 88/379/EEC apply when considering the testing of ecotoxilogical properties and Safety in the work environment.

#### 1 Scope

This European Standard specifies requirements for chemical and physical properties, and minimum performance requirements of low expansion foams suitable for surface application to water-immiscible liquids. Requirements are also given for marking.

NOTE: Some concentrates complying with this Part of EN 1568 can also comply with other Parts and therefore can also be suitable for application as medium and/or high expansion foams, and for application at low expansion to water-miscible liquids.

#### 2 Normative references

This European Standard incorporates by dated or undated reference, provisions from other publications. These normative references are cited at the appropriate places in the text and the publications are listed hereafter. For dated references, subsequent amendments to or revisions of any of these publications apply to this European Standard only when incorporated in it by amendment or revision. For undated references the latest edition for the publication referred to applies (including amendments).

EN ISO 3104 Petroleum products - Transparent and opaque liquids

- Determination of kinematic viscosity and calculation of

dynamic viscosity (ISO 3104:1994)

ISO 304 Surface active agents - Determination of surface tension by

drawing up liquid films

ISO 3310-1:1990 Test sieves - Technical requirements and testing - Part 1 : Test

sieves of metal wire cloth

ISO 3696 Water for analytical laboratory use - Specification and test

methods

iTeh STANDARD PREVIEW (standards.iteh.ai)

EN 1568-3:2000

#### **3 Definitions**

For the purposes of this European Standard, the following definitions apply.

## 3.1

#### **25%/50%** drainage time

Time taken for 25/50 % of the volume of the original foam solution to drain out of the generated foam.

#### 3.2

#### expansion

Ratio of the volume of foam to the volume of the foam solution from which it was made.

#### 3.3

#### low expansion foam

Foam which has an expansion ratio not greater than 20.

## 3.4

#### medium expansion foam

Foam which has an expansion ratio greater than 20 but not greater than 200.

#### 3.5

#### high expansion foam

Foam which has an expansion ratio greater than 200.

#### 3.6

# fire-fighting foam

Aggregate of air filled bubbles formed from a foam solution used for fire fighting.

#### 3.7

## foam concentrate

Liquid which is diluted with water to produce foam solution.

NOTE: Annex A gives information on grades of foam concentrate.

## 3.8

# (standards.iteh.ai)

# foam solution

Solution of foam concentrate in water IST EN 1568-3:2001

https://standards.iteh.ai/catalog/standards/sist/1768e80d-a270-40ce-a014-3292bd9738d5/sist-en-1568-3-2001

# 3.9

# gentle application

Application (of foam from the test nozzle) indirectly to the surface of the fuel from a backboard.

NOTE: This definition of gentle application relates to the fire test procedures used in EN 1568 Parts 3 and 4. In practice fire-fighting systems foam can also be applied gently by fixed foam pourers or by indirect application via a tank wall or other surface.

#### 3.10

#### forceful application

Application (of foam from the test nozzle) directly onto the surface of the fuel.

#### 3.11

#### sediment

Insoluble particles in the foam concentrate.

#### 3.12

#### spreading coefficient

Value which indicates the ability of one liquid to spread spontaneously across the surface of another.

#### 3.13

## **Newtonian foam concentrates**

foam concentrates which have a viscosity which is independent of the shear rate.

#### 3.14

#### pseudoplastic foam concentrates

foam concentrates which have a viscosity which decreases with increasing shear rate.

#### 4 Sediment in the foam concentrate

#### 4.1 Sediment before ageing

Any sediment in the foam concentrate sampled in accordance with annex B, but not aged in accordance with C.1, shall be dispersible through a 180 µm sieve, and the percentage volume of sediment shall be not more than 0,25 % when tested in accordance with annex C.

#### 4.2 Sediment after ageing

Any sediment in the foam concentrate sampled in accordance with annex B, and aged in accordance with C.1, shall be dispersible through a 180  $\mu$ m sieve and the percentage volume of sediment shall be not more than 1.0 % when tested in accordance with annex C.

# (standards.iteh.ai)

# 5 Viscosity of the foam concentrate

SIST EN 1568-3:2001

**5.1 Newtonian foam: concentrates** catalog/standards/sist/1768e80d-a270-40ce-a014-3292bd9738d5/sist-en-1568-3-2001

The viscosity of the foam concentrate at the lowest temperature for use claimed by the manufacturer, shall be determined in accordance with EN ISO 3104.

# 5.2 Pseudoplastic foam concentrates

The viscosity of the foam concentrate shall be determined in accordance with annex D.

# 6 pH of the foam concentrate

The pH of the foam concentrate sampled in accordance with annex B shall be not less than 6,0 and not more than 9,5 at  $(20 \pm 1)$  °C.

#### 7 Surface tension of the foam solution

The surface tension (determined in accordance with annex F.2.1) of the foam solutions prepared using top and bottom samples (see E.4) of the foam concentrate sampled in accordance with annex B and conditioned in accordance with annex E shall be not less than 0,95 times and not more than 1,05 times the surface tension (determined in accordance with annex F.2.1) of the foam solution prepared using the foam concentrate sampled in accordance with annex B.

# 8 Spreading coefficient of the foam solutions

NOTE: The spreading coefficient indicates the possibility of film-forming, but it does not measure its quality. Certain properties of film-forming foams are not defined by this standard.

#### 8.1 Before temperature conditioning

The foam solution prepared using the concentrate, if it is claimed by the supplier to be "film-forming", sampled in accordance with annex B shall have a positive spreading coefficient over cyclohexane when tested in accordance with F.2.2.

#### 8.2 After temperature conditioning

The foam solution prepared using top and bottom samples, see E.4, of the foam concentrate, if it is claimed by the supplier to be "film-forming", sampled in accordance with annex B and conditioned in accordance with annex E, shall have a positive spreading coefficient over cyclohexane when tested in accordance with F.2.2.

# iTeh STANDARD PREVIEW (standards.iteh.ai)

# 9 Expansion and drainage of foam

SIST EN 1568-3:2001

**9.1 Before temperature conditioning**log/standards/sist/1768e80d-a270-40ce-a014-3292bd9738d5/sist-en-1568-3-2001

The foam produced from the foam solution prepared from the foam concentrate sampled in accordance with annex B, at the suppliers recommended concentration with potable water shall be tested in accordance with annex G. If appropriate, a further sample for the same concentration made with the simulated sea water of G.4 shall also be tested.

# 9.2 After temperature conditioning

The foams produced from the foam solutions prepared using top and bottom samples, see E.4, of foam concentrate, sampled in accordance with annex B, at the suppliers recommended concentration, and if appropriate further samples at the same concentration made with the simulated sea water of G.4, when tested in accordance with annex G, shall have the following:

- a) expansion values which do not differ from each other or from the value obtained in 9.1 (i.e. before temperature conditioning) by more than 20 % of the value obtained in 9.1; and
- b) 25 % drainage times which do not differ from each other or from the value obtained in 9.1 (i.e. before temperature conditioning) by more than 20 % of the value obtained in 9.1.

### 10 Test fire performance

The foam produced from the foam solutions, prepared using the foam concentrate sampled in accordance with annex B at the supplier's recommended concentration with potable water and if appropriate at the same concentration with the simulated sea water of G.4, shall have an extinguishing performance class and burnback resistance level as specified in table 1 when tested in accordance with H.1 and H.2 and/or H.3 as appropriate.

NOTE 1: The values obtained with seawater can differ from those obtained with potable water.

NOTE 2: Annex I describes a small scale fire test which can be suitable for quality control purposes.

iTeh STANDARD PREVIEW (standards.iteh.ai)

Table 1 - Maximum extinction times and minimum burnback times

Times in minutes

Extinguishing performance class	Burnback resistance level	Gentle application test (See H.2)		Forceful application test (See H.3)	
		Extinction	Burnback	Extinction	Burnback
		time not	time not less	time not more	time not less
		more than	than	than	than
	A	not applicable		3	10
I	В	5	15	3	
	С	5	10	3	not
	D	5	5	3	applicable
	A	not applicable		4	10
П	В	5	15	4	
	С	5	10	4	not
	D	5	5	4	applicable
	В	5	15		
III	С	5	10	not	
	D	5	5	applic	cable

NOTE 1: There is no burnback resistance level A for class III.

NOTE 2: Typical extinguishing performance classes and burnback resistance levels for different types of foam concentrate are given in annex A.

## 11 Container marking

The following information shall be marked on the packaging or transport container:

- a) the designation (identifying name) of the concentrate;
- b) the words "low expansion fire-fighting foam concentrate" and the number and date of this European Standard (i.e. EN 1568-3: 2000);

NOTE: For low expansion concentrates which also conform to other Parts of EN 1568 additional markings can be used as given in those Parts.

- c) if the concentrate conforms to clause 8 the words "film-forming";
- d) recommended usage concentration (most commonly 17%, 3% or 6%);
- e) any tendency of the foam concentrate to cause harmful physiological effects, the methods needed to avoid them and the first aid treatment if they should occur;
- f) recommended maximum storage temperature and lowest temperature for use;
- g) if the concentrate does not conform to clause 7, 8.2 and 9.2 after conditioning in accordance with E.2 the words 'Do not store below 0 °C';
- h) the nominal quantity in the container;
- i) the supplier's name and address;

- j) the batch number and the date of manufacture;
- k) the words "Not suitable for use with sea water" or "Suitable for use with sea water" as appropriate;
- l) the extinguishing performance class and the burnback resistance level using potable water, and if appropriate, using seawater;
- m) if the foam concentrate is Newtonian and the viscosity at the lowest temperature for use is more than 200 mm<sup>2</sup> s when measured in accordance with EN ISO 3104 the words "This concentrate can require special proportioning equipment";
- n) if the foam concentrate is pseudoplastic the words "Pseudoplastic foam concentrate".

NOTE 1: The packaging of the foam concentrate should ensure that the essential characteristics of the concentrate are preserved when stored and handled in accordance with the supplier's recommendations.

NOTE 2: Markings on shipping containers should be permanent and legible.

# iTeh STANDARD PREVIEW (standards.iteh.ai)