



Designation: D6974 – 09(Reapproved 2013)^{ε1}

Standard Practice for Enumeration of Viable Bacteria and Fungi in Liquid Fuels— Filtration and Culture Procedures¹

This standard is issued under the fixed designation D6974; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

^{ε1} NOTE—Subsections 8.4 and 8.8.2 were editorially corrected in August 2014.

1. Scope

1.1 This practice covers a membrane filter (MF) procedure for the detection and enumeration of Heterotrophic bacteria (HPC) and fungi in liquid fuels with kinematic viscosities $\leq 24 \text{ mm}^2 \cdot \text{s}^{-1}$ at ambient temperature.

1.2 This quantitative practice is drawn largely from IP Method 385 and Test Method D5259.

1.3 This test may be performed either in the field or in the laboratory.

1.4 The ability of individual microbes to form colonies on specific growth media depends on the taxonomy and physiological state of the microbes to be enumerated, the chemistry of the growth medium, and incubation conditions. Consequently, test results should not be interpreted as absolute values. Rather they should be used as part of a diagnostic or condition monitoring effort that includes other test parameters, in accordance with Guide D6469.

1.5 This practice offers alternative options for delivering fuel sample microbes to the filter membrane, volumes or dilutions filtered, growth media used to cultivate fuel-borne microbes, and incubation temperatures. This flexibility is offered to facilitate diagnostic efforts. When this practice is used as part of a condition monitoring program, a single procedure should be used consistently.

1.6 The values stated in SI units are to be regarded as standard. No other units of measurement are included in this standard.

1.7 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

¹ This practice is under the jurisdiction of ASTM Committee D02 on Petroleum Products, Liquid Fuels, and Lubricants and is the direct responsibility of Subcommittee D02.14 on Stability and Cleanliness of Liquid Fuels.

Current edition approved May 1, 2013. Published August 2013. Originally approved in 2003. Last previous edition approved in 2009 as D6974 – 09. DOI: 10.1520/D6974-09R13E01.

2. Referenced Documents

2.1 ASTM Standards:²

- D1129 Terminology Relating to Water
- D1193 Specification for Reagent Water
- D4175 Terminology Relating to Petroleum, Petroleum Products, and Lubricants
- D5259 Test Method for Isolation and Enumeration of Enterococci from Water by the Membrane Filter Procedure
- D6426 Test Method for Determining Filterability of Middle Distillate Fuel Oils
- D6469 Guide for Microbial Contamination in Fuels and Fuel Systems
- D7463 Test Method for Adenosine Triphosphate (ATP) Content of Microorganisms in Fuel, Fuel/Water Mixtures, and Fuel Associated Water
- D7464 Practice for Manual Sampling of Liquid Fuels, Associated Materials and Fuel System Components for Microbiological Testing
- E1326 Guide for Evaluating Nonconventional Microbiological Tests Used for Enumerating Bacteria
- F1094 Test Methods for Microbiological Monitoring of Water Used for Processing Electron and Microelectronic Devices by Direct Pressure Tap Sampling Valve and by the Presterilized Plastic Bag Method

2.2 Energy Institute Standards:³

- IP 385 Viable aerobic microbial content of fuels and fuel components boiling below 90°C—Filtration and culture method

3. Terminology

3.1 Definitions:

- 3.1.1 For definition of terms used in this method refer to Terminologies D1129 and D4175, and Guide D6469.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For Annual Book of ASTM Standards volume information, refer to the standard's Document Summary page on the ASTM website.

³ Available from Energy Institute, 61 New Cavendish St., London, WIG 7AR, U.K., <http://www.energyinst.org.uk>.

3.1.2 *aseptic, adj*—sterile, free from viable microbiological contamination.

3.2 *Acronyms:*

3.2.1 *CFU*—colony forming unit

3.2.2 *HPC*—heterotrophic plate count

3.2.3 *MF*—membrane filter

3.2.4 *MEA*—malt extract agar

3.2.5 *TNTC*—too numerous to count

3.2.6 *TSA*—tryptone soy agar

3.3 *Symbols:*

3.3.1 *N*—number of CFU · L⁻¹

3.3.2 *CC*—number of colonies on membrane filter

3.3.3 *V*—sample volume filtered, mL

4. Summary of Practice

4.1 Any free water present in a fuel sample is removed by settling in a separatory funnel. After the water has been removed, a known volume of the remaining fuel is filtered through a membrane filter aseptically by one of three methods.

4.2 The filter membrane retains microbes present in the fuel. Filter replicate fuel samples through fresh membranes to permit replicate testing, growth on alternative nutrient media, or both.

4.3 After filtration, place each membrane on one of two types of agar growth media, incubate at a designated temperature for three days, and examine for the presence of CFU.

4.4 Incubate the filter media on agar for two more days, then reexamine.

4.5 Count the colonies manually or by electronic counter.

4.5.1 If practical, identify colonies on each agar medium, based on colony color, morphology, and microscopic examination.

4.5.2 Convert bacterial and fungal colony counts to CFU per litre of fuel.

5. Significance and Use

5.1 Biodeteriogenic microbes infecting fuel systems typically are most abundant within slime accumulations on system surfaces or at the fuel-water interface (Guide **D6469**). However, it is often impractical to obtain samples from these locations within fuel systems. Although the numbers of viable bacteria and fungi recovered from fuel-phase samples are likely to be several orders of magnitude smaller than those found in water-phase samples, fuel-phase organisms are often the most readily available indicators of fuel and fuel system microbial contamination.

5.2 *Growth Medium Selectivity*—Guide **E1326** discusses the limitations of growth medium selection. Any medium selected will favor colony formation by some species and suppress colony formation by others. As noted in **6.3**, physical, chemical and physiological variables can affect viable cell enumeration test results. Test Method **D7463** provides a non-culture means of quantifying microbial biomass in fuels and fuel associated water.

5.3 Since a wide range of sample sizes, or dilutions thereof, can be analyzed by the membrane filter technique (Test Methods **D5259** and **F1094**), the test sensitivity can be adjusted for the population density expected in the sample.

5.4 Enumeration data should be used as part of diagnostic efforts or routine condition monitoring programs. Enumeration data should not be used as fuel quality criteria.

6. Interferences

6.1 High non-biological particulate loads (sediment) can clog the membrane and prevent filtration.

6.2 Each CFU is assumed to originate from a single microbial cell. In reality, microbes often form aggregates which appear as a single colony. Consequently, viable count data are likely to underestimate the total number of viable organisms in the original sample.

6.3 The metabolic state of individual microbes may be affected by numerous physical-chemical variables in the fuel. Injured cells or cells that have relatively long generation times may not form colonies within the time allotted for test observations. This results in an underestimation of the numbers of viable microbes in the original fuel sample.

7. Apparatus

7.1 *Separatory Funnels*, glass, nominal capacity 500 mL.

7.2 *Measuring Cylinders*, glass, nominal capacity 100 mL and 1 L.

7.3 *Pipettes*, glass or sterile disposable plastic, nominal capacity 10 mL, or adjustable volume pipette and sterile disposable plastic tips.

7.4 *Membrane Filter*, mixed esters of cellulose, presterilized, preferably gridded, 47 mm diameter, nominal pore size 0.45 μm.

NOTE 1—While the recommended filter material is mixed esters of cellulose, the selection of membrane material will depend on individual preference and fuel type.

7.5 *Filtration Unit*, one of:

7.5.1 *Unit*, as described in Test Method **D6426**, with presterilized in-line filter housing, or

7.5.2 *Hypodermic Syringe*, sterile, 100 mL, with presterilized in-line filter housing, or

7.5.3 *Filter Holder Assembly*, single or manifold, glass, stainless steel, or polypropylene, pre-sterilized.

NOTE 2—If the vacuum filtration option (**7.5.3**) is chosen, a vacuum source, not more than -66 kPa will also be needed.

7.6 *Forceps*, blunt tipped.

7.7 *Filter Flask*, of sufficient capacity to receive the entire sample being filtered plus washings.

7.8 *Petri Dishes*, disposable plastic or glass, nominal diameter ≥50 mm.

NOTE 3—Pre-poured Petri dishes, containing the growth media described below are available commercially and may be substituted for the dishes listed here.

7.9 *Incubator*, capable of maintaining a temperature of 25 ± 2°C or any other temperature (within the range—ambient to 60°C), as appropriate.