



Designation: **E2292 – 04 (Reapproved 2012) E2292 – 14**

Standard Practice Guide for Field Investigation of Investigating Carbon Monoxide Poisoning Incidents¹

This standard is issued under the fixed designation E2292; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This practice covers guidelines for collecting and preserving information and physical evidence related to incidents involving the poisoning of individuals by carbon monoxide.

1.2 This practice is not intended to be a guide for investigating carbon monoxide poisoning caused by hostile fires, or contamination in closed air systems. Guidance on the investigation of carbon monoxide poisonings related to fire can be found in NFPA 921, *Guide for Fire and Explosion Investigations*.

1.3 The values stated in inch-pound units are to be regarded as standard. The values given in parentheses are mathematical conversions to SI units that are provided for information only and are not considered standard.

1.4 This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.

2. Referenced Documents

2.1 *ASTM Standards*:²

[E678 Practice for Evaluation of Scientific or Technical Data](#)

[E860 Practice for Examining And Preparing Items That Are Or May Become Involved In Criminal or Civil Litigation](#)

[E1020 Practice for Reporting Incidents that May Involve Criminal or Civil Litigation](#)

2.2 *NFPA Standards*:³

[NFPA 54 National Fuel Gas Code](#)

[NFPA 921 Guide for Fire and Explosion Investigations](#)

3. Significance and Use

3.1 Carbon monoxide poisoning is responsible for approximately 300 deaths annually in the United States, (excluding fire deaths) and carbon monoxide poisoning causes thousands of individuals to seek medical attention.

3.2 This practice is intended for use by individuals who investigate incidents involving carbon monoxide poisoning. If this procedure is followed, the cause for the carbon monoxide poisoning incident may be determined, and steps can be taken to prevent future incidents.

4. Equipment

4.1 *Electronic Carbon Monoxide Monitor*—A properly calibrated direct reading electronic monitor having a range of 0 to 1000 ppm is useful in that its output provides almost instantaneous concentration data, and it therefore has the capability to warn the investigator if carbon monoxide levels are reaching dangerous concentrations.

4.2 *Reagent Tube Indicator*—Several types of reagent tube indicators are available for measuring carbon monoxide, carbon dioxide, and fuel gases. Reagent tubes capable of responding to concentrations of 0 to 100 ppm, 0 to 1000 ppm, and 0 to 1 % carbon monoxide in air are recommended.

4.3 *Ventilation Equipment*—A fan or similar device should be available to allow flushing the air space around equipment between tests.

¹ This practice is under the jurisdiction of ASTM Committee E58 on Forensic Engineering and is the direct responsibility of Subcommittee E58.05 on Industrial Processes. Current edition approved Nov. 1, 2012 Aug. 1, 2014. Published November 2012 September 2014. Originally approved in 2003. Last previous edition approved in 2004 2012 as E2292 – 04 E2292 – 04 (2012). DOI: 10.1520/E2292-04R12.10.1520/E2292-14.

4.4 All equipment shall be calibrated at least annually.

5. Safety

5.1 Testing equipment suspected of causing carbon monoxide poisoning can yield definitive results that cannot be obtained any other way. Testing equipment that may have injured individuals; however, is a potentially dangerous undertaking, in that the investigator runs the risk of becoming exposed to carbon monoxide being produced by improperly functioning equipment.

5.2 Safe testing procedures are of the utmost importance. Before any testing is planned, a safety officer shall be identified. The safety officer's responsibilities shall be to protect the safety and health of the investigator and any individuals who may be affected by the testing.

5.3 Stable communications should be assured between the site and emergency service providers.

5.4 Until its safe operation has been verified, only one person at a time should be allowed into any space where a piece of equipment is being tested for carbon monoxide output. That person should remain within sight of the safety officer or another individual capable of rescuing that individual from the space.

5.5 All testing shall be discussed in detail with all individuals involved in the testing, prior to the beginning of any test.

6. Procedure

6.1 *Scene Security*—The first priority is to evacuate the scene and prevent further injuries or loss of life.

6.1.1 After evacuation, the scene should be secured, and if possible, a field measurement of carbon monoxide levels in various locations around the scene should be taken.

6.1.2 The fuel supply to the scene should be turned off. This may require the switching off of internal combustion engines, or the closing of valves for gaseous or liquid fuels.

6.2 *Documentary Information*—Collect information related to the poisoning event, including emergency phone line recordings, and medical records, particularly those that describe the blood gas analysis of the victims. Obtain statements as early as feasible from all individuals associated with the incident.

6.3 Identify all fuel-burning equipment in the site.

6.3.1 A partial list of equipment that might be a potential source of carbon monoxide includes gas appliances (furnaces, ranges, ovens, water heaters, and clothes dryers), fireplaces, wood and coal stoves, space heaters, charcoal grills, camp stoves, automobiles, gas-powered lawnmowers, and gas powered tools.

6.4 Once all of the fuel-burning equipment has been identified, establish and document the condition of the valves and/or switches on each piece of equipment at the time of the incident.

6.5 Determine the source of fuel, air, and ventilation of each piece of equipment.

6.5.1 Determine whether any of the equipment is located in an enclosure that can be defined as a "confined space."

6.5.1.1 Confined spaces are defined in NFPA 54 as, "a space whose volume is less than fifty cubic feet per 1000 btu per hour (4.8 m³ per kW) of the aggregate input of all appliances installed in that space."

6.5.2 Determine whether the equipment has an adequate supply of air for combustion and ventilation as specified in NFPA 54, chapter 5.

6.5.3 Determine whether the equipment, if venting is required, is vented to safely carry the products of combustion outside, as required by NFPA 54, chapter 7.

6.5.4 Determine whether any temporary obstructions of the equipment ventilation, including obstructions of the return air vents have been moved.

6.6 *Planning the Test*—Develop a plan for safely testing the potential sources of carbon monoxide in the scene. In most cases, this planning will involve preparation of a written protocol for tests to be carried out. Refer to Practice E678 in planning any tests.

6.6.1 This plan will typically include the turning on of equipment and observing its performance using the carbon monoxide monitoring devices described in Section 5.

6.6.2 Identify the individuals who will be conducting the tests, including the safety officer.

6.6.3 Identify any individuals who may have an interest in the outcome of the testing.

6.6.3.1 Such individuals may include the property owner, representatives of the victim(s), equipment manufacturers, equipment service personnel, law enforcement officers, code enforcement officers, and the insurance carrier for any of the parties listed above.

6.7 Notify individuals who have been identified as possibly having an interest in the testing of the time that the tests are going to take place. For additional guidance on notification, see Practice E860.

6.7.1 Keep a record of individuals who have been notified of the proposed testing.

6.7.2 Notification of other interested parties may not be necessary if the investigation is going to be limited to observations that do not change the condition of any of the structures or equipment.

6.8 Operate each piece of equipment that has been identified as a potential source of carbon monoxide in the manner in which it is designed to be operated, and, using the equipment described in Section 5, measure the carbon monoxide output, if any.

- 6.8.1 Attempt to reconstruct temporary obstructions to the return air or combustion air vents or to the flues or chimneys.
- 6.8.2 If abnormal operation of any piece of equipment is suspected, operate that equipment in the abnormal fashion, if possible, changing only one operating parameter at a time, and record the results.
- 6.8.3 Operate equipment or appliances in combination, only if the combination of equipment is suspected of contributing to the cause of the carbon monoxide buildup.

7. Collection of Physical Evidence

- 7.1 Once all parties to the investigation are satisfied that sufficient testing has been accomplished, items of physical evidence pertinent to the conclusions may be secured.
- 7.2 Label according to Practice E1859.
- 7.3 Frequently, the device that is identified as having produced the carbon monoxide can be restored to a safe operating condition, and left in place after the condition that led to the poisoning event has been sufficiently documented.

8. Report

- 8.1 The investigative report should include the following information:
 - 8.1.1 Location, date and time of the incident.
 - 8.1.2 Extent of the victim's injuries, including carboxyhemoglobin (COHb) level in the victim's blood.
 - 8.1.3 Identification of the source of the carbon monoxide.
 - 8.1.4 Identification of conditions that caused the source of the carbon monoxide to produce the carbon monoxide.
 - 8.1.5 Identification of a path of travel from the carbon monoxide producing device to the victim.
 - 8.1.6 A description of corrective actions needed to render the equipment safe.
 - 8.1.7 For additional guidance on reporting the incident, refer to Practice E1020.

ASTM International takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this standard. Users of this standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.

This standard is subject to revision at any time by the responsible technical committee and must be reviewed every five years and if not revised, either reapproved or withdrawn. Your comments are invited either for revision of this standard or for additional standards and should be addressed to ASTM International Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend. If you feel that your comments have not received a fair hearing you should make your views known to the ASTM Committee on Standards, at the address shown below.

This standard is copyrighted by ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959, United States. Individual reprints (single or multiple copies) of this standard may be obtained by contacting ASTM at the above address or at 610-832-9585 (phone), 610-832-9555 (fax), or service@astm.org (e-mail); or through the ASTM website (www.astm.org). Permission rights to photocopy the standard may also be secured from the Copyright Clearance Center, 222 Rosewood Drive, Danvers, MA 01923, Tel: (978) 646-2600; http://www.copyright.com/

1. Scope

- 1.1 This guide covers collection and preservation of information and physical evidence related to incidents involving the poisoning of individuals by carbon monoxide.
- 1.2 This guide is not intended to address the medical effects of carbon monoxide exposure.
- 1.3 This guide is not intended to be a guide for investigating carbon monoxide poisoning caused by hostile fires, or contamination in closed air systems or confined spaces. Guidance on the investigation of carbon monoxide poisonings related to fire can be found in NFPA 921.
- 1.4 This guide is not intended for an investigation where equipment is removed from the incident site and conducted in a more controlled setting.
- 1.5 This guide is intended to be used by a wide range of investigators, including first responders, appliance technicians and engineers.
- 1.6 This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.

2. Referenced Documents

- 2.1 ASTM Standards:²
E1459 Guide for Physical Evidence Labeling and Related Documentation

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

[E2713 Guide to Forensic Engineering](#)

[2.2 NFPA Standards:³](#)

[NFPA 54 National Fuel Gas Code](#)

[NFPA 921 Guide for Fire and Explosion Investigations](#)

[2.3 UL Standards:⁴](#)

[UL 2034 Single and Multiple Station Carbon Monoxide Alarms](#)

3. Significance and Use

3.1 This guide is intended for use by individuals who investigate incidents involving carbon monoxide poisoning. If this guide is followed, the cause for the carbon monoxide poisoning incident may be determined, and corrective action may be identified to prevent future incidents.

3.2 When attempting to identify the source of carbon monoxide, consider that it is produced at some level in virtually every fuel-burning engine, boiler, furnace, burner, stove or fire. All carbon-based fuels (for example, gasoline, diesel fuel, natural gas, propane, coal, wood, paper products, plastics) produce carbon monoxide as a result of incomplete combustion. When there is insufficient air for complete combustion, carbon monoxide can become a major product of combustion. In properly-operating combustion equipment, the level of carbon monoxide produced may be as little as a hundred parts per million or less (that is, 0.01 %). However, combustion with insufficient air can produce carbon monoxide concentrations of 10 000 ppm to 100 000 ppm (that is, 1 to 10 %) or higher.

3.3 Be aware of the effects of carbon monoxide on humans and pets. Carbon monoxide acts as a central nervous system depressant. With increasing concentration or time of exposure, or both, carbon monoxide will cause people to feel sleepy or sick, lose consciousness, and die. Carbon monoxide is especially hazardous because it is colorless and odorless, providing no warning of its presence. When inhaled, carbon monoxide binds with hemoglobin in the blood, creating carboxyhemoglobin (COHb). The affinity of carbon monoxide for hemoglobin is approximately 200 times greater than the affinity of oxygen for hemoglobin. Therefore, the blood can accumulate dangerous levels of COHb, depriving the body of oxygen.

3.4 Since there is the potential for investigators to become victims of elevated carbon monoxide levels themselves, extreme care should be taken to assure the safety of investigators and anyone else at risk of continuing carbon monoxide exposure. Carbon monoxide monitoring and measurement equipment is required to ensure life safety of those present, as well as to determine the cause of the problem and its solution.

³ Available from National Fire Protection Association (NFPA), 1 Batterymarch Park, Quincy, MA 02169-7471, <http://www.nfpa.org>.

⁴ Available from Underwriters Laboratories (UL), 2600 N.W. Lake Rd., Camas, WA 98607-8542, <http://www.ul.com>.




FIG. 1 Common Locations of Carbon Monoxide Build-Up

4. Equipment

4.1 The following is a listing of basic measurement equipment that may be useful in diagnosing a carbon monoxide problem and determining the source, cause, and validating corrective actions:

4.1.1 *Electronic Carbon Monoxide Monitor*—A properly calibrated direct reading electronic monitor having a range of 0 to 1000 or 2000 ppm (that is, 0.1 to 0.2 %) is preferred in that its output provides almost instantaneous concentration data, and it therefore has the capability to warn the investigator if carbon monoxide levels are reaching dangerous concentrations. The carbon monoxide monitor may also be used to survey different areas of a building to locate the area of highest concentration, helping to identify the source.

4.1.2 *Carbon Monoxide Alarms (compliant with UL 2034)*—These alarms may be used as warning devices (see Section 5). Alarms with digital readouts should not be used as primary investigative monitors since their range is typically limited to ~100 ppm (that is, 0.01 %).

4.1.3 *Combustion Gas Analyzer*—Because malfunctioning combustion equipment is sometimes found to be the source of excessive carbon monoxide, portable gas analyzers are useful to check the combustion products produced by fuel burning equipment. These instruments indicate carbon monoxide as well as other exhaust gases. Combustion gas analyzers are used to determine whether the combustion equipment is operating within its normal limits for carbon monoxide in the exhaust. A measurement range up to 10 % carbon monoxide (100 000 ppm) may be required.

4.1.4 *Manometer*, or equivalent instrument, capable of determining positive and negative pressures in the combustion air supply, exhaust stack, and inside the living space while fuel burning equipment is operating.

4.1.5 *Ventilation Equipment*—A fan, blower, or similar device should be available to provide air movement in the space around equipment between tests. Monitor the carbon monoxide level in the area before running each test.

4.1.6 *SCBA (self contained breathing apparatus)* may be used if entering a highly contaminated area while conducting tests.

4.1.7 All indicating equipment should be calibrated at least annually or per the manufacturer's recommendations, and checked prior to each use. The equipment may be checked against a standard reference gas. Selection of calibration gas concentrations should reflect both low and high range for gas measurement equipment.

5. Safety

5.1 Entering spaces and testing of equipment suspected of causing carbon monoxide poisoning may yield definitive results that cannot be obtained any other way. Testing of equipment that may have injured individuals; however, is a potentially dangerous undertaking, in that the investigator runs the risk of becoming exposed to carbon monoxide being produced by improperly functioning equipment.

5.2 Safe testing procedures are of the utmost importance. Before any testing is undertaken, a safety officer should be identified. The safety officer's responsibilities are to protect the safety and health of the investigator and any individuals who may be affected by the testing.

5.3 Stable communications should be assured between the site and emergency service providers.

5.4 Audible carbon monoxide alarms, compliant with UL 2034, may be used as warning devices to warn participants of hazardous conditions. Such alarms are not substitutes for carbon monoxide monitors or analyzers, which provide better accuracy.

5.5 Until its safe operation has been verified, the minimum number of participants should be in the space where a piece of equipment is being tested for carbon monoxide output that the potentially interested parties will agree upon. Those persons inside should remain within sight of the safety officer or another individual capable of rescuing that individual from the space. SCBAs may be used if necessary.

5.6 All testing should be discussed in detail with all individuals involved in the testing, prior to the beginning of any test. A written test protocol may be advisable, as discussed in 6.9 below.

5.7 Permissible levels of carbon monoxide concentration depend on the time of exposure. The U.S. Environmental Protection Agency (EPA) advises a threshold of 50 ppm averaged over 8 hours. Higher concentrations or longer exposures at lower levels, or both, are also hazardous.

6. Procedure

6.1 *Scene Security*—If the carbon monoxide concentration is elevated in the area, the first priority is to evacuate the scene and prevent further injuries or loss of life.

6.1.1 After evacuation, the scene should be secured. If possible, field measurements of carbon monoxide levels in various locations around the scene should be taken.

6.1.2 The fuel supply to the scene should be turned off. This may require the switching off of internal combustion engines, or the closing of valves for gaseous or liquid fuels.

6.2 Notify individuals who have been identified as possibly having an interest in the testing of the time that the tests are going to take place. For additional guidance on notification, see Guide E2713. The advice of legal counsel may be advisable.

6.2.1 Identify any individuals who may have an interest in the outcome of the testing. Such individuals may include the property owner, representatives of the victim(s), equipment manufacturers, equipment service personnel, law enforcement officers, code enforcement officers, and the insurance carrier for any of the parties listed above. Provide each of these individuals a copy of the testing protocol developed for their information and comment.

6.2.2 Keep a record of individuals who have been notified of the proposed testing.

6.2.3 Notification of other interested parties may not be necessary if the investigation is going to be limited to observations that do not change the condition of any of the structures or equipment.

6.3 *Documentary Information*—The following information may be of interest; not all of the information ultimately obtained will be available at the time of the initial field investigation. Nevertheless, the collection process should begin as soon as practical.

6.3.1 Emergency phone line recordings and medical records, particularly those that describe the blood gas analysis of the victims.

6.3.2 Obtain statements as early as possible from all individuals associated with the incident.

6.3.2.1 Determination of whether the occupants (including small animals) exhibited prior signs of carbon monoxide exposure; for example, flu like symptoms.

6.3.2.2 First responders' test protocols and data.

6.3.2.3 First responders' actions to correct defects or remove carbon monoxide sources.

6.3.3 Weather data prior to and at the time of the incident; wind speed and direction, temperature, precipitation (snow, rain).

6.3.4 Altitude of the site if over 2000 feet; see NFPA 54 regarding high altitude installations.

6.3.5 Maintenance/service records for any fuel burning equipment, including maintenance contracts.

6.3.6 Equipment manuals or other related information regarding operation, service, maintenance, and input ratings.

6.3.7 Activities prior to the incident that may have affected the fuel sources, fuel burning equipment or ventilation of combustion products.

6.3.8 Information about the status of carbon monoxide alarms and monitoring systems.

6.3.9 Layout of the rooms and their dimensions.

6.4 Identify all fuel-burning equipment in the site. Determine when and how often the equipment operates.

6.4.1 Fuel gas burning equipment is operated on natural gas or propane. This equipment includes boilers, furnaces, water heaters, dryers, forklifts, gas fireplaces, stoves, ovens, etc. This equipment may be vented to the outside or unvented (discharging combustion products to the living or working space).

6.4.2 Liquid burning equipment is operated on gasoline, diesel, kerosene or fuel oil. This equipment includes internal combustion engines, kerosene heaters and fuel oil burning furnaces. The equipment is usually unvented if it is portable and vented if it is stationary.

6.4.3 Solid burning equipment includes wood stoves, fireplaces and pellet stoves. These are usually stationary and vented. If applicable, note position of fireplace dampers (open or closed) as well as door and window positions.

6.5 Identify all ventilation equipment, not associated with fuel burning equipment. This equipment includes power vents for bathrooms or gas ranges, electric dryers, and heat recovery ventilators.

6.6 Determine and document the condition of the equipment at the time of the incident.

6.6.1 Determine the condition of the flues on ventilated equipment. Look for sooting that would indicate incomplete combustion. Look for corrosion that might permit the recirculation of combustion products as combustion air.

6.6.2 If the equipment includes a heat exchanger, determine whether there is a crack or break that might permit combustion products being introduced into the living/working space.

6.6.3 Measure the pressure to fuel gas appliances during operation, as well as the regulated pressure within those appliances.

6.6.4 If the equipment is convertible (for example, natural gas to propane), determine whether it is properly configured and adjusted.

6.6.5 If the altitude is above 2000 feet above sea level, determine whether the equipment is adjusted in accordance with the appliance instructions or NFPA 54.

6.6.6 Establish the condition of valves and/or switches. Systems within an appliance may be tested individually or in combination with the overall function of the appliance.

6.7 Determine the source of fuel, combustion air, and ventilation of each piece of equipment.

6.7.1 Determine whether any of the equipment is located in an enclosure that can be defined as a "confined space." Confined spaces are defined in NFPA 54 as, "a space whose volume is less than fifty cubic feet per 1000 BTU per hour (4.8 m³ per kW) of the aggregate input of all appliances installed in that space."

6.7.2 Determine whether the equipment has an adequate supply of air for combustion and ventilation as specified in NFPA 54, Chapter 9.

6.7.2.1 Where combustion air is obtained directly from the outdoors, determine whether openings comply with NFPA 54; including reduction due to louvers, grills and screens.

6.7.2.2 Where combustion air is mechanically supplied, determine whether openings comply with NFPA 54.