



Standard Specification for Entrainment Separators for Use in Marine Piping Applications¹

This standard is issued under the fixed designation F1006; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

^{ε1} NOTE—The Keywords Section was editorially added in November 2014.

1. Scope

1.1 This specification covers the minimum requirements for the pressure-temperature rating, testing, and making of pressure-containing vessels for entrainment separators.

1.2 The values stated in inch-pound units are to be regarded as the standard. The values given in parentheses are for information only—mathematical conversions to SI units that are provided for information only and are not considered standard.

1.3 The following safety hazards caveat pertains only to the test methods portion, Section 6, of this specification: *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

2. Referenced Documents

2.1 ANSI Standards:²

B2.1 Pipe Threads (Except Dryseal)

B16.1 Cast Iron Pipe Flanges and Flanged Fittings

B16.3 Malleable Iron Threaded Fittings, Class 150 and 300

B16.4 Cast Iron Threaded Fittings, Class 125 and 250

B16.5 Steel Pipe Flanges and Flanged Fittings

B16.11 Forged Steel Fittings, Socket Welding and Threaded

B16.15 Cast Bronze Threaded Fittings, Class 150 and 300

B16.24 Bronze Flanges and Flanged Fittings, Class 150 and 300

B16.25 Buttwelding Ends

B16.31 Nonferrous Pipe Flanges

2.2 ASME Standards:³

SA278 Cast Gray Iron Pressure Vessels

SA395-60 Cast Ductile Iron

Boiler and Pressure Vessel Code, Section VIII

Boiler and Pressure Vessel Code, Section II

2.3 ~~Manufacturer's Standardization Society of the Valve and Fittings Industry Standard:~~ **MSS Standards:**⁴

MSSSP-51 150 LB Corrosion Resistant Cast Flanges and Flanged Fittings

2.4 ~~Military Standard:~~ **Standards:**⁵

MIL-F-1183 Fittings Tube, Bronze, Cast (Silver Brazings)

¹ This specification is under the jurisdiction of Committee F25 on Ships and Marine Technology and is the direct responsibility of Subcommittee F25.11 on Machinery and Piping Systems.

Current edition approved Nov. 1, 2008. Published December 2008/November 2014. Originally approved in 1986. Last previous edition approved in 2004/2008 as F1006 – 86/F1006 – 86 (2008), (2004). DOI: 10.1520/F1006-86R08-10.1520/F1006-86R14E01.

² Available from American National Standards Institute (ANSI), 25 W. 43rd St., 4th Floor, New York, NY 10036, <http://www.ansi.org>.

³ Available from American Society of Mechanical Engineers (ASME), ASME International Headquarters, Three Two Park Ave., New York, NY 10016-5990, <http://www.asme.org>.

⁴ Available from Manufacturers Standardization Society of the Valve and Fittings Industry (MSS), 127 Park St., NE, Vienna, VA 22180-4602, <http://www.mss-hq.com>.

⁵ Available from Standardization Documents Order Desk, DODSSP, Bldg. 4, Section D, 700 Robbins Ave., Philadelphia, PA 19111-5098, <http://www.dodssp.daps.mil>.

3. Definitions of Terms Specific to This Standard

3.1 *entrainment separator*—a mechanical device inserted in a pipeline which by centrifugal force, baffles, or other means will separate a liquid from a gas (vapor).

3.2 *hydrostatic test*—the act of filling an entrainment separator vessel with water and applying internal pressure to all parts of the vessel.

3.3 *master gage*—the calibrated gage used to verify the accuracy of the test gage. This gage shall be recalibrated traceable to the National Bureau of Standards.

3.4 *pressure rating*—the maximum working pressure of an entrainment separator when operated at a specific temperature.

3.5 *proof test*—the act of filling an entrainment separator vessel with water and applying internal pressure to all parts of the vessel for the purpose of causing yielding of the vessel and bursting of the vessel.

3.6 *temperature ratings*—minimum and maximum temperatures at which the entrainment separator may be operated while at specific pressures.

3.7 *test gage*—the pressure gage that is used to check the internal pressure of the entrainment separator. The test gage shall be calibrated at least annually or at any time it is suspected to be in error by a calibrated master gage.

4. Materials and Manufacture

4.1 The pressure-temperature ratings established under this specification are based upon the manufacturer's manufacturer's usage of high quality materials produced under regular control of chemical and physical properties by a recognized process. The manufacturer shall be prepared to submit certification of compliance, verifying that his product has been so produced and that it has been manufactured from material with chemical and physical properties at least equal to the requirements of the appropriate standard or specification listed in 4.3 of this specification or Section II of the ASME Boiler and Pressure Vessel Code.

4.2 For materials not having values of allowable stress tabulated in Section VIII Division I of the ASME Boiler and Pressure Vessel Code, allowable stresses shall be determined in accordance with the procedures outlined in Appendix P of Section VIII, Division 1 of the ASME Boiler and Pressure Vessel Code.

4.3 Materials of construction shall be suitable for the service intended.

4.4 Bolting materials shall be at least equal to those listed in Table 1B of ANSI B16.5. Bolting materials shall not be used beyond temperature limits specified in the governing codes.

5. Requirements

5.1 Entrainment separators covered in this specification shall be designed according to the lowest pressure-temperature rating of any individual component, or as established by proof tests.

5.2 The design pressure-temperature of entrainment separators covered in this specification will be established by the manufacturer using one of the following methods:

5.2.1 Design calculations in accordance with the requirements prescribed in the ASME Boiler and Pressure Vessel Code, Section VIII, Division 1, Part UG of Subsection A and the applicable part of Subsection C.

5.2.2 Proof test in accordance with the requirements of UG 101 (m), UCI-101, or UCD-101 of Section VIII, Division 1 of the ASME Boiler and Pressure Vessel Code.

5.2.3 Where any part of the entrainment separator vessel cannot be designed within the scope of the ASME Boiler and Pressure Vessel Code, Section VIII, Division 1, Design Section, the pressure-temperature rating must be determined through proof and hydrostatic tests using the following formulas to determine the allowable operating limits of pressure and temperature. Operator safety should be considered when conducting these tests.

$$P = \left(\frac{P_{HT}}{4} \right) \times \left(\frac{S_1}{S_2} \right) \text{ (for steel vessels)}$$

$$P = \left(\frac{P_{HT}}{4} \right) \times \left(\frac{T_1}{T_2} \right) \text{ (for cast - iron vessels)}$$

where:

- P = maximum allowable working pressure (psig) at design temperature,
- P_{HT} = hydrostatic test pressure (psig) at test temperature,
- S_1 = stress value at design temperature (psi),
- S_2 = stress value at test temperature (psi),
- T_1 = specified minimum tensile strength (psi), and
- T_2 = actual tensile strength test specimen (psi).

5.2.3.1 Stress values S_1 and S_2 are determined from Section VIII, of the ASME Boiler and Pressure Vessel Code.