

INTERNATIONAL STANDARD

IEC
61131-1

Second edition
2003-05

Programmable controllers –

Part 1: General information

Automates programmables –

*Partie 1:
Informations générales*

[IEC 61131-1:2003](#)

<https://standards.iteh.ai/catalog/standards/iec/633d5c7-28ec-492c-bdf7-0eeb245fbcc1/iec-61131-1-2003>



Reference number
IEC 61131-1:2003(E)

Publication numbering

As from 1 January 1997 all IEC publications are issued with a designation in the 60000 series. For example, IEC 34-1 is now referred to as IEC 60034-1.

Consolidated editions

The IEC is now publishing consolidated versions of its publications. For example, edition numbers 1.0, 1.1 and 1.2 refer, respectively, to the base publication, the base publication incorporating amendment 1 and the base publication incorporating amendments 1 and 2.

Further information on IEC publications

The technical content of IEC publications is kept under constant review by the IEC, thus ensuring that the content reflects current technology. Information relating to this publication, including its validity, is available in the IEC Catalogue of publications (see below) in addition to new editions, amendments and corrigenda. Information on the subjects under consideration and work in progress undertaken by the technical committee which has prepared this publication, as well as the list of publications issued, is also available from the following:

- **IEC Web Site** (www.iec.ch)

- **Catalogue of IEC publications**

The on-line catalogue on the IEC web site (http://www.iec.ch/searchpub/cur_fut.htm) enables you to search by a variety of criteria including text searches, technical committees and date of publication. On-line information is also available on recently issued publications, withdrawn and replaced publications, as well as corrigenda.

- **IEC Just Published**

This summary of recently issued publications (http://www.iec.ch/online_news/justpub/jp_entry.htm) is also available by email. Please contact the Customer Service Centre (see below) for further information.

- **Customer Service Centre**

If you have any questions regarding this publication or need further assistance, please contact the Customer Service Centre:

Email: custserv@iec.ch
Tel: +41 22 919 02 11
Fax: +41 22 919 03 00

INTERNATIONAL STANDARD

IEC 61131-1

Second edition
2003-05

Programmable controllers –

Part 1: General information

Automates programmables –

*Partie 1:
Informations générales*

IEC 61131-1:2003

<https://standards.iteh.ai/catalog/standards/iec/633d5c7-28ec-492c-bdf7-0eeb245fbcc1/iec-61131-1-2003>

© IEC 2003 — Copyright - all rights reserved

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

International Electrotechnical Commission, 3, rue de Varembé, PO Box 131, CH-1211 Geneva 20, Switzerland
Telephone: +41 22 919 02 11 Telefax: +41 22 919 03 00 E-mail: inmail@iec.ch Web: www.iec.ch



Commission Electrotechnique Internationale
International Electrotechnical Commission
Международная Электротехническая Комиссия

PRICE CODE

R

For price, see current catalogue

CONTENTS

FOREWORD	3
INTRODUCTION	5
1 Scope	6
2 Normative references	6
3 Terms and definitions	7
4 Functional characteristics	8
4.1 Basic functional structure of a programmable controller system	8
4.2 Characteristics of the CPU function	11
4.3 Characteristics of the interface function to sensors and actuators	13
4.4 Characteristics of the communication function	14
4.5 Characteristics of the human-machine interface (HMI) function	14
4.6 Characteristics of the programming, debugging, monitoring, testing and documentation functions	14
4.7 Characteristics of the power-supply functions	16
5 Availability and reliability	16
Bibliography	18
Figure 1 – Basic functional structure of a PLC-system	8
Figure 2 – Programmable controller hardware model (from IEC 61131-5)	9
Figure 3 – Typical interface/port diagram of a PLC-system (from IEC 61131-2)	10
Table 1 – Summary of programmable functions	12

[IEC 61131-1:2003](https://standards.iteh.ai/catalog/standards/iec/633d5c7-28ec-492c-bdf7-0eeb245fbcc1/iec-61131-1-2003)

<https://standards.iteh.ai/catalog/standards/iec/633d5c7-28ec-492c-bdf7-0eeb245fbcc1/iec-61131-1-2003>

INTERNATIONAL ELECTROTECHNICAL COMMISSION

PROGRAMMABLE CONTROLLERS –**Part 1: General information**

FOREWORD

- 1) The IEC (International Electrotechnical Commission) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of the IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, the IEC publishes International Standards. Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. The IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of the IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested National Committees.
- 3) The documents produced have the form of recommendations for international use and are published in the form of standards, technical specifications, technical reports or guides and they are accepted by the National Committees in that sense.
- 4) In order to promote international unification, IEC National Committees undertake to apply IEC International Standards transparently to the maximum extent possible in their national and regional standards. Any divergence between the IEC Standard and the corresponding national or regional standard shall be clearly indicated in the latter.
- 5) The IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with one of its standards.
- 6) Attention is drawn to the possibility that some of the elements of this International Standard may be the subject of patent rights. The IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61131-1 has been prepared by subcommittee 65B: Devices, of IEC technical committee 65: Industrial-process measurement and control.

This second edition of IEC 61131-1 cancels and replaces the first edition published in 1992 and constitutes a technical revision.

The text of this standard is based on the following documents:

FDIS	Report on voting
65B/484/FDIS	65B/487/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

IEC 61131 consists of the following parts under the general title: *Programmable controllers*.

Part 1: General information

Part 2: Equipment requirements and tests

Part 3: Programming languages

Part 4: User guidelines

Part 5: Communications

Part 6: Reserved

Part 7: Fuzzy-control programming

Part 8: Guidelines for the application and implementation of programming languages for programmable controllers

The committee has decided that the contents of this publication will remain unchanged until 2007. At this date, the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

A bilingual version of this standard may be issued at a later date.

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[IEC 61131-1:2003](#)

<https://standards.iteh.ai/catalog/standards/iec/633df5c7-28ec-492c-bdf7-0eeb245fbcc1/iec-61131-1-2003>

INTRODUCTION

This Part of IEC 61131 constitutes Part 1 of a series of standards on programmable controllers and their associated peripherals and should be read in conjunction with the other parts of the series.

Where a conflict exists between this and other IEC standards (except basic safety standards), the provisions of this standard should be considered to govern in the area of programmable controllers and their associated peripherals.

The purposes of this standard are:

Part 1 establishes the definitions and identifies the principal characteristics relevant to the selection and application of programmable controllers and their associated peripherals;

Part 2 specifies equipment requirements and related tests for programmable controllers (PLC) and their associated peripherals;

Part 3 defines, for each of the most commonly used programming languages, major fields of application, syntactic and semantic rules, simple but complete basic sets of programming elements, applicable tests and means by which manufacturers may expand or adapt those basic sets to their own programmable controller implementations;

Part 4 gives general overview information and application guidelines of the standard for the PLC end-user;

Part 5 defines the communication between programmable controllers and other electronic systems;

Part 6 is reserved;

Part 7 defines the programming language for fuzzy control;

Part 8 gives guidelines for the application and implementation of the programming languages defined in Part 3.

PROGRAMMABLE CONTROLLERS –

Part 1: General information

1 Scope

This Part of IEC 61131 applies to programmable controllers (PLC) and their associated peripherals such as programming and debugging tools (PADTs), human-machine interfaces (HMIs), etc., which have as their intended use the control and command of machines and industrial processes.

PLCs and their associated peripherals are intended to be used in an industrial environment and may be provided as open or enclosed equipment. If a PLC or its associated peripherals are intended for use in other environments, then the specific requirements, standards and installation practices for those other environments must be additionally applied to the PLC and its associated peripherals.

The functionality of a programmable controller can be performed as well on a specific hardware and software platform as on a general-purpose computer or a personal computer with industrial environment features. This standard applies to any products performing the function of PLCs and/or their associated peripherals. This standard does not deal with the functional safety or other aspects of the overall automated system. PLCs, their application programme and their associated peripherals are considered as components of a control system.

Since PLCs are component devices, safety considerations for the overall automated system including installation and application are beyond the scope of this Part. However, PLC safety as related to electric shock and fire hazards, electrical interference immunity and error detecting of the PLC-system operation (such as the use of parity checking, self-testing diagnostics, etc.), are addressed. Refer to IEC 60364 or applicable national/local regulations for electrical installation and guidelines.

This Part of IEC 61131 gives the definitions of terms used in this standard. It identifies the principal functional characteristics of programmable controller systems.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61131-2, *Programmable controllers – Part 2: Equipment requirements and tests*¹

IEC 61131-3:2003, *Programmable controllers – Part 3: Programming languages*

¹ To be published.

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1

application programme or user programme

logical assembly of all the programming language elements and constructs necessary for the intended signal processing required for the control of a machine or process by a PLC-system

3.2

automated system

control system beyond the scope of IEC 61131, in which PLC-systems are incorporated by or for the user, but which also contains other components including their application programmes

3.3

field device

catalogued part to provide input and/or output interfaces or to provide data pre-processing/post-processing to the programmable controller system. A remote field device may operate autonomously from the programmable controller system. It can be connected to the programmable controller using a field bus

3.4

ladder diagram or relay ladder diagram

one or more networks of contacts, coils, graphically represented functions, function blocks, data elements, labels, and connective elements, delimited on the left and (optionally) on the right by power rails

3.5

programmable (logic) controller (PLC)

digitally operating electronic system, designed for use in an industrial environment, which uses a programmable memory for the internal storage of user-oriented instructions for implementing specific functions such as logic, sequencing, timing, counting and arithmetic, to control, through digital or analogue inputs and outputs, various types of machines or processes. Both the PLC and its associated peripherals are designed so that they can be easily integrated into an industrial control system and easily used in all their intended functions

NOTE The abbreviation PLC is used in this standard to stand for programmable controllers, as is the common practice in the automation industry. The use of PC as an abbreviation for programmable controllers leads to confusion with personal computers.

3.6

programmable controller system or PLC-system

user-built configuration, consisting of a programmable controller and associated peripherals, that is necessary for the intended automated system. It consists of units interconnected by cables or plug-in connections for permanent installation and by cables or other means for portable and transportable peripherals

3.7

programming and debugging tool (PADT)

catalogued peripheral to assist in programming, testing, commissioning and troubleshooting the PLC-system application, programme documentation and storage and possibly to be used as HMI. PADTs are said to be pluggable when they may be plugged or unplugged at any time into their associated interface, without any risk to the operators and the application. In all other cases, PADTs are said to be fixed

3.8 remote input/output station (RIOS)

manufacturer's catalogued part of a PLC-system including input and/or output interfaces allowed to operate only under the hierarchy of the main processing unit (CPU) for I/O multiplexing/demultiplexing and data pre-processing/post-processing. The RIOS is the only permitted limited autonomous operation, for example, under emergency conditions such as breakdown of the communication link to the CPU or of the CPU itself, or when maintenance and troubleshooting operations are to be performed

4 Functional characteristics

4.1 Basic functional structure of a programmable controller system

The general structure with main functional components in a programmable controller system is illustrated in Figures 1, 2 and 3. These functions communicate with each other and with the signals of the machine/process to be controlled.




Figure 1 – Basic functional structure of a PLC-system