This document is not an ASTM standard and is intended only to provide the user of an ASTM standard an indication of what changes have been made to the previous version. Because it may not be technically possible to adequately depict all changes accurately, ASTM recommends that users consult prior editions as appropriate. In all cases only the current version of the standard as published by ASTM is to be considered the official document.



Designation: F1120 - 87 (Reapproved 2010) F1120 - 87 (Reapproved 2015) American National Standard

Standard Specification for Circular Metallic Bellows Type Expansion Joints for Piping Applications¹

This standard is issued under the fixed designation F1120; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ε) indicates an editorial change since the last revision or reapproval.

1. Scope

- 1.1 This specification establishes the minimum requirements for the mechanical design, manufacture, inspection, and testing of circular metallic bellows-type expansion joints used to absorb the dimensional changes resulting from piping thermal expansion or contraction, as well as the movement of terminal equipment and supporting structures.
- 1.2 Additional or better features, over and above the minimum requirements set by this specification, are not prohibited by this specification.
- 1.3 The layout of many piping systems provides inherent flexibility through natural changes in direction so that any displacements produce primarily bending or torsional strains, within acceptable limits. Where the system lacks this inherent flexibility the designer should then consider adding flexibility through the use of metallic bellows-type expansion joints.
- 1.4 The values stated in inch-pound units are to be regarded as the standard. The values given in parentheses are for information only. mathematical conversions to SI units that are provided for information only and are not considered standard.

2. Referenced Documents

iTeh Standards

2.1 ANSI Standards:²

ANSI B16.5 Pipe Flanges and Flanged Fittings
B16.25 Butt Welding Ends

ANSI B31.1 Power Piping Code

2.2 ASME Standards:³

Section VIII, Division 1,1 Pressure Vessels

Section IX, IX Welding and Brazing Qualifications

2.3 EJMA Standard:⁴

Standards of the Expansion Joint Manufacturer's Manufacturer's Association 678-c523cad0ed01/astm-f1120-872015

2.4 Pipe Fabrication Institute PFI Standard:⁵

ES-3 Fabrication Tolerances

3. Terminology Definitions

- 3.1 Expansion joint definitions shall be in accordance with those in the EJMA standards. Standards.
- 3.2 double expansion joint—expansion joint consisting of two bellows joined by a common connector.

3.2.1 Discussion—

¹ This specification is under the jurisdiction of ASTM Committee F25 on Ships and Marine Technology and is the direct responsibility of Subcommittee F25.11 on Machinery and Piping Systems.


Current edition approved May 1, 2010May 1, 2015. Published June 2010June 2015. Originally approved in 1987. Last previous edition approved in 20042010 as F1120 – 87 (2004)-(2010). DOI: 10.1520/F1120-87R10.10.1520/F1120-87R15.

² Available from American National Standards Institute (ANSI), 25 W. 43rd St., 4th Floor, New York, NY 10036, http://www.ansi.org.

³ Available from American Society of Mechanical Engineers (ASME), ASME International Headquarters, Three Two Park Ave., New York, NY 10016-5990, http://www.asme.org.

⁴ Available from Expansion Joint Manufacturer's Manufacturer's Association, Inc (EJMA), 25 N. Broadway, Tarrytown, NY 10591.—10591, http://www.ejma.org. The Standardsstandards of the Expansion Joint Manufacturer's Association are a collection of standards developed by this industry and published in one volume, herein called EJMA Standards.

⁵ Available from Pipe Fabrication Institute, 1326 Freeport Rd., Pittsburgh, PA 15238:Institute (PFI), 511 Avenue of the Americas, Suite 601, New York, NY 10011, http://www.pfi-institute.org.



The common connector is anchored to some rigid part of the installation by means of an anchor base. The anchor base may be attached to the common connector either at installation or at time of manufacture. Each bellows acts as a single expansion joint and absorbs the movement of the pipe section in which it is installed independently of the other bellows.

3.3 gimbal expansion joint—expansion joint designed to permit angular rotation in any plane by the use of two pairs of hinges affixed to a common floating gimbal ring.

3.3.1 Discussion—

The gimbal ring, hinges, and pins are designed to restrain the thrust of the expansion joint as a result of internal pressure and extraneous forces, where applicable.

3.4 *hinged expansion joint*—expansion joint containing one bellow designed to permit angular rotation in one plane only by the use of a pair of pins through hinge plates attached to the expansion joint ends.

3.4.1 Discussion—

The hinges and hinge pins are designed to restrain the thrust of the expansion joint as a result of internal pressure and extraneous forces. Hinged expansion joints should be used in sets of two or three to function properly.

3.5 pressure balanced expansion joint—expansion joint designed to absorb axial movement or lateral deflection, or both, while restraining the pressure thrust by means of tie devices interconnecting the flow bellows with an opposed bellows also subjected to line pressure.

3.5.1 Discussion—

This type of expansion joint is intended for use where a change of direction occurs in a run of piping. The flow end of a pressure balanced expansion joint sometimes contains two bellows separated by a common connector, in which case it is called a universal pressure balanced expansion joint.

- 3.6 *single expansion joint*—simplest form of expansion joint, consisting of single bellows construction, designed to absorb all movement of the pipe section in which it is installed.
 - 3.7 swing expansion joint—expansion joint designed to absorb lateral deflection or angular rotation, or both, in one plane.

3.7.1 Discussion—

Pressure thrust and extraneous forces are restrained by the use of a pair of swing bars, each of which is pinned to the expansion joint ends.

3.8 *universal expansion joint*—expansion joint containing two bellows joined by a common connector for the purpose of absorbing any combination of axial movement, lateral deflection, and angular rotation.

3.8.1 Discussion—

Universal expansion joints are usually furnished with control rods to distribute the movement between the two bellows of the expansion joint and stabilize the common connector.

4. Ordering Information

- 4.1 An expansion joint is a unique product and must be specifically designed for the intended service. It is the responsibility of the piping system designer to supply sufficient engineering data necessary for the complete design. The information compiled by the piping system designer must be complete and contain all pertinent data detailing the conditions under which the expansion joint is expected to operate.
 - 4.2 Orders for each expansion joint shall include the following information:
 - 4.2.1 Title, designation number, and latest revision of this specification.
 - 4.2.2 Size—The nominal pipe diameter or specific ducting diameter.
 - 4.2.3 Type of Expansion Joint—single, double, universal, guided, hinged, gimbal, swing, or pressure balanced.
 - 4.2.4 Flow Characteristics:
 - 4.2.4.1 Flow Medium—indicate whether the medium is gas or liquid.
 - 4.2.4.2 Flow velocity, medium density, or viscosity, or combination thereof.
 - 4.2.4.3 Flow direction.

- 4.2.5 Pressure in psig (N/mm²)—design, operating, and test pressures.
- 4.2.6 *Temperature in* °*F* (°*C*)—design, operating, and installation temperatures.
- 4.2.7 *Movement*—axial (extension, compression); lateral (single plane, multiplane); angular; torsional (to be avoided). Differentiate between start-up, operational, or field installation tolerance movements.
- 4.2.8 *Materials*—Material types (including that for the bellows) shall be specified by the purchaser (see 5.1 for material restrictions).
- 4.2.9 *Internal Liner*—Liner shall be specified when needed because of flow velocity or other flow conditions. Specific criteria for liners is shown in Section C-3 of the EJMA Standards (see 6.6).
- 4.2.10 *External Cover*—To protect personnel having close access to the bellows, when thermal insulation is to be added in the field, or when external mechanical damage is possible (see 6.5).
- 4.2.11 *End Fittings*—The type of end connections such as flanged, threaded, or others to match the mating piping or terminal equipment.
- 4.2.12 *Accessories*—Specify what accessories are required and the conditions under which they operate. Consider items such as insulation lugs, tie, limit, or control rods, pantographic linkages, trunions, gimbals, drains, purge connections, anchor bases, and interply monitoring devices.
- 4.2.13 *Dimensional Limitations*—If space limitations exist, specify the maximum overall length, maximum outside diameter, minimum inside diameter, and installation tolerances.
- 4.2.14 *Operating Forces*—Specify calculated bellows spring forces and pressure thrust forces if they are required for subsequent anchor design or other piping systems analysis. If there are maximum allowable values, these must also be specified.
 - 4.2.15 Installation Position—horizontal, vertical (flow up or down). Specify if liner drainage holes are required.
 - 4.2.16 Cycle Life Requirements—Specify an anticipated number of thermal cycles over the intended life of the expansion joint.
- 4.2.17 *Testing Requirements*—Specify testing requirements in addition to the hydrostatic test required by 9.4 (for example, vacuum testing, testing at operating temperature).
- 4.2.18 *Inspection Requirements*—Specify inspection requirements in addition to the inspection required by Section 9 (that is, radiographic, fluorescent penetrant, or mass spectrometer).
- 4.2.19 *Piping Code Requirements*—Specify any piping or design code that must be used as the basis for design in addition to those specified in 5.2.
 - 4.2.20 Special Requirements—Specify the magnitude of special system conditions such as vibration, shock, or hydraulic surge.
- 4.2.21 *Shipping Requirements*—Specify whether special packing is required including protection for extended outside storage, export handling, or special lifting considerations for heavy or large assemblies.
- 4.2.22 *Piping Drawing*—In addition to specifying the above information it would be beneficial to provide a drawing of the proposed piping system.
 - 4.2.23 Supplementary Requirements—Specify any additional requirements not identified herein.
 - 4.3 Fig. 1 and Fig. 2 should be used as a guide in ordering expansion joints to this specification.

5. Materials and Manufacture

- 5.1 Materials:
- 5.1.1 Pressure-containing parts shall be manufactured from material specifications and grades listed in Section VIII, Division 1, of the ASME Code or ANSI B31.1. End connection material shall have in service properties similar to the bellows material. Flanges shall meet ANSI B16.5.
- 5.1.2 All other materials of construction shall be of the type specified by the user and shall conform to an ASTM or ASME material specification. Materials not identified by the ordering data shall be of the manufacturer's standard and of the same quality used for the intended purpose in commercial practice.
 - 5.1.3 Materials used shall be free from defects that would adversely affect the performance of the expansion joint.
- 5.1.4 All material incorporated in the work covered by this specification shall be new. The use of rebuilt or used products is not allowed under this specification.
 - 5.1.5 Materials for hinge or gimbal hardware, or other sliding parts, shall be chosen to minimize galling of the contacting parts.
 - 5.2 Manufacture:
- 5.2.1 Expansion joints shall be designed and fabricated in accordance with requirements set forth in the ordering data and the EJMA Standards.
- 5.2.2 Nonstandard flanges shall be designed and fabricated in accordance with Appendix 2 of Section VIII, Division 1,of the ASME Code. Flanges machined from plate shall not be used at pressures exceeding 150 psi (1034 kPa) and temperatures exceeding 450°F (232°C). Hubbed flanges machined from plate or bar stock shall meet the requirements of Appendix 2, Paragraph 2-2(d) of Section VIII, Division 1,of the ASME Code.
 - 5.2.3 All welding shall be accomplished in accordance with ANSI B31.1
- 5.2.4 Welding personnel and welding procedures shall be qualified in accordance with the applicable sections of Section IX, of the ASME Code.

COMPANY:					DATE			
					SHEET	OF		
PROJECT:					INQUIRY NO.			
	,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,			JOB NO.				
					pob ito:	T		
	ITEM NO./EJ	TAG NO.	EJMA				-+	
1	QUANTITY		PAGE				-+	
2	NOMINAL SIZE/I.D./O.D. (IN.)		REFERENCE				-+	
3	EXPANSION JOINT TYPE	1				-+		
4a	FLUID	MEDIUM GAS/LIQUID	5, 6, 147				-+	
4b	INFORMATION	VELOCITY (FT./SEC)	77				-	
4c		FLOW DIRECTION					$-\!\!+\!\!$	
5	DESIGN PRESSURE, PSIG		6, 19,				$-\!\!\!+\!\!\!\!-$	
6	TEST PRESSURE, PSIG		83, 135				\longrightarrow	
7a	TEMPERATURE	DESIGN (°F)						
7b		MAXIMUM/MINIMUM (°F)	6, 13					
7c		INSTALLATION (°F)						
8a	MAXIMUM	AXIAL COMPRESSION (IN	.)					
8b	INSTALLATION	AXIAL EXTENSION (IN.)	6, 7, 8,					
8c	MOVEMENT	LATERAL (IN.)	141					
8d		ANGULAR (DEG.)						
9a		AXIAL COMPRESSION (IN	.)					
9b	MAXIMUM	AXIAL EXTENSION (IN.)	6, 7, 13,					
9c	DESIGN MOVEMENTS	LATERAL (IN.)	47	_	1			
9d		ANGULAR (DEG.)	n Stand	ar	US			
9e		NO. OF CYCLES						
10a		AXIAL COMPRESSION (IN	standar		iteh	ail		
10b	ODEDATING	AXIAL EXTENSION (IN.)	, con ructi		100111	,		
10c	OPERATING FLUCTUATIONS	LATERAL (IN.)	84	MOX	HOW			
10d		ANGULAR (DEG.)	mid III	IUV	IUW			
10e		NO. OF CYCLES						
11a		BELLOWS	5, 6, 45	2015)				
11b	MATERIALS	LINERS	77, 78	2013)				
11c	os://standords.iteh.ai/c	COVER standards/sist/	7, 72 -	4b12-	9678-c52	3cad0ed01/a	ıstm-fl	120-872015
11d	CONSTRUCTION	PIPE SPECIFICATION						
11e		FLANGE SPECIFICATION	3, 43					
12	RODS (TIE/LIMIT/CONTROL)		3, 4, 41					
13	PANTOGRAPHIC LINKAGE		4					
14	ANCHOR BASE (MAIN/INTERMEDIATE)		1, 2, 17					
15a	-	OVERALL LENGTH (IN.)					-	
15b	DIMENSIONAL LIMITATIONS	OUTSIDE DIAMETER (IN.))					
15c		INSIDE DIAMETER (IN.)						
16a		AXIAL (LBS./IN.)						
16b	SPRING RATE	LATERAL (LBS./IN.)	54					
16c	LIMITATIONS	ANGULAR (INLBS./DEG.)					-+	
17	INSTALLATION POSITION	8, 141						
18a		BELLOWS LONG. S	EAM				-+	
18b		WELD NDE ATTAC					-+	
18c	QUALITY	PIPING NDE					-+	
18d	ASSURANCE	DESIGN CODE REQRD.					-+	
18e	REQUIREMENTS	PARTIAL DATA REQRD.					-+	
18f					<u> </u>		-+	
18g							-+	
19	VIBRATION AMPLITUDE/FREOUENCY						-+	

FIG. 1 Standard Expansion Joint Specification Sheet