



Designation: **C1224 – 11** **C1224 – 15**

Standard Specification for Reflective Insulation for Building Applications¹

This standard is issued under the fixed designation C1224; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This specification covers the general requirements and physical properties of reflective insulations for use in building applications. These insulation materials consist of one or more low emittance surfaces, such as metallic foil or metallic deposits, unmounted or mounted on substrates. Reflective insulations derive thermal performance from surfaces with an emittance of 0.1 or less, facing enclosed air spaces.

1.2 The values stated in inch-pound units are to be regarded as standard. The values given in parentheses are mathematical conversions to SI units that are provided for information only and are not considered standard.

1.3 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

2. Referenced Documents

2.1 *ASTM Standards:*²

[C168 Terminology Relating to Thermal Insulation](#)

[C177 Test Method for Steady-State Heat Flux Measurements and Thermal Transmission Properties by Means of the Guarded-Hot-Plate Apparatus](#)

[C390 Practice for Sampling and Acceptance of Thermal Insulation Lots](#)

[C518 Test Method for Steady-State Thermal Transmission Properties by Means of the Heat Flow Meter Apparatus](#)

[C727 Practice for Installation and Use of Reflective Insulation in Building Constructions](#)

[C1258 Test Method for Elevated Temperature and Humidity Resistance of Vapor Retarders for Insulation](#)

[C1338 Test Method for Determining Fungi Resistance of Insulation Materials and Facings](#)

[C1363 Test Method for Thermal Performance of Building Materials and Envelope Assemblies by Means of a Hot Box Apparatus](#)

[C1371 Test Method for Determination of Emittance of Materials Near Room Temperature Using Portable Emissometers](#)

[E84 Test Method for Surface Burning Characteristics of Building Materials](#)

[E96/E96M Test Methods for Water Vapor Transmission of Materials](#)

[E2599 Practice for Specimen Preparation and Mounting of Reflective Insulation, Radiant Barrier and Vinyl Stretch Ceiling Materials for Building Applications to Assess Surface Burning Characteristics](#)

2.2 *TAPPI Standard:*

[T512 Creasing of Flexible Packaging Material Paper Specimens for Testing](#)³

3. Terminology

3.1 *Definitions*—Terminology [C168](#) shall apply to the terms in this specification.

4. Ordering Information

4.1 Prior to purchase, for sampling and acceptance procedures, Practice [C390](#) is an option when agreed upon by the purchaser and the manufacturer.

¹ This specification is under the jurisdiction of ASTM Committee [C16](#) on Thermal Insulation and is the direct responsibility of Subcommittee [C16.21](#) on Reflective Insulation.

Current edition approved ~~May 15, 2011~~ Oct. 15, 2015. Published ~~July 2011~~ November 2015. Originally approved in 1993. Last previous edition approved in ~~2009~~ 2011 as [C1224-09-11](#). DOI: [10.1520/C1224-11](#). [10.1520/C1224-15](#).

² For referenced ASTM standards, visit the ASTM website, [www.astm.org](#), or contact ASTM Customer Service at [service@astm.org](#). For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

³ Available from Technical Association of the Pulp and Paper Industry (TAPPI), 15 Technology Parkway South, Norcross, GA 30092, [http://www.tappi.org](#).

- 4.2 Specify the required thermal resistance by the direction of the heat flow.
- 4.3 Specify the width, depth, and total area to be insulated.
- 4.4 Specify special markings, when required.

5. Materials and Manufacture

5.1 Reflective insulation materials shall consist of low emittance surface(s) with, or without, substrates and adhesives required to meet the specified thermal performance and physical properties.

5.2 Multiple layer reflective insulations shall be designed to attain the intended separation of layers in normal application. Such multiple layer insulation shall form an attachment flange suitable for stapling, or other means of attachment.

5.3 *Dimensions*—Insulation shall be furnished in dimensions to fit framing members, at spacings standard in the construction industry, or as specifically agreed upon between the producer and the buyer.

6. Physical Properties Requirements

6.1 Low emittance materials shall have a surface with an emittance of 0.1 or less, as determined in accordance with 9.1.

6.2 *Permeance*—When the reflective insulation is to serve as a vapor retarder, the permeance of the material shall not exceed one perm, as determined in accordance with 9.2.

6.2.1 When the reflective insulation is to be vapor transmitting the permeance of the material shall be equal to or greater than five perms, as determined in accordance with 9.2.

6.3 *Surface Burning Characteristics*—Building code requirements specify flame spread and smoke development values determined in accordance with 9.3, except as follows:

(1) Maximum surface burning characteristics shall not exceed 25 flame spread index and 50 smoke development index for inside plenum applications.

(2) Maximum surface burning characteristics shall not exceed 25 flame spread index and 450 smoke development index in exposed building applications.

6.4 *Humidity Resistance*—The laminates of the reflective insulation shall be tested in accordance with 9.4. Three specimens shall be exposed. Shield the test specimens from condensate that drips from the ceiling of the humidity chamber.

6.4.1 The specimens shall be evaluated for visible corrosion and delamination. For purposes of corrosion evaluation disregard the outer 0.25 in. (6.4 mm) perimeter. No tested specimen shall exhibit visible crystalline deposits exceeding 2 % of the test area nor exhibit unaided delamination of layers.

6.5 *Adhesive Performance:*

6.5.1 *Bleeding*—Adhesives, when used, shall show no sign of bleeding when tested in accordance with the test procedure in 9.5.1. Disregard bleeding at cut edges. Bleeding or delamination, covering over 2 % of the specimen area, shall be cause for rejection.

6.5.2 *Pliability*—Specimens tested in accordance with the test procedure in 9.5.2 shall not show cracking or delamination.

6.6 *Fungi Resistance*—Specimens shall not have growth greater than comparative item when tested in accordance with 9.6. Use Interpretation of Results (Paragraph 7.2) of Test Method C1338.

6.7 *Thermal Resistance*—Determine the thermal resistance in accordance with procedures in 9.7. The results of the procedures shall indicate the R-value of the ~~product,~~ product and the enclosed air space, in the assembly tested.

7. Workmanship, Finish, and Appearance

7.1 The insulation shall be manufactured, packaged, and shipped in such a manner that, when received by the customer, it shall be suitable for installation in accordance with Practice C727.

8. Sampling

8.1 Sampling shall be performed in accordance with Practice C390.

9. Test Methods

9.1 *Emittance*—The emittance of the product shall be tested in accordance with Test Method C1371.

9.2 *Permeance*—The permeance of the product shall be tested in accordance with Test Method E96/E96M, Desiccant Method.

9.3 *Surface Burning*—Surface burning characteristics shall be tested in accordance with Test Method E84 and shall be mounted according to Practice E2599.

9.4 *Humidity Resistance*—The humidity resistance of the product shall be tested in accordance with Test Method C1258.

9.5 *Adhesive Performance:*