



Designation: D5411 – 10 (Reapproved 2015)

Standard Practice for Calculation of Average Energy Per Disintegration (\bar{E}) for a Mixture of Radionuclides in Reactor Coolant¹

This standard is issued under the fixed designation D5411; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This practice applies to the calculation of the average energy per disintegration (\bar{E}) for a mixture of radionuclides in reactor coolant water.

1.2 The microcurie (μCi) is the standard unit of measurement for this standard. The values given in parentheses are mathematical conversions to SI units, which are provided for information only and are not considered standard.

1.3 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety, health, and environmental practices and determine the applicability of regulatory limitations prior to use.*

1.4 *This international standard was developed in accordance with internationally recognized principles on standardization established in the Decision on Principles for the Development of International Standards, Guides and Recommendations issued by the World Trade Organization Technical Barriers to Trade (TBT) Committee.*

2. Referenced Documents

2.1 ASTM Standards:²

D1066 Practice for Sampling Steam

D1129 Terminology Relating to Water

D3370 Practices for Sampling Water from Closed Conduits

D3648 Practices for the Measurement of Radioactivity

D7282 Practice for Set-up, Calibration, and Quality Control of Instruments Used for Radioactivity Measurements

2.2 Code of Federal Regulations:

10 CFR 100 Reactor Site Criteria³

¹ This practice is under the jurisdiction of ASTM Committee D19 on Water and is the direct responsibility of Subcommittee D19.04 on Methods of Radiochemical Analysis.

Current edition approved Dec. 15, 2015. Published December 2015. Originally approved in 1993. Last previous edition approved in 2010 as D5411 – 10. DOI: 10.1520/D5411-10R15.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

³ Available from Standardization Documents Order Desk, Bldg. 4 Section D, 700 Robbins Ave., Philadelphia, PA 19111-5094, Attn: NPODS.

3. Terminology

3.1 *Definitions*—For definitions of terms used in this practice, refer to Terminology D1129.

4. Summary of Practice

4.1 The average energy per disintegration, \bar{E} (pronounced *E bar*), for a mixture of radionuclides is calculated from the known composition of the mixture. \bar{E} is computed by calculating the total beta/gamma energy release rate, in MeV, and dividing it by the total disintegration rate. The resultant \bar{E} has units of MeV per disintegration.

5. Significance and Use

5.1 This practice is useful for the determination of the average energy per disintegration of the isotopic mixture found in the reactor-coolant system of a nuclear reactor (1).⁴ The \bar{E} value is used to calculate a site-specific activity limit for the reactor coolant system, generally identified as

$$A_{\text{limiting}} = K/\bar{E}$$

where

K = a power reactor site specific constant (usually in the range of 50 to 200).

The activity of the reactor coolant system is routinely measured, then compared to the value of A_{limiting} . If the reactor coolant activity value is less than A_{limiting} then the 2-h radiation dose, measured at the plant boundary, will not exceed an appropriately small fraction of the Code of Federal Regulations, Title 10, part 100 dose guidelines. It is important to note that the measurement of the reactor coolant system radioactivity is determined at a set frequency by use of gamma spectrometry *only*. Thus the radionuclides that go into the calculation of \bar{E} and subsequently A_{limiting} are only those that are calculated using gamma spectrometry.

5.2 In calculating \bar{E} , the energy dissipated by beta particles (negatrons and positrons) and photons from nuclear decay of beta-gamma emitters. This accounting includes the energy

⁴ The boldface numbers in parentheses refer to a list of references at the end of this practice.

released in the form of energy released from extra-nuclear transitions in the form of X-rays, Auger electrons, and conversion electrons. However, not all radionuclides present in a sample are included in the calculation of \bar{E} .

5.3 Individual, nuclear reactor, technical specifications vary and each nuclear operator must be aware of limitations affecting their plant operation. Typically, radioiodines, radionuclides with half lives of less than 10 min (except those in equilibrium with the parent), and those radionuclides, identified using gamma spectrometry, with less than a 95 % confidence level, are not typically included in the calculation. However, the technical requirements are that the reported activity must account for at least 95 % of the activity after excluding radioiodines and short-lived radionuclides. There are individual bases for each exclusion.

5.3.1 Radioiodines are typically excluded from the calculation of \bar{E} because United States commercial nuclear reactors are required to operate under a more conservative restriction of 1 μC (37 kBq) per gram dose equivalent ^{131}I (DEI) in the reactor coolant.

5.3.2 Beta only emitting radio isotopes (for example, ^{90}Sr or ^{63}Ni) and alpha emitting radioisotopes (for example, ^{241}Am or ^{239}Pu) which comprise a small fraction of the activity, should not be included in the E-bar calculation. These isotopes are not routinely analyzed for in the reactor coolant, and thus their inclusion in the E-bar calculation is not representative of what is used to assess the 10 CFR 100 dose limits. Tritium, also a beta only emitter, should not be included in the calculation. Tritium has the largest activity concentration in the reactor coolant system, but the lowest beta particle energy. Thus its dose contribution is always negligible. However its inclusion in the E-bar calculation would raise the value of A_{limiting} , yielding a non-conservative value for dose assessment.

5.3.3 Excluding radionuclides with half-lives less than 10 min, except those in equilibrium with the parent, has several bases.

5.3.3.1 The first basis considers the nuclear characteristics of a typical reactor coolant. The radionuclides in a typical reactor coolant have half-lives of less than 4 min or have half-lives greater than 14 min. This natural separation provides a distinct window for choosing a 10-min half-life cutoff.

5.3.3.2 The second consideration is the predictable time delay, approximately 30 min, which occurs between the release of the radioactivity from the reactor coolant to its release to the environment and transport to the site boundary. In this time, the short-lived radionuclides have undergone the decay associated with several half-lives and are no longer considered a significant contributor to \bar{E} .

5.3.3.3 A final practical basis is the difficulty associated with identifying short-lived radionuclides in a sample that requires some significant time, relative to 10 min, to collect, transport, and analyze.

5.3.4 The value of E-bar is usually calculated once every 6 months. However, anytime a significant increase in the activity of the reactor coolant occurs, the value of E-bar should be reassessed to ensure compliance with 10 CFR 100. Such reassessment should be done any time there is a significant fuel

defect that would alter the \bar{E} value and affect A_{limiting} . The two possible causes to reassess the value of \bar{E} would be:

(1) A significant fuel defect has occurred where the noble gas activity has increased.

(2) A significant corrosion product increase has occurred.

For the case of a fuel defect, the plant staff may need to include new radionuclides not normally used in the calculation of \bar{E} such as ^{239}U and ^{239}Np .

6. Interferences

6.1 The analytical determination of the radionuclides used for this calculation is made by gamma ray spectrometry. Commercially available software is generally used to perform the spectrum analysis and data reduction. However there can be significant number of interferences from gamma ray emitters with multiple gamma ray emissions. The user must carefully select the appropriate interference free gamma ray energy for each radionuclide in order to determine accurately the activity of each radionuclide. As a specific example ^{56}Mn ($t_{1/2} = 2.6$ h) has a gamma ray energy of 847 keV and ^{134}I ($t_{1/2} = 53$ min) also has a gamma ray energy of 847 keV. The 847 keV gamma ray is also the most abundant for each of these radionuclides. It would be inaccurate to use the 847 keV gamma ray for the determination of either of these radionuclides.

7. Sampling

7.1 If samples are collected for analysis in support of this practice they should be representative of the matrix, be of sufficient volume to ensure adequate analysis, and be collected in accordance with Practices **D1066**, **D3370**, and **D3648**.

7.2 In addition to the requirements of **7.1**, if samples of reactor coolant are required in support of this practice, they should typically be collected only after a minimum of 2 effective full-power days and 20 days of power operation have elapsed since the reactor was last subcritical for 48 h or longer. Individual nuclear operator technical specifications (or now for many plants called “technical requirements”) vary and should be reviewed to determine specific requirements.

8. Calibration and Standardization

8.1 Any calibrations and standardizations required in support of this practice should be in accordance with the applicable sections of Practices **D3648** and **D7282** and in accordance with the manufacturer’s specifications for the gamma spectrometry system used.

9. Procedure

9.1 Conduct all analyses in support of this practice in accordance with the applicable sections of Practice **D3648**.

9.2 Perform sufficient gamma isotopic analyses of the liquid, gaseous, and suspended fractions of the sample to ensure that at least 95 % of the coolant activity due to gamma emitting isotopes has been quantified. Samples should be analyzed at approximately 0.5 h, 2 h, 24 h, and 7 days following sample collection. Multiple sample analyses are required to ensure accurate quantification of the longer-lived