



Designation: **D6757–07 (Reapproved 2013) D6757/D6757M – 16**

Standard Specification for Underlayment Felt Containing Inorganic Fibers Used in Steep-Slope Roofing¹

This standard is issued under the fixed designation ~~D6757~~D6757/D6757M; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This specification covers (1) inorganic fiber-reinforced organic felt underlayment and (2) inorganic fiber-based felt for use as underlayment with steep-slope roofing products. The intent of this specification is to provide criteria for producing and evaluating underlayments with a significantly reduced tendency to wrinkle before or after the installation of steep roofing products.

1.2 The values stated in either SI units or inch-pound units are to be regarded separately as the standard. ~~The values in parentheses are for information only.~~ stated in each system may not be exact equivalents; therefore, each system shall be used independently of the other. Combining values from the two systems may result in non-conformance with the standard.

1.3 The following safety hazards caveat pertains only to the test method portion, Section 8, of this specification: *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory requirements prior to use.*

2. Referenced Documents

2.1 ASTM Standards:²

D146 Test Methods for Sampling and Testing Bitumen-Saturated Felts and Woven Fabrics for Roofing and Waterproofing

D228 Test Methods for Sampling, Testing, and Analysis of Asphalt Roll Roofing, Cap Sheets, and Shingles Used in Roofing and Waterproofing

D1079 Terminology Relating to Roofing and Waterproofing

D4869 Specification for Asphalt-Saturated Organic Felt Underlayment Used in Steep Slope Roofing

iTeh Standards

Document Preview

[ASTM D6757/D6757M-16](#)

<https://standards.iteh.ai/catalog/standards/sist/0f87d48c-ef8a-43ff-a08a-fe14531ab041/astm-d6757-d6757m-16>

¹ This specification is under the jurisdiction of ASTM Committee **D08** on Roofing and Waterproofing and is the direct responsibility of Subcommittee **D08.02** on Steep Roofing Products and Assemblies.

Current edition approved ~~June 15, 2013~~ Jan. 1, 2016. Published ~~July 2013~~ January 2016. Originally approved in 2002. Last previous edition approved in ~~2007~~ 2013 as **D6757–07**/**D6757 – 07 (2013)**. DOI: ~~10.1520/D6757-07R13~~ 10.1520/D6757_D6757M-16.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.