



Designation: **D7215 – 08 (Reapproved 2013) D7215 – 16**

Standard Test Method for Calculated Flash Point from Simulated Distillation Analysis of Distillate Fuels¹

This standard is issued under the fixed designation D7215; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope—Scope*

1.1 This test method covers the calculated flash point formula, which represents a means for directly estimating the flash point temperature of distillate fuels from Test Method **D2887** data. The value computed from the equation is termed the “calculated flash point.” The calculated flash point formula is applicable to diesel fuel samples based on a correlation to Test Method **D93** over the range from 4747°C to 99°C , 99°C , and to jet fuel samples based on a correlation to Test Method **D56** and Test Method **D3828** over the range from 3535°C to 67°C , 67°C .

1.2 The calculated flash point formula is valid for diesel and jet fuels with an IBP between 9090°C and 162°C (194162°C (194°F and 324°F), 324°F), Test Method **D2887** 5% recovery temperature between 136136°C and 207°C (277207°C (277°F and 405°F), 405°F), and Test Method **D2887** 10% recovery temperature between 142142°C and 222°C (288222°C (288°F and 432°F), 432°F). For each flash point test method (Test Method **D56**, Test Method **D93**, and Test Method **D3828**) a separate equation has been established. See 4.4 for a detailed overview of the simulated distillation IBP, 5% , and 10% ranges per equation.

1.3 A calculated diagnostic parameter, not exceeding a given threshold value, is a prerequisite for acceptance of the calculated flash point.

1.4 The diagnostic parameter MSPE_x (Mean Summed Prediction Error) checks the sample compliance, based on reconstruction of T_{IBP} , $T_{5\%}$, and $T_{10\%}$ of the sample, via a calculation procedure. A value for MSPE_x not exceeding the threshold level of 1.9°C is a prerequisite for accepting the calculated flash point, CFP.

NOTE 1—It is important to note that calculated flash point results, at this time, are not recognized by regulatory organizations in verifying conformance to applicable regulations.

NOTE 2—The calculated flash point derived from simulated distillation data depends upon the accuracy of determination of the IBP temperature and the 5% and 10% recovery temperatures.

NOTE 3—If the user's specification requires a defined flash point test method other than this test method, neither this test method nor any other test method should be substituted for the prescribed test method without obtaining comparative data and an agreement from the specifier.

1.5 The values stated in SI units are to be regarded as the standard. ~~The values given in parentheses are for information only.~~

1.5.1 *Exception*—The values given in parentheses are for information only.

1.6 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

2. Referenced Documents

2.1 *ASTM Standards:*²

D56 Test Method for Flash Point by Tag Closed Cup Tester

D93 Test Methods for Flash Point by Pensky-Martens Closed Cup Tester

D975 Specification for Diesel Fuel Oils

D1655 Specification for Aviation Turbine Fuels

D2887 Test Method for Boiling Range Distribution of Petroleum Fractions by Gas Chromatography

¹ This test method is under the jurisdiction of ASTM Committee **D02** on Petroleum Products—Products, Liquid Fuels, and Lubricants and is the direct responsibility of Subcommittee **D02.04.0K** on Correlative Methods.

Current edition approved ~~May 1, 2013~~ July 1, 2016. Published ~~August 2013~~ July 2016. Originally approved in 2008. Last previous edition approved in ~~2008~~ 2013 as **D7215 – 08**; **D7215 – 08 (2013)**. DOI: ~~10.1520/D7215-08R13~~ 10.1520/D7215-16.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

*A Summary of Changes section appears at the end of this standard

TABLE 1 Overview

	IBP		5%		10%	
	Min temp	Max temp	Min temp	Max temp	Min temp	Max temp
Test Method D93 Diesel	103°C (217°F)	163°C (326°F)	144°C (291°F)	210°C (410°F)	159°C (318°F)	236°C (457°F)
Test Method D93 Diesel	103 °C (217 °F)	163 °C (326 °F)	144 °C (291 °F)	210 °C (410 °F)	159 °C (318 °F)	236 °C (457 °F)
Test Method D56 Jet Fuel	101°C (213°F)	136°C (277°F)	135°C (275°F)	169°C (337°F)	141°C (285°F)	183°C (362°F)
Test Method D56 Jet Fuel	101 °C (213 °F)	136 °C (277 °F)	135 °C (275 °F)	169 °C (337 °F)	141 °C (285 °F)	183 °C (362 °F)
Test Method D3828 Jet Fuel	101°C (213°F)	136°C (277°F)	135°C (275°F)	169°C (337°F)	141°C (285°F)	183°C (362°F)
Test Method D3828 Jet Fuel	101 °C (213 °F)	136 °C (277 °F)	135 °C (275 °F)	169 °C (337 °F)	141 °C (285 °F)	183 °C (362 °F)

D3828 Test Methods for Flash Point by Small Scale Closed Cup Tester

D6708 Practice for Statistical Assessment and Improvement of Expected Agreement Between Two Test Methods that Purport to Measure the Same Property of a Material

3. Terminology

3.1 Definitions:

3.1.1 *diesel fuel, n*—fuel for diesel engines, as described in Specification **D975**.

3.1.2 *flash point, n*—lowest temperature, corrected to a pressure of ~~101.3 kPa (760 mm Hg)~~ 101.3 kPa (760 mm Hg), at which application of an ignition source causes the vapors of a specimen of the sample to ignite under specified conditions of test.

3.1.3 *jet fuel (kerosene type), n*—aviation turbine fuel as described in Specification **D1655**.

3.1.4 *simulated distillation, n*—distillation, simulated by gas chromatography, to obtain a boiling range distribution.

3.2 Definitions of Terms Specific to This Standard:

3.2.1 *calculated flash point (CFP), n*—flash point calculated using this test method from the IBP, ~~5%, 5 %~~, and ~~10%, 10 %~~ recovery temperature obtained from simulated distillation according to Test Method **D2887**.

3.2.2 *mean sum of prediction errors of variable X (MSPE_X), n*—mean of summed prediction errors of the predictor variables, that is, the recovery temperatures.

3.2.3 *partial least squares (PLS) regression, n*—extension of the multiple linear regression model, specifying a linear relationship between a dependent variable and a set of predictor variables.

4. Significance and Use

4.1 The flash point temperature is one measure of the tendency of the test specimen to form a flammable mixture with air under controlled laboratory conditions. It is only one of a number of properties that must be considered in assessing the overall flammability hazard of a material.

4.2 Flash point is used in shipping and safety regulations to define flammable and combustible materials. Consult the particular regulation involved for precise definitions of these classifications.

4.3 Flash point can indicate the possible presence of highly volatile and flammable materials in a relatively non-volatile or non-flammable material.

4.4 In cases where Test Method **D2887** data are available, that is, for determination of boiling range distribution or calculation of other physical properties, this test method provides a calculation method for flash point without performing an additional analysis. **Table 1** shows the ranges for the IBP, ~~5%, 5 %~~, and ~~10%, 10 %~~ results for each equation.

4.5 In the case where the flash point of a fuel has been initially established, the calculated flash point is useful as a flash point check on subsequent samples of that fuel, provided its source and mode of manufacture remain unchanged.

5. Procedure

5.1 Obtain the IBP, ~~5%, 5 %~~ and ~~10%, 10 %~~ recovered temperatures of the specimen by performing a simulated distillation according to Test Method **D2887**.

5.2 Calculate reconstruction values of T_{IBP} , $T_{5\%}$, and $T_{10\%}$ recovery temperatures according to **Eq 1-3**:

$$\hat{T}_{IBP} = 2.75 + 0.944 \cdot T_{IBP} + 0.163 \cdot T_{5\%} - 0.124 \cdot T_{10\%} \text{ [}^\circ\text{C]} \quad (1)$$

$$\hat{T}_{5\%} = 2.21 + 0.163 \cdot T_{IBP} + 0.363 \cdot T_{5\%} + 0.455 \cdot T_{10\%} \text{ [}^\circ\text{C]} \quad (2)$$

$$\hat{T}_{10\%} = -3.71 - 0.124 \cdot T_{IBP} + 0.455 \cdot T_{5\%} + 0.694 \cdot T_{10\%} \text{ [}^\circ\text{C]} \quad (3)$$

5.3 Compute the sample compliance mean sum of prediction errors of the recovery temperatures, $MSPE_X$ of the specimen according to **Eq 4**: