

Publication 60298 de la CEI
(Troisième édition – 1990)

**Appareillage sous enveloppe métallique pour
courant alternatif de tensions assignées
supérieures à 1 kV et inférieures
ou égales à 52 kV**

IEC Publication 60298
(Third edition – 1990)

**A.C. metal-enclosed switchgear and controlgear
for rated voltages above 1 kV and
up to and including 52 kV**

CORRIGENDUM 2

Sous 3.102.1 et 2, et partout où cela est applicable, remplacer:

«... le degré de protection est donné dans le tableau 1 (ou plus élevé)» *par:*

«... le degré de protection IP2X (ou supérieur) du tableau 6 de la CEI 60694 (1996)».

In 3.102.1 and 2, and wherever it is referred to, replace:

"... the degree of protection included in table 1 (or higher)" *by:*

"... the degree of protection IP2X (or higher) of table 6 of IEC 60694 (1996)".

iTech Standards
(<https://standards.iteh.ai>)
Document Preview

[IEC 60298:1990/COR2:1998](https://standards.iteh.ai/catalog/standards/iec/60694-1996/iec-60298-1990/cor2-1998)

[https://standards.iteh.ai/catalog/standards/iec/60694-1996/iec-60298-1990-cor2-1998](https://standards.iteh.ai/catalog/standards/iec/60694-1996/iec-60298-1990/cor2-1998)