



Designation: **D5222—08 D5222 – 16**

## Standard Specification for High Fire-Point Mineral Electrical Insulating Oils<sup>1</sup>

This standard is issued under the fixed designation D5222; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon ( $\epsilon$ ) indicates an editorial change since the last revision or reapproval.

### 1. Scope

1.1 This specification describes a high fire-point mineral oil based insulating fluid, for use as a dielectric and cooling medium in new and existing power and distribution electrical apparatus, such as transformers and switchgear.

1.2 High fire-point insulating oil differs from conventional mineral insulating oil by possessing a fire-point of at least 300°C. High fire-point mineral insulating oils are also referred to as “less flammable” mineral insulating oils. This property is necessary in order to comply with certain application requirements of the National Electrical Code (Article 450-23) or other agencies. The material discussed in this specification is miscible with other petroleum based insulating oils. Mixing high fire-point liquids with lower fire point hydrocarbon insulating oils (for example, Specification [D3487](#) mineral oil) may result in fire points of less than 300°C.

1.3 This specification is intended to define a high fire-point electrical mineral insulating oil that is compatible with typical material of construction of existing apparatus and will satisfactorily maintain its functional characteristic in its application in this application. The material described in this specification may not be miscible with electrical insulating liquids of non-petroleum origin. The user should contact the manufacturer of the high fire-point insulating oil for guidance in this respect.

1.4 This specification applies only to new insulating material oil as received prior to any processing. Information on in-service maintenance testing is available in appropriate guides.<sup>2</sup> The user should contact the manufacturers of the equipment or oil if questions of recommended characteristics or maintenance procedures arise.

1.5 The values stated in SI units are to be regarded as standard. No other units of measurement are included in this standard.

### 2. Referenced Documents

#### 2.1 *ASTM Standards:*<sup>3</sup>

[D92 Test Method for Flash and Fire Points by Cleveland Open Cup Tester](#)

[D97 Test Method for Pour Point of Petroleum Products](#)

[D117 Guide for Sampling, Test Methods, and Specifications for Electrical Insulating Oils of Petroleum Origin](#)

[D445 Test Method for Kinematic Viscosity of Transparent and Opaque Liquids \(and Calculation of Dynamic Viscosity\)](#)

~~[D611 Test Methods for Aniline Point and Mixed Aniline Point of Petroleum Products and Hydrocarbon Solvents](#)~~

[D664 Test Method for Acid Number of Petroleum Products by Potentiometric Titration](#)

~~[D877](#)~~ [D878 Test Method for Dielectric Breakdown Voltage of Insulating Liquids Using Disk Electrodes](#) [Inorganic Chlorides and Sulfates in Insulating Oils \(Withdrawn\)](#)

~~[D878 \(Withdrawn 2015\)](#)~~<sup>4</sup>

[D923 Practices for Sampling Electrical Insulating Liquids](#)

[D924 Test Method for Dissipation Factor \(or Power Factor\) and Relative Permittivity \(Dielectric Constant\) of Electrical Insulating Liquids](#)

[D971 Test Method for Interfacial Tension of Oil Against Water by the Ring Method](#)

[D974 Test Method for Acid and Base Number by Color-Indicator Titration](#)

[D1275 Test Method for Corrosive Sulfur in Electrical Insulating Liquids](#)

<sup>1</sup> This specification is under the jurisdiction of ASTM Committee [D27](#) on Electrical Insulating Liquids and Gases and is the direct responsibility of Subcommittee [D27.01](#) on Mineral.

Current edition approved Jan. 1, 2008; Nov. 1, 2016. Published February 2008; December 2016. Originally approved in 1992. Last previous edition approved in 2000 as [D5222-00-08](#). DOI: [10.1520/D5222-08.10.1520/D5222-16](#).

<sup>2</sup> Refer to [American National Standard C57.121 IEEE Guide for Acceptance and Maintenance of Less Flammable Hydrocarbon Fluid in Transformers](#); IEEE C57.121.

<sup>3</sup> For referenced ASTM standards, visit the ASTM website, [www.astm.org](#), or contact ASTM Customer Service at [service@astm.org](#). For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

D1298 Test Method for Density, Relative Density, or API Gravity of Crude Petroleum and Liquid Petroleum Products by Hydrometer Method

D1500 Test Method for ASTM Color of Petroleum Products (ASTM Color Scale)

D1524 Test Method for Visual Examination of Used Electrical Insulating Liquids in the Field

D1533 Test Method for Water in Insulating Liquids by Coulometric Karl Fischer Titration

D1816 Test Method for Dielectric Breakdown Voltage of Insulating Liquids Using VDE Electrodes

D2112 Test Method for Oxidation Stability of Inhibited Mineral Insulating Oil by Pressure Vessel

D2300 Test Method for Gassing of Electrical Insulating Liquids Under Electrical Stress and Ionization (Modified Pirelli Method)

D2440 Test Method for Oxidation Stability of Mineral Insulating Oil

D2668 Test Method for 2,6-*di-tert*-Butyl- *p*-Cresol and 2,6-*di-tert*-Butyl Phenol in Electrical Insulating Oil by Infrared Absorbance

D2864 Terminology Relating to Electrical Insulating Liquids and Gases

D3487 Specification for Mineral Insulating Oil Used in Electrical Apparatus

D4052 Test Method for Density, Relative Density, and API Gravity of Liquids by Digital Density Meter

D4059 Test Method for Analysis of Polychlorinated Biphenyls in Insulating Liquids by Gas Chromatography

D4768 Test Method for Analysis of 2,6-Ditertiary-Butyl Para-Cresol and 2,6-Ditertiary-Butyl Phenol in Insulating Liquids by Gas Chromatography

D5949 Test Method for Pour Point of Petroleum Products (Automatic Pressure Pulsing Method)

D5950 Test Method for Pour Point of Petroleum Products (Automatic Tilt Method)

2.2 *National Fire Protection Association Standards:*

*National Electrical Code, Article 450-23*<sup>4</sup>

2.3 *Institute of Electrical and Electronics Engineers Standard:*

C57.121 Guide for Acceptance and Maintenance of Less-Flammable Hydrocarbon Fluids and its Maintenance Fluid in Transformers<sup>5</sup>

### 3. Terminology

3.1 Definitions of terms related to this specification are given in Terminology D2864. Significance of tests related to this specification can be found in Guide D117 and Specification D3487.

### 4. Sampling and Testing

4.1 Take all oil samples in accordance with Test Methods-Practices D923.

4.2 Perform each test in accordance with the ASTM test method specified in Table 1.

NOTE 1—Because of the different needs of various users, items relating to packaging, labeling, and inspection are considered to be subject to buyer-seller-supplier-user agreement.

NOTE 2—In addition to all other tests listed herein, it is sound engineering practice for the apparatus manufacturer to perform an evaluation of insulating oils in insulation systems, prototype structures, or full-scale apparatus, or any combination thereof, to ensure suitable service life.

### 5. Property Requirements

5.1 High fire-point mineral insulating oil, as received, shall conform to the requirements of Table 1. The significance of these properties is covered in Guide D117.

### 6. Keywords

6.1 electrical insulating oil; fire point; flammability; insulating fluid; mineral insulating oil

<sup>4</sup> Available from the National Fire Protection Association, Batterymarch Park, Quincy, MA 02269.

<sup>5</sup> Available from the Institute of Electrical and Electronics Engineers, Inc. 345 E. 47th St., New York, NY 10017-2394 (IEEE), 445 Hoes Ln., Piscataway, NJ 08854-4141, <http://www.ieee.org>.