

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Live working – Voltage detectors –
Part 1: Capacitive type to be used for voltages exceeding 1 kV a.c.**

**Travaux sous tension – Détecteurs de tension –
Partie 1: Type capacitif pour usage sur des tensions alternatives de plus de 1 kV**

IEC 61243-1:2003

<https://standards.iteh.ai/standards/iec/6388c0c2-4e20-4893-a85f-9e3c4f3b4c86/iec-61243-1-2003>



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2009 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland
Email: inmail@iec.ch
Web: www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: www.iec.ch/searchpub

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: www.iec.ch/online_news/justpub

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: www.iec.ch/webstore/custserv

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: csc@iec.ch

Tel.: +41 22 919 02 11

Fax: +41 22 919 03 00

A propos de la CEI

La Commission Electrotechnique internationale (CEI) est la première organisation mondiale qui élabore et publie des normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

- Catalogue des publications de la CEI: www.iec.ch/searchpub/cur_fut-f.htm

Le Catalogue en-ligne de la CEI vous permet d'effectuer des recherches en utilisant différents critères (numéro de référence, texte, comité d'études,...). Il donne aussi des informations sur les projets et les publications retirées ou remplacées.

- Just Published CEI: www.iec.ch/online_news/justpub

Restez informé sur les nouvelles publications de la CEI. Just Published détaille deux fois par mois les nouvelles publications parues. Disponible en-ligne et aussi par email.

- Electropedia: www.electropedia.org

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International en ligne.

- Service Clients: www.iec.ch/webstore/custserv/custserv_entry-f.htm

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions, visitez le FAQ du Service clients ou contactez-nous:

Email: csc@iec.ch

Tél.: +41 22 919 02 11

Fax: +41 22 919 03 00

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Live working – Voltage detectors –
Part 1: Capacitive type to be used for voltages exceeding 1 kV a.c.**

**Travaux sous tension – Détecteurs de tension –
Partie 1: Type capacitif pour usage sur des tensions alternatives de plus de 1 kV**

IEC 61243-1:2003

<https://standards.iteh.ai/standards/iec/6386c0c2-4e20-4893-a85f-9e3c4f3b4c86/iec-61243-1-2003>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	7
2 Normative references.....	7
3 Terms and definitions.....	8
4 Requirements.....	12
4.1 General requirements.....	12
4.1.1 Safety.....	12
4.1.2 Indication.....	12
4.2 Functional requirements.....	12
4.2.1 Clear indication.....	12
4.2.2 Clear perceptibility.....	13
4.2.3 Temperature and humidity dependence of the indication.....	14
4.2.4 Frequency dependence.....	14
4.2.5 Response time.....	14
4.2.6 Power source dependability.....	14
4.2.7 Testing element.....	14
4.2.8 Non-response to d.c. voltage.....	15
4.2.9 Time rating.....	15
4.3 Electrical requirements.....	15
4.3.1 Insulating material.....	15
4.3.2 Protection against bridging.....	15
4.3.3 Resistance against sparking.....	15
4.4 Mechanical requirements.....	15
4.4.1 Design.....	15
4.4.2 Dimensions, construction.....	16
4.4.3 Grip force and deflection.....	17
4.4.4 Vibration resistance.....	17
4.4.5 Drop resistance.....	17
4.4.6 Shock resistance.....	17
4.5 Markings.....	17
4.6 Instructions for use.....	18
5 Specific requirements.....	18
5.1 For insulating element of a voltage detector as a complete device.....	18
5.1.1 Dielectric strength.....	18
5.1.2 Leakage current.....	18
5.2 For indicator casing of voltage detector as a separate device.....	18
6 Tests.....	18
6.1 General.....	18
6.1.1 Tests under wet conditions.....	19
6.1.2 Type test.....	19
6.1.3 Test methods.....	20

6.2	Function tests.....	20
6.2.1	Clear indication	20
6.2.2	Clear perceptibility of visual indication.....	23
6.2.3	Clear perceptibility of audible indication.....	24
6.2.4	Frequency dependence	25
6.2.5	Response time	26
6.2.6	Power source dependability.....	26
6.2.7	Check of testing element	26
6.2.8	Non-response to d.c. voltage	27
6.2.9	Time rating	27
6.3	Dielectric tests	27
6.3.1	Protection against bridging for indoor/outdoor type voltage detector	27
6.3.2	Protection against bridging for outdoor type voltage detector.....	29
6.3.3	Spark resistance.....	30
6.4	Mechanical tests	31
6.4.1	Visual and dimensional inspection	31
6.4.2	Grip force and deflection (only applicable for voltage detector as a complete device).....	31
6.4.3	Vibration resistance.....	32
6.4.4	Drop resistance	32
6.4.5	Shock resistance	32
6.4.6	Climatic dependence	33
6.4.7	Durability of markings.....	33
7	Specific tests.....	34
7.1	Leakage current for voltage detector as a complete device.....	34
7.1.1	Leakage current under dry conditions	34
7.1.2	Leakage current under wet conditions (for outdoor type only)	34
8	Conformity assessment of voltage detectors having completed the production phase.....	35
Annex A (normative)	Suitable for live working; double triangle	51
Annex B (normative)	Instructions for use	52
Annex C (normative)	Chronology of type tests	53
Annex D (normative)	Classification of defects and tests to be allocated	55
Annex E (normative)	Mechanical shock tests – Pendulum method	57
Annex F (Deleted)	59
Annex G (informative)	In-service care	60
Bibliography	62

INTERNATIONAL ELECTROTECHNICAL COMMISSION

LIVE WORKING – VOLTAGE DETECTORS –

Part 1: Capacitive type to be used for voltages
exceeding 1 kV a.c.

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61243-1 has been prepared by IEC technical committee 78: Live working.

This edition includes the following major technical changes from the previous edition:

- a) the Scope has been extended to cover the use on electrical systems for voltages up to 765 kV a.c.;
- b) the notion of family of voltage detectors which are identical in terms of design and dimensions and only differ by their nominal voltages (or nominal voltage ranges) has been included;
- c) the classification in terms of the setting of the threshold voltage to give a clear indication has been eliminated;
- d) a new test set-up with bars has been introduced. Depending on the nominal voltage of the voltage detector, it is required or becomes an alternative test set-up for checking the influence of interference fields, the influence of interference voltages, the protection against bridging and the spark resistance;

- e) the revision of specific dielectric tests has been included;
- f) some test procedures (clear perceptibility of audible indication, drop resistance, climatic dependence) have been improved and completed.

This consolidated version of IEC 61243-1 consists of the second edition (2003) [documents 78/527/FDIS and 78/537/RVD], its amendment 1 (2009) [documents 78/751/CDV and 78/794/RVC] and its corrigendum of October 2005.

The technical content is therefore identical to the base edition and its amendment and has been prepared for user convenience.

It bears the edition number 2.1.

A vertical line in the margin shows where the base publication has been modified by amendment 1.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

IEC 61243 consists of the following parts, under the general title *Live working – Voltage detectors*:

Part 1: Capacitive type to be used for voltages exceeding 1 kV a.c.

Part 2: Resistive type to be used for voltages of 1 kV to 36 kV a.c.

Part 3: Two-pole low-voltage type

Part 5: Voltage detecting systems (VDS)

The committee has decided that the contents of the base publication and its amendments will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

[IEC 61243-1:2003](https://www.iec.ch/iec/61243-1-2003)

<https://www.iec.ch/iec/61243-1-2003>

INTRODUCTION

This International Standard has been prepared according to the requirements of IEC 61477, where applicable.

Withdrawing

iTech Standards
(<https://standards.itih.ai>)
Document Preview

<https://standards.itih.ai/standards/iec/61243-1:2003>

<https://standards.itih.ai/standards/iec/e386c0c2-4e20-4893-a85f-9e3c4f3b4c86/iec-61243-1-2003>

LIVE WORKING – VOLTAGE DETECTORS –

Part 1: Capacitive type to be used for voltages exceeding 1 kV a.c.

1 Scope

This part of IEC 61243 is applicable to portable voltage detectors, with or without built-in power sources, to be used on electrical systems for voltages of 1 kV to 765 kV a.c., and frequencies of 50 Hz and/or 60 Hz.

This part applies only to voltage detectors of capacitive type used in contact with the part to be tested, as a complete device including its insulating element or as a separate device, adaptable to an insulating stick which, as a separate tool, is not covered by this standard (see 4.4.1 for general design).

Other types of voltage detectors are not covered by this part of the standard.

Some restrictions on their use are applicable in the case of factory-assembled switchgear and on overhead systems of electrified railways (see Annex B, instructions for use).

NOTE Except where otherwise specified, all the voltages defined in this standard refer to values of phase-to-phase voltages of three-phase systems. In other systems, the applicable phase-to-phase or phase-to-earth (ground) voltages should be used to determine the operating voltage.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60060-1:1989, *High-voltage test techniques – Part 1: General definitions and test requirements*

IEC 60068-1, *Environmental testing -Part 1: General and guidance*

IEC 60068-2-6:1995, *Environmental testing – Tests – Test Fc and guidance: Vibration (sinusoidal)*

IEC 60068-2-14:1984, *Environmental testing – Tests – Test N: Change of temperature*
Amendment 1 (1986)

IEC 60068-2-32:1975, *Environmental testing – Tests – Test Ed: Free fall*
Amendment 2 (1990)

IEC 60071-1:2006, *Insulation co-ordination – Part 1: Definitions, principles and rules*

IEC 60417-DB:2002¹, *Graphical symbols for use on equipment*

IEC 60942, *Electroacoustics – Sound calibrators*

IEC 61260:1995, *Electroacoustics – Octave-band and fractional-octave-band filters*

¹ "DB" refers to the IEC on-line database.

IEC 61318:2007, *Live working – Conformity assessment applicable to tools, devices and equipment*

IEC 61477:2001, *Live working – Minimum requirements for the utilization of tools, devices and equipment*

Amendment 1 (2002)²

IEC 61672-1:2002, *Electroacoustics – Sound level meters – Part 1: Specifications*

ISO 286-1:1988, *ISO system of limits and fits – Part 1: Bases of tolerances, deviations and fits*

ISO 286-2:1988, *ISO system of limits and fits – Part 2: Tables of standard tolerance grades and limit deviations for holes and shafts*

ISO 3744:1994, *Acoustics – Determination of sound power levels of noise sources using sound pressure – Engineering method in an essentially free field over a reflecting plane*

CIE (International Commission on Illumination) 15.2:1986, *Colorimetry*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 61318:2007 and the following apply.

3.1

voltage detector

device used to provide clear evidence of the presence or the absence of the operating voltage

NOTE For example, voltage detectors can be described as capacitive type or resistive type.

[Definition 11.2.5 of IEC 60743, modified, and IEC 651-10-04, modified]

3.2

voltage detector of capacitive type

device whose operation is based on the current passing through the stray capacitance to earth (ground)

NOTE The term voltage detector is used in this document for voltage detector of capacitive type.

3.3

designs of voltage detectors

different constructions of voltage detectors, either as a complete device with or without contact electrode extension, or as a separate device intended to be equipped with an insulating stick, with or without contact electrode extension

NOTE Some parts such as the contact electrode, the contact electrode extension (if existing), or the insulating element of a voltage detector as a complete device may be dismantled.

3.4

family of voltage detectors

for testing purposes, a group of voltage detectors, delimited by a minimum and a maximum rated voltage, that are identical in design (including dimensions) and only differ by their nominal voltages or nominal voltage ranges

² There exists a consolidated edition 1.1 (2002) that includes edition 1 and its amendment.

3.5**contact electrode**

bare conductive part of the conductive element which establishes the electric connection to the component to be tested

[IEV 651-10-09]

3.6**contact electrode extension**

externally insulated conductive element between the indicator and the contact electrode, intended to achieve the correct position of the indicator relative to the installation being tested

3.7**indicator**

part of the voltage detector which indicates the presence or absence of the operating voltage at the contact electrode

[IEV 651-10-08, modified]

3.8**adaptor**

part of a voltage detector as a separate device which permits attachment of an insulating stick

3.9**insulating element**

part of a voltage detector as a complete device that provides adequate safety distance and insulation to the user

3.10**insulating stick**

insulating tool essentially made of an insulating tube and/or rod with end fittings

[Definition 2.5.1 of IEC 60743 and IEV 651-02-01]

NOTE For voltage detection, an insulating stick is intended to be attached to a voltage detector as a separate device in order to provide the length to reach the installation to be tested and adequate safety distance and insulation to the user.

3.11**limit mark**

distinctive location or mark to indicate to the user the physical limit to which the voltage detector may be inserted between live parts or may touch them

3.12**hand guard**

distinctive physical guard separating the handle from the insulating element

NOTE Its purpose is to prevent the hands from slipping and passing into contact with the insulating element.

3.13**testing element**

built-in or external device, by means of which the functioning of the voltage detector can be checked by the user

[IEV 651-10-11, modified]

3.14**accessories**

items used to lengthen the handle or the contact electrode, to improve the efficiency of the contact electrode or to enable the contact electrode to reach the part to be tested

3.15 nominal voltage

 U_n

suitable approximate value of voltage used to identify a system or device

[IEV 601-01-21, modified]

NOTE The nominal voltage of the voltage detector is the parameter associated with its clear indication. A voltage detector may have more than one nominal voltage, or a nominal voltage range. Limit values of the nominal voltage range are named U_n min and U_n max.

3.16 operating voltage (in a system)

value of the voltage under normal conditions, at a given instant and a given point of the system

NOTE This value may be expected, estimated or measured.

[IEV 601-01-22]

3.17 threshold voltage

 U_t

minimum voltage between the live part and earth (ground) required to give a clear indication corresponding to specific conditions as defined in the corresponding test

NOTE As defined in this part of IEC 61243, threshold voltage is related to specific test conditions. Users should be aware that their requirements for threshold voltage for field operation need to be related to the test conditions in the standard.

3.18 rated voltage

 U_r

value of voltage generally agreed upon by manufacturer and customer, to which certain operating specifications are referred. The rated voltage of the voltage detector is the voltage selected from IEC 60071-1, Tables 2 and 3, column 1, which should either be equal to the nominal voltage (or the highest nominal voltage of its nominal voltage range), or the next higher voltage selected from those tables

3.19 interference voltage

voltage picked up inductively or capacitively by the part to be tested

3.20 interference field

superposed electric field which may affect the indication. It may result from the part to be tested or other adjacent parts, and may have any phase relationship

NOTE The extreme cases for the tests are:

- an in-phase interference field exists when a small change of potential in the direction of the voltage detector axis results in an incorrect indication. This occurs as a result of the dimensions and/or configuration of the part of installation to be tested (or of adjacent parts of the installation having voltages in the same phase);
- an interference field in phase opposition exists when a strong change of potential in the direction of the voltage detector axis results in an incorrect indication. This occurs as a result of the adjacent parts of the installation having voltages in phase opposition.

3.21**active signal**

audible or visual phenomenon whose presence, absence or variation is considered as representing information on the condition “voltage present” or “voltage not present”

[IEV 101-12-02, modified]

NOTE A signal indicating that the voltage detector is ready to operate is not considered an active signal.

3.22**clear indication**

unambiguous detection and indication of the voltage state at the contact electrode

[IEV 651-10-10]

3.23**clear perceptibility**

case where the indication is unmistakably discernible by the user under specific environmental conditions when the voltage detector is in its operating position

3.24**response time**

time delay between sudden change of the voltage state on the contact electrode and the associated clear indication

3.25**protection against bridging**

protection against flashover or breakdown, when the insulation between the parts of installation to be tested, at different potentials, is reduced by the presence of the voltage detector

3.26**stand-by state**

state at which the voltage detector is ready to work without manual switching on

3.27**indoor type**

voltage detector designed for use in dry conditions, normally indoors

3.28**outdoor type**

voltage detector designed for use in wet conditions, either indoors or outdoors

3.33**maintenance test**

test carried out periodically on a device or equipment to ascertain and, if necessary, make certain adjustments to ensure that its performance remains within specified limits

[IEV 151-16-25 modified]

4 Requirements

4.1 General requirements

4.1.1 Safety

The voltage detector shall be designed and manufactured to be safe for the user, provided it is used in accordance with safe methods of work, and the instructions for use.

4.1.2 Indication

The voltage detector shall give a clear indication of the state "voltage present" and/or "voltage not present", by means of the change of the status of the signal. The indication shall be visual and/or audible.

4.2 Functional requirements

4.2.1 Clear indication

The voltage detector shall give an unambiguous indication of the presence and/or the absence of the system operating voltage as a function of the nominal voltage or nominal voltage range of the voltage detector, and its nominal frequency or nominal frequencies.

Indication may not be reliable in the vicinity of large conductive parts that create equipotential zones.

When the voltage detector is used in accordance with instructions for use, the presence of an adjacent live or earthed part shall not affect its indication.

When used in accordance with instructions for use, the voltage detector shall not indicate "voltage present" for usual values of interference voltages.

4.2.1.1 Continuous indication

The voltage detector shall give continuous indication when in direct contact with a live part.

4.2.1.2 Threshold voltage

4.2.1.2.1 General

The user shall not have access to the threshold voltage setting.

The indication "voltage present" shall appear if the voltage to earth on the part to be tested is greater than 45 % of the nominal voltage.

NOTE 1 45 % of the nominal voltage corresponds to $0,78 U_n / \sqrt{3}$.

The indication "voltage present" shall not appear if the voltage to earth on the part to be tested is equal to or less than 10 % of the nominal voltage.

NOTE 2 10 % of the nominal voltage corresponds to $0,17 U_n / \sqrt{3}$ and is the maximum phase to earth induced voltage normally encountered in the field.

To fulfil the above requirements, the threshold voltage U_t shall satisfy the following relationship:

$$0,10 U_n \max < U_t \leq 0,45 U_n \min$$