



SLOVENSKI STANDARD SIST EN ISO 5136:2004

01-januar-2004

BUXca Yý U
SIST EN 25136:1997

5_i gh_U!`8c`c Ub^nj c bY'a c jž_]'c`j`_UbU`gYj U`c`j Ybh`Urcf`]b`Xfi []'ghfc`]nU
kfUbgdcfhinfU_U!'`AYrcXUnUa Yf^b^j`_UbUi`f`GC`) % * .&\$\$' Ł

Acoustics - Determination of sound power radiated into a duct by fans and other air-moving devices - In-duct method (ISO 5136:2003)

Akustik - Bestimmung der von Ventilatoren und anderen Strömungsmaschinen in Kanäle abgestrahlten Schalleistung - Kanalverfahren (ISO 5136:2003); Deutsche Fassung EN ISO 5136:2003

[SIST EN ISO 5136:2004](#)

Acoustique - Détermination de la puissance acoustique rayonnée dans un conduit par des ventilateurs et d'autres systèmes de ventilation - Méthode en conduit (ISO 5136:2003)

Ta slovenski standard je istoveten z: EN ISO 5136:2003

ICS:

17.140.20	Emisija hrupa naprav in opreme	Noise emitted by machines and equipment
23.120	Zlæ} ä äX^d} ä äS ä æ\^ } ä æ^	Ventilators. Fans. Air-conditioners

SIST EN ISO 5136:2004 en

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN ISO 5136:2004

<https://standards.iteh.ai/catalog/standards/sist/1faebf50-426e-4a94-b14e-f3688c5d7a68/sist-en-iso-5136-2004>

English version

Acoustics - Determination of sound power radiated into a duct
by fans and other air-moving devices - In-duct method (ISO
5136:2003)

Acoustique - Détermination de la puissance acoustique
rayonnée dans un conduit par des ventilateurs et d'autres
systèmes de ventilation - Méthode en conduit (ISO
5136:2003)

Akustik - Bestimmung der von Ventilatoren und anderen
Strömungsmaschinen in Kanäle abgestrahlten
Schalleistung - Kanalverfahren (ISO 5136:2003)

This European Standard was approved by CEN on 11 March 2003.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Luxembourg, Malta, Netherlands, Norway, Portugal, Slovakia, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: rue de Stassart, 36 B-1050 Brussels

CORRECTED 2003-07-16

Foreword

This document (EN ISO 5136:2003) has been prepared by Technical Committee ISO/TC 43 "Acoustics" in collaboration with Technical Committee CEN/TC 211 "Acoustics", the secretariat of which is held by DS.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by October 2003, and conflicting national standards shall be withdrawn at the latest by October 2003.

This document supersedes EN 25136:1993.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive(s).

For relationship with EU Directive(s), see informative Annex ZB, which is an integral part of this document.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Luxembourg, Malta, Netherlands, Norway, Portugal, Slovakia, Spain, Sweden, Switzerland and the United Kingdom.

[SIST EN ISO 5136:2004](https://standards.iteh.ai/catalog/standards/sist/1faebf50-426e-4a94-b14e-f3688c5d7a68/sist-en-iso-5136-2004)

<https://standards.iteh.ai/catalog/standards/sist/1faebf50-426e-4a94-b14e-f3688c5d7a68/sist-en-iso-5136-2004>

Endorsement notice

The text of ISO 5136:2003 has been approved by CEN as EN ISO 5136:2003 without any modifications.

NOTE Normative references to International Standards are listed in Annex ZA (normative).

Annex ZA (normative)

Normative references to international publications with their relevant European publications

This European Standard incorporates by dated or undated reference, provisions from other publications. These normative references are cited at the appropriate places in the text and the publications are listed hereafter. For dated references, subsequent amendments to or revisions of any of these publications apply to this European Standard only when incorporated in it by amendment or revision. For undated references the latest edition of the publication referred to applies (including amendments).

NOTE Where an International Publication has been modified by common modifications, indicated by (mod.), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN</u>	<u>Year</u>
ISO 266	1997	Acoustics - Preferred frequencies	EN ISO 266	1997

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN ISO 5136:2004](https://standards.iteh.ai/catalog/standards/sist/1faebf50-426e-4a94-b14e-f3688c5d7a68/sist-en-iso-5136-2004)

<https://standards.iteh.ai/catalog/standards/sist/1faebf50-426e-4a94-b14e-f3688c5d7a68/sist-en-iso-5136-2004>

Annex ZB
(informative)

Clauses of this European Standard addressing essential requirements or other provisions of EU Directives

This European Standard has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of the Directive 98/79/EC.

WARNING Other requirements and other EU Directives may be applicable to the product(s) falling within the scope of this standard.

The following clauses of this standard, as detailed in Table ZA.1, are likely to support requirements of the EU Directive 98/79/EC.

Compliance with these clauses of this standard provides one means of conforming with the specific essential requirements of the Directive concerned and associated EFTA regulations.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN ISO 5136:2004](https://standards.iteh.ai/catalog/standards/sist/1faebf50-426e-4a94-b14e-f3688c5d7a68/sist-en-iso-5136-2004)

<https://standards.iteh.ai/catalog/standards/sist/1faebf50-426e-4a94-b14e-f3688c5d7a68/sist-en-iso-5136-2004>

**Acoustics — Determination of sound
power radiated into a duct by fans and
other air-moving devices — In-duct
method**

*Acoustique — Détermination de la puissance acoustique rayonnée
dans un conduit par des ventilateurs et d'autres systèmes de
ventilation — Méthode en conduit*

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN ISO 5136:2004](https://standards.iteh.ai/catalog/standards/sist/1faebf50-426e-4a94-b14e-f3688c5d7a68/sist-en-iso-5136-2004)

[https://standards.iteh.ai/catalog/standards/sist/1faebf50-426e-4a94-b14e-
f3688c5d7a68/sist-en-iso-5136-2004](https://standards.iteh.ai/catalog/standards/sist/1faebf50-426e-4a94-b14e-f3688c5d7a68/sist-en-iso-5136-2004)



Reference number
ISO 5136:2003(E)

© ISO 2003

PDF disclaimer

This PDF file may contain embedded typefaces. In accordance with Adobe's licensing policy, this file may be printed or viewed but shall not be edited unless the typefaces which are embedded are licensed to and installed on the computer performing the editing. In downloading this file, parties accept therein the responsibility of not infringing Adobe's licensing policy. The ISO Central Secretariat accepts no liability in this area.

Adobe is a trademark of Adobe Systems Incorporated.

Details of the software products used to create this PDF file can be found in the General Info relative to the file; the PDF-creation parameters were optimized for printing. Every care has been taken to ensure that the file is suitable for use by ISO member bodies. In the unlikely event that a problem relating to it is found, please inform the Central Secretariat at the address given below.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN ISO 5136:2004](https://standards.iteh.ai/catalog/standards/sist/1faebf50-426e-4a94-b14e-f3688c5d7a68/sist-en-iso-5136-2004)

<https://standards.iteh.ai/catalog/standards/sist/1faebf50-426e-4a94-b14e-f3688c5d7a68/sist-en-iso-5136-2004>

© ISO 2003

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Case postale 56 • CH-1211 Geneva 20
Tel. + 41 22 749 01 11
Fax + 41 22 749 09 47
E-mail copyright@iso.org
Web www.iso.org

Published in Switzerland

Contents

Page

Foreword	iv
Introduction	v
1 Scope	1
1.1 General	1
1.2 Types of sound source	1
2 Normative references	2
3 Terms, definitions and symbols	2
4 Uncertainty of the measurement method	7
5 Test facilities and instrumentation	8
5.1 General requirements	8
5.2 Duct specifications	9
5.3 Instrumentation	16
5.4 System calibration	19
6 Test arrangement	20
6.1 Sampling tube mounting	20
6.2 Microphone position	20
6.3 Operating condition control equipment	21
7 Test procedure	21
7.1 Operating conditions	21
7.2 Sound pressure level readings	21
7.3 Measurements with and without flow straightener on the outlet side	22
7.4 Inlet side measurements — Large fans: installation category D (according to ISO 5801:1997)	22
8 Calculations	23
8.1 Average sound pressure level	23
8.2 Sound power level	23
9 Information to be recorded	24
10 Information to be reported	24
Annex A (normative) Determination of the combined mean flow velocity and modal correction $C_{3,4}$	25
Annex B (normative) Determination of the signal-to-noise ratio of sound vs. turbulent pressure fluctuation in the test duct	31
Annex C (normative) Computational procedures for calculating the A-weighted sound power level from one-third-octave-band sound power levels	34
Annex D (informative) Example of calculation of $C_{3,4}$ for a given duct diameter and mean flow velocity	35
Annex E (informative) Guidelines for the design and construction of an anechoic termination	38
Annex F (informative) Evaluation of performance of anechoic terminations	47
Annex G (informative) Sampling tube information	50
Annex H (informative) Test method for small ducted fans	54
Annex I (informative) Test method for large ducted fans	58
Annex J (informative) Measurement of the swirl component	65
Bibliography	66

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 5136 was prepared by Technical Committee ISO/TC 43, *Acoustics*, Subcommittee SC 1, *Noise*.

This second edition cancels and replaces the first edition (ISO 5136:1990), which has been technically revised.

iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST EN ISO 5136:2004](https://standards.iteh.ai/catalog/standards/sist/1faebf50-426e-4a94-b14e-f3688c5d7a68/sist-en-iso-5136-2004)

<https://standards.iteh.ai/catalog/standards/sist/1faebf50-426e-4a94-b14e-f3688c5d7a68/sist-en-iso-5136-2004>

Introduction

This International Standard describes a procedure for the measurement of sound pressure levels in the inlet or outlet ducts of a fan and a method to use these sound pressure levels to calculate the sound power levels radiated by the fan to the duct system.

Annex A lists values of coefficients for the determination of the combined mean flow velocity and modal correction. Annex B specifies two procedures for the determination of the signal-to-noise ratio of sound versus turbulence. A computational procedure for the calculation of the A-weighted sound power level from one-third-octave band levels is given in Annex C. Annex D shows an example of the calculation of the combined mean flow velocity and modal correction.

The sound power radiated into a duct by a fan or other air-moving device depends to some extent on the type of duct, characterized by its acoustical impedance. For a measurement method, the test duct has, therefore, to be clearly specified. In this International Standard, the test duct is of circular cross-section and terminated anechoically. Details of typical anechoic terminations are given in Annex E. The sound power obtained under these special conditions is a representative value for actual applications, as the anechoic termination forms an impedance about midway between the higher and lower impedances found in practice. The sound power radiated in actual applications can, in theory, be estimated from data on air-moving devices and duct impedances. Since this information is at present incomplete, these effects are not usually considered in acoustical calculations.

In order to suppress the turbulent pressure fluctuations at the microphone, the use of a long cylindrical windscreen ("sampling tube") is preferred. The microphone, with the sampling tube, is mounted at a radial position such that the sound pressure is well related to the sound power by the plane wave formula to an acceptable extent, even in the frequency range in which higher-order acoustic modes are possible.

The uncertainty of measurement (see Clause 4) is given in terms of the standard deviation to be expected if the measurements were repeated in many different laboratories.

The procedures for measuring the operating conditions (performance measurements) are not specified in detail in this International Standard. The operating conditions are specified in ISO 5801.

This International Standard is one of a series specifying different methods for determining the sound power levels of fans and other air-moving devices.

In general, the sound powers radiated from a fan inlet or outlet into free space and into a duct are different because of the reflection of sound energy at the fan inlet or outlet plane when there is no connected duct. The in-duct method according to this International Standard is suitable for determining the sound power radiated into a duct by a fan inlet or outlet. The sound power radiated into free space by a fan inlet or outlet should be determined using the a reverberation room method (ISO 3741, ISO 3743), a free-field method (ISO 3744, ISO 3745, ISO 3746) or a sound intensity method (ISO 9614).

<https://standards.iteh.ai/catalog/standards/sist/1faeb50-426e-4a94-b14e-f3688c5d7a68/sist-en-iso-5136-2004>

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN ISO 5136:2004

<https://standards.iteh.ai/catalog/standards/sist/1faebf50-426e-4a94-b14e-f3688c5d7a68/sist-en-iso-5136-2004>

Acoustics — Determination of sound power radiated into a duct by fans and other air-moving devices — In-duct method

1 Scope

1.1 General

This International Standard specifies a method for testing ducted fans and other air-moving devices to determine the sound power radiated into an anechoically terminated duct on the inlet and/or outlet side of the equipment.

NOTE 1 For the sake of brevity, wherever the term “fan” occurs in the text, it means “fan or other air-moving device”.

The method is applicable to fans which emit steady, broad-band, narrow-band and discrete-frequency sound and to air temperatures between -50 °C and $+70\text{ °C}$. The test duct diameter range is from 0,15 m to 2 m. Test methods for small ($d < 0,15\text{ m}$) and large ($d > 2\text{ m}$) test ducts are described in the informative Annexes H and I, respectively.

The maximum mean flow velocity at the microphone head for which the method is suitable depends on the type of microphone shield used, and is as follows:

- foam ball 15 m/s;
- nose cone 20 m/s;
- sampling tube 40 m/s.

Above these values the suppression of turbulent pressure fluctuations by the microphone shield (see 3.9) may be insufficient.

It is expected that sound power tests will be conducted in conjunction with airflow performance tests in accordance with ISO 5801. The ducting arrangement will therefore normally incorporate a “star” type flow straightener on the outlet side of the fan which will minimize swirl (see 7.3). Where it is permissible to delete the straightener as, for example, with large fans to installation category C according to ISO 5801:1997, the method is limited to a swirl angle of 15° . (An example of a method for determining the angle of swirl is given in Annex J.)

NOTE 2 The installation categories defined in ISO 5801 imply that the fan is either ducted on the outlet side only (category B), on the inlet side only (category C) or on both sides (category D).

1.2 Types of sound source

The method described in this International Standard is applicable to a sound source in which a fan is connected to ducts on at least one side. It is also applicable to other fan/attenuator combinations or equipment incorporating fans which can be considered as “black boxes”.

Examples of fans and other equipment covered by this International Standard are

- ducted centrifugal fans,
- ducted axial flow fans,

- ducted mixed-flow fans,
- ducted air-handling units,
- ducted dust-collection units,
- ducted air-conditioning units, and
- ducted furnaces.

This International Standard is also applicable to other aerodynamic sources such as boxes, dampers and throttle devices provided that a quiet air flow delivered by an auxiliary fan is available, and the signal-to-noise ratio of sound pressures to turbulent pressure fluctuations in the test duct is at least 6 dB (see 7.2.1).

An alternative method to determine the sound power level of the flow-generated noise of such aerodynamic sound sources, which does not require the measurement of sound pressure in a flow environment, is described in ISO 7235. The method was originally devised for the determination of the flow noise level of ducted silencers. The sound power is determined in a reverberation room connected to the test duct via a transition element.

In the case of ducted fans with closely coupled attenuators, the signal-to-noise ratio of sound pressures to turbulent pressures may be insufficient when using the in-duct method. Therefore the method described in ISO 7235 is recommended for such fan/attenuator combinations.

This International Standard is not applicable to non-ducted fans or equipment.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 266, *Acoustics — Preferred frequencies*

ISO 5801:1997, *Industrial fans — Performance testing using standardized airways*

IEC 60651:2001, *Sound level meters*

IEC 60942:1997, *Electroacoustics — Sound calibrators*

IEC 61260, *Electroacoustics — Octave-band and fractional-octave-band filters*

iTech STANDARD PREVIEW
(standards.iteh.ai)

3 Terms, definitions and symbols

SIST EN ISO 5136:2004

For the purpose of this document, the following terms and definitions apply. The symbols are given in Table 1.

3.1

fan inlet area

S_{f1}

surface plane bounded by the upstream extremity of the fan

NOTE 1 The inlet area is, by convention, taken as the gross area in the inlet plane inside the casing. No deduction is made for motors, fairings or other obstructions.

NOTE 2 Where motors, fairings or other obstructions extend beyond an inlet or outlet flange at which the performance for ducted installation is to be determined, the casing should be extended by a duct of the same size and shape as the inlet or outlet and of sufficient length to cover the obstruction. The test airway dimensions should be measured from the plane through the outermost extension of the obstruction as if this were the plane of the inlet or outlet flange.

NOTE 3 The fan inlet area is expressed in square metres (m²).

NOTE 4 Adapted from ISO 5801:1997.

3.2

fan outlet area

S_{f2}

surface plane bounded by the downstream extremity of the fan

NOTE 1 The outlet area is, by convention, taken as the gross area in the outlet plane inside the casing. No deduction is made for motors, fairings or other obstructions.

NOTE 2 Some free-outlet fans without casings have no well-defined outlet area. For the purpose of determining the fan's dynamic pressure, a nominal area may then be defined and stated, e.g. the area within the ring of a propeller wall fan or the circumferential outlet area of an open-running centrifugal impeller. The corresponding fan dynamic pressure and fan pressure will also be nominal and should be so described.

NOTE 3 The fan outlet area is expressed in square metres (m²).

NOTE 4 Adapted from ISO 5801:1997.

3.3

ducts

any of the airways defined in 3.3.1, 3.3.2 and 3.3.3

3.3.1

test duct

duct in which the fan sound power is measured

NOTE The test duct has an anechoic termination.

3.3.2

terminating duct

duct opposite to the test duct, if both sides of the fan are ducted

NOTE The terminating duct has an anechoic termination.

3.3.3

intermediate duct

duct fitted on the intake side and on the discharge side of the fan to ensure desired flow conditions

NOTE The intermediate duct connects to the test duct or the terminating duct, if necessary by a transition section (see Figure 7).

iTech STANDARD PREVIEW
(standards.iteh.ai)
SIST EN ISO 5136:2004
<https://standards.iteh.ai/catalog/standards/sist/1faeb50-426e-4a94-b14e-f3688c5d7a68/sist-en-iso-5136-2004>

3.4

measurement plane

radial plane in the test duct in which the microphone diaphragm is located

3.5

sound pressure level

L_p

$$L_p = 10 \lg \frac{p^2}{p_0^2} \text{ dB} \quad (1)$$