

Designation: A888 - 17

Standard Specification for Hubless Cast Iron Soil Pipe and Fittings for Sanitary and Storm Drain, Waste, and Vent Piping Applications¹

This standard is issued under the fixed designation A888; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ε) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This specification covers hubless cast iron soil pipe and fittings for use in gravity flow applications. It establishes standards covering material, manufacture, mechanical and chemical properties, dimensions, coating, test methods, inspection, certification, and product marking for hubless cast iron soil pipe and fittings. These pipe and fittings are intended for non-pressure applications, as the selection of the proper size for sanitary drain, waste, vent, and storm drain systems allows free air space for gravity drainage.

1.2 The EDP/ASA numbers indicated in this section represent a Uniform Industry Code adopted by the American Supply Association (ASA). A group designation prefix, 022, is assigned to hubless products, followed by the four-digit identification assigned to individual items and a check digit. This system has been instituted to facilitate EDP control through distribution channels, and is to be used universally in ordering and specifying product items. Those items with no EDP numbers are either new, special, or transitory and will be assigned numbers on subsequent prints of this specification.

1.3 This specification covers pipe and fittings of the following patterns and applies to any other patterns that conform with the applicable requirements given in this specification.²

1.3.1 Lengths:

EDP/ASA Identification Numbers Fig. 1
for Hubless Pipe
10 ft (3.0 m) in sizes and 5 ft. (1.5 m) Fig. 1, Fig. 2
1½, 2, 3, 4, 5, 6, 8,
10, 12, and 15 in.
Method of Specifying Fittings Fig. 3
1.3.2 Fittings:

	uarrer Bend	Fig. 5
	uarter Bend, Reducing	Fig. 6
	uarter Bend, with Side Opening	Fig. 7
	uarter Bend, with Heel Opening	Fig. 8
	uarter Bend, Tapped	Fig. 9
	uarter Bend, Double	Fig. 10
Q	uarter Bend, Long	Fig. 1
S	hort Sweep	Fig. 12
L	ong Sweep	Fig. 13
	ong Sweep, Reducing	Fig. 14
Fi	fth Bend	Fig. 15
S	ixth Bend	Fig. 16
Ε	ighth Bend	Fig. 17
Ε	ighth Bend, Long	Fig. 18
S	ixteenth Bend	Fig. 19
S	anitary Tee	Fig. 20
	anitary Tee with Side Opening	Fig. 2
S	anitary Tee with 2 in. Side Opening R or L/R and L	Fig. 22
S	anitary Tee, New Orleans Special with Side Opening	Fig. 23
S	anitary Tee with 45° Side Openings and New Orleans	Fig. 24
S	anitary Special Tee Tapped	Fig. 28
S	anitary Tapped Tee, Horizontal Twin	Fig. 20
S	anitary Tapped Tee, Double Vertical	Fig. 27
Υ	Branch	Fig. 28
Υ	Branch, Double	Fig. 29
Υ	Branch, Upright	Fig. 30
U	pright Y Wide Center Florida Special	Fig. 3
Y	Branch, Combination 1/8 Bend	Fig. 32
Y	Branch, Combination 1/8 Bend Double 1/4e/astm-a888-11	Fig. 33
S	anitary Cross	Fig. 34
	anitary Cross with Side Opening	Fig. 3
S	anitary Cross, New Orleans, with Side Openings	Fig. 36
	anitary Cross, New Orleans, with 45° Special and	Fig. 3
	Regular Side Openings	Ü
S	anitary Cross, Tapped	Fig. 38
	est Tee	Fig. 39
Ta	apped Extension Piece	Fig. 40
In	creaser-Reducer	Fig. 4
	creaser-Reducer, Short	Fig. 42
_	apped Adapter	Fig. 43
	lind Plug	Fig. 44
	on Body Cleanout, Tapped	Fig. 4
	Trap	Fig. 46
	Trap, Long	Fig. 47
	Trap, Deep Seal	Fig. 48
	Trap, with Primer	Fig. 49
	Trap, with Tapped Inlet	Fig. 50
	apped Inlet, Double	Fig. 5
	odified Combination Wye and 1/8 Bend, Double	Fig. 52
	odified Combination Wye and 1/8 Bend, Double,	Fig. 50
	xtended	.g. 0
	wo-Way Cleanout	Fig. 54
	win Cleanout	Fig. 5
	loset Bend, Regular and Reducing	Fig. 56
	loset Flange Riser	Fig. 5
_		9. 0

¹ This specification is under the jurisdiction of ASTM Committee A04 on Iron Castings and is under the direct responsibility of Subcommittee A04.12 on Pipes and Tubes.

Current edition approved June 1, 2017. Published October 2017. Originally approved in 1990. Last previous edition approved in 2015 as A888 – 15. DOI: 10.1520/A0888-17.

² Reprinted with permission from Cast Iron Soil Pipe Institute (CISPI), 2401 Fieldcrest Dr., Mundelein, IL 60060, http://www.cispi.org. Available from American National Standards Institute (ANSI), 25 W. 43rd St., 4th Floor, New York, NY 10036, http://www.ansi.org.



Tapping Bosses Double Sweep Sanitary Tee (Extended) Running Trap with Double Vents	Fig. 58 Fig. 59 Fig. 60
P Trap with Tapped or Hubless Side Inlet Vented Tub Wye Extended, Double	Fig. 61 Fig. 62
Vented Tub Wye Extended Offset, Left or Right Vented Tub Wye Pouble Two Way Cleanout	Fig. 63 Fig. 64 Fig. 65
Double Two-Way Cleanout	Fig. 65

- 1.4 The values stated in inch-pound units are to be regarded as standard. The values given in parentheses are mathematical conversions to SI units that are provided for information only and are not considered standard.
- 1.5 The committee with jurisdiction over this standard is aware of another comparable standard published by the Cast Iron Soil Pipe Institute, CISPI 301.

Note 1—The text of this standard references notes and footnotes that provide explanatory material. These notes and footnotes (excluding those in tables and figures) shall not be considered as requirements of the standard.

1.6 This international standard was developed in accordance with internationally recognized principles on standardization established in the Decision on Principles for the Development of International Standards, Guides and Recommendations issued by the World Trade Organization Technical Barriers to Trade (TBT) Committee.

2. Referenced Documents

2.1 ASTM Standards:³

A48/A48M Specification for Gray Iron Castings

A644 Terminology Relating to Iron Castings

D1248 Specification for Polyethylene Plastics Extrusion Materials for Wire and Cable

D3960 Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings (TMA)

E8/E8M Test Methods for Tension Testing of Metallic Materials

E1645 Practice for Preparation of Dried Paint Samples by Hotplate or Microwave Digestion for Subsequent Lead Analysis

E2349 Practice for Safety Requirements in Metal Casting Operations: Sand Preparation, Molding, and Core Making; Melting and Pouring; and Cleaning and Finishing

2.2 Federal Standard:⁴

Fed. Std. No. 123 Marking for Shipment (Civil Agencies)

2.3 Military Standard:⁴

MIL-STD-129 Military Marking for Shipment and Storage

2.4 ANSI/ASME Standard:⁵

B1.20 Pipe Threads

2.5 Other Documents:

Uniform Freight Classification Rules⁶

National Motor Freight Classification Rules⁷

Cast Iron Soil Pipe Institute (CISPI) Specification 301⁸

3. Terminology

3.1 Abbreviations:

3.1.1 AC—above center

3.1.2 ADAPTR—adapter

3.1.3 &—and

3.1.4 ASA—American Supply Association

3.1.5 ASSY—assembly

3.1.6 BD—bend

3.1.7 CARL—Carlson

3.1.8 *CF*—Carlson fitting

3.1.9 CLO—closet

3.1.10 *CO*—cleanout

3.1.11 COMB—combination

3.1.12 *CRS*—cross

3.1.13 *DB*—double

3.1.14 DBL—double

3.1.15 EDP—electronic data processing

3.1.16 EXT—extended, extension

3.1.17 *F*—figure

3.1.18 FER—ferrule

3.1.19 *FLNG*—flange

3.1.20 FTG—fitting

3.1.21 HI—high

3.1.22 HOR—horizontal

3.1.23 *INC*—increaser, increasing asim-a888-17

3.1.24 *L*—left hand

3.1.25 *L*/—less

3.1.26 *LG*—long

3.1.27 *LH*—left hand

3.1.28 *LNG*—long

3.1.29 /MAIN—on main

3.1.30 MN—on main

3.1.31 NO-New Orleans

3.1.32 *R*—right hand

3.1.33 RAD—radius

3.1.34 RED—reducer, reducing

3.1.35 REV—revent

3.1.36 RH—right hand

³ For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

⁴ Available from Standardization Documents Order Desk, DODSSP, Bldg. 4, Section D, 700 Robbins Ave., Philadelphia, PA 19111-5098, http://www.dodssp.daps.dla.mil.

⁵ Available from American National Standards Institute (ANSI), 25 W. 43rd St., 4th Floor, New York, NY 10036, http://www.ansi.org.

⁶ Available from the Uniform Classification Commission, Room 1106, 222 S. Riverside Plaza, Chicago, IL 60606.

⁷ Available from National Motor Freight Traffic Association, Inc. (NMFTA), 1001 N. Fairfax St., Suite 600, Alexandria, VA 22314-1798, http://www.nmfta.org.

⁸ Available from Cast Iron Soil Pipe Institute (CISPI), 2401 Fieldcrest Dr., Mundelein, IL 60060, http://www.cispi.org.



- 3.1.37 SAN—sanitary
- 3.1.38 SD—side
- 3.1.39 SL & NOTCH-slotted and notched
- 3.1.40 SO—side openings
- 3.1.41 ST—sanitary tap
- 3.1.42 *T*—tee
- 3.1.43 *TAP*—tap, tapped
- 3.1.44 *TOT*—tap on top
- 3.1.45 *TP*—tap, tapped
- 3.1.46 V—vent
- 3.1.47 VERT—vertical
- 3.1.48 W/-with
- 3.1.49 *Y*—wye
- 3.2 Definitions of Terms Specific to This Standard:
- 3.2.1 *manufacturer*—the entity that casts the pipe and fittings covered by this standard.

4. Materials and Manufacture

- 4.1 The pipe and fittings shall be iron castings suitable for installation and service for sanitary, storm drain, waste, and vent piping applications. The pipe and fittings shall meet all applicable requirements and tests given in this specification.
- 4.2 The castings shall be made of cast iron, produced by an established commercial method that provides control over chemical and mechanical properties. Cast iron is a generic term for a series of alloys as defined in Terminology A644 and includes gray iron as well as ductile iron. The castings shall be sound, true to pattern, and of compact close grain that permits drilling and cutting by ordinary methods. The interior surface shall be reasonably smooth and free from defects that would make the castings unfit for the use for which they are intended.
- 4.3 To minimize the possibility of introducing radioactive material to a melting operation, ferrous scrap, pig iron, and any recycled ferrous material shall be screened by the manufacturer for radioactivity with detection devices operated in accordance with the detection manufacturer's instructions. Written operating, calibration, and maintenance procedures for the detection equipment shall be provided to the purchaser for review when requested. Records shall be maintained by load of these tests for a period of seven years.
- 4.3.1 Only radiation devices designed specifically for the purpose of screening ferrous material shipments shall be used for the purpose of conforming to this requirement. Handheld radiation detectors (Geiger counters) are not appropriate and shall not be used for the purpose of conforming to this requirement.
- 4.3.2 Material that is found contaminated with radioactivity shall not be used to produce products covered by this specification.
- 4.3.3 Analysis of castings after the time of production shall not be used to determine compliance to this specification.

- 4.4 Foundries manufacturing products to this specification shall comply with all local, provincial, state, and national safety laws and regulations, and with the requirements of Practice E2349.
- 4.5 Pipe and fittings shall not be patched, filled, or welded by the manufacturer to repair cosmetic or material defects that occur during the course of manufacturing.

5. Mechanical Properties

- 5.1 Mechanical Tests for Gray Iron—The manufacturer shall perform tests to determine mechanical properties of the gray iron used in the manufacture of gray iron soil pipe and fittings. Tension test specimens shall be employed. The manufacturer shall maintain a record of mechanical tests for a minimum of 7 years.
- 5.1.1 *Tensile Strength Test*—The tensile strength shall be not less than 21 000 psi (145 MPa).
- 5.1.2 Tension test reports shall include breaking load of test bars, machined diameter of test bar, and calculated tensile strength.
- 5.1.3 Analysis of castings or test bars after the time of production shall not be used as evidence of compliance to this specification.

6. Chemical Test for Gray Iron

6.1 The manufacturer shall perform tests to determine the significant chemical constituents of the gray iron used in the manufacture of gray iron soil pipe and fittings. Analysis shall be performed at the minimum of once per lot as defined in this specification. The manufacturer shall maintain a record of chemical tests performed for a minimum of seven years. The test results shall conform to the following requirements as to chemical composition:

 Phosphorous (P)
 0.38 % Maximum

 Sulfur (S)
 0.15 % Maximum

 Chromium (Cr) (b) (-1 a) (7) (b) (0.50 % Maximum (A))
 0.50 % Maximum

 Itanium (Ti)
 0.10 % Maximum

 Aluminum (Al)
 0.50 % Maximum

 Lead (Pb)
 0.015 % Maximum

 Carbon Equivalent
 4.10 % Minimum by mass

 Note: Carbon equivalent for gray iron = %C+%Si/3+%P/3

- 6.1.1 Chemical tests shall be performed at the time of production of the castings covered by this specification.
- 6.1.2 Analysis of castings after the time of production shall not be used as evidence of compliance to this specification.

7. Dimensions and Permissible Variations

- 7.1 *Pipe:*
- 7.1.1 *Ends of Pipe*—The end of pipe shall be cast with or without a spigot bead. The pipe shall be cast in one piece.
- 7.1.2 *Dimensions of Pipe*—Pipe shall be 10 ft (3 m) long or 5 ft (1.5 m) long with the dimensions and tolerances specified in Figs. 1 and 2. (The laying length of pipe is the same as actual length.)
- 7.1.3 Straightness of Pipe—Pipe shall be straight to the extent that for 10-ft (3-m) lengths, deflections in the barrel shall not exceed ½ in. (16 mm). For 5-ft (1.5-m) lengths, deflections in the barrel shall not exceed ½ in. (8 mm).



7.2 Fittings:

- 7.2.1 *Dimensions of Fittings*—All fittings shall conform to the dimensions and tolerances specified in Figs. 1 and 2 as applicable. Fittings of the patterns specified in this specification shall conform to the applicable dimensions in Figs. 6–65, inclusive. Fittings not listed shall conform to Fig. 1 for wall thickness and dimension *R* for the minimum radius of any drain inlets that any such fittings provide.
- 7.2.2 All bends, sanitary tees, stack fittings, and special fittings that perform the function of a sanitary tee, designed for the conveyance of soil, waste, or both, affluent, shall have a radius not less than the following:

Nominal Size of Run or Branch (in.)	Minimum Radius
1½ – 2	125 % of the smaller run or branch
3 -4	100 % of the smaller run or branch
5 -6	80 % of the smaller run or branch
8 - 10	70 % of the smaller run or branch
12 - 15	60 % of the smaller run or branch

- 7.2.3 Ends of Fittings—Ends shall have spigot beads as shown in Figs. 1 and 2. Positioning lugs shall be cast on fittings. Positioning lugs shall be as described in Fig. 2 or continuous around circumference of the fitting. Exception: where permitted in Figs. 3–65, spigot beads and gasket positioning lugs shall be optional depending on casting method used. It is permissible to increase the wall thickness on the inside surface of fitting ends. The increased thickness shall not reduce the minimum B dimension in Table 1 in excess of 0.06 in. and shall not extend more than $4\frac{1}{4}$ in. from the plain end. The increased thickness shall be tapered and shall offer no obstruction to flow.
- 7.2.4 *Pipe Threads*—Screw plugs and tapped openings in fittings shall have taper pipe threads in accordance with ANSI/ASME Standard B1.20.
- 7.2.5 Internal threads shall be chamfered at the entering end approximately to the major diameter of the thread, at an angle of approximately 45° with the axis of the thread for easy entrance in making a joint and for protection of the thread. The chamfer shall be concentric with the thread and shall be included in the measurement of the thread length.

TABLE 1 EDP Identification Numbers for Hubless Pipe

Note 1—When ordering by these EDP numbers, be sure to include the check (\sqrt) digit following the item number (022 0126 7). This check digit is verification of the group and item number you select.

Manufacturer's		Code	Di-tiA	
Item	Group	Group Item No.		 Description^A
				10 ft (3 m) length
Hubless pipe (see Fig. 1.)		0156	4	11/2
		0158	0	21/2
		0160	6	3
	022	0162	2	4
		0164	8	5
		0168	9	6
		0170	5	8
		0171	3	10
		0172	7	12
		0173	1	15

^A EDP numbers for fittings will appear in each of the respective tables.

8. Methods of Specifying Fittings

- 8.1 *Method of Specifying Sizes of Fittings of More Than One Size*—The sizes shall be designated by the order of listing, as follows:
 - 8.1.1 Branch and Tapped Fittings:
- 8.1.1.1 *Size of Run*—The run shall be that portion of the fitting that forms part of the main pipe line.
 - 8.1.1.2 Size of Branch:
- 8.2 Methods of Specifying Hand of Fittings with Side Inlets—When placed in the position described below, if the side inlet appears on the right, it shall be a right-hand fitting; if on the left, it shall be a left-hand fitting.
- 8.2.1 *Branch Fittings*—The branch shall be placed toward the observer and the outlet end of the run lower than the branch.
- 8.3 The fitting illustrated in Fig. 3 has a right-hand inlet. Left-hand fittings have these openings on the side opposite to that shown. Inlets on fittings shall be made with or without spigot bead and positioning lug.

9. Coating

- 9.1 The pipe and fittings shall be uniformly coated with a material suitable for the purpose that is adherent, not brittle, and without a tendency to scale. The coating shall not contain asbestos above current MSDS reportable levels. Material safety data sheets shall be furnished by the coating manufacturer when requested. The coating shall be evenly and smoothly applied to all surfaces, except in threaded openings.
- 9.2 Pipe and fittings shall not be coated with paint containing lead which exceeds levels above 0.06 % (600 ppm).
- 9.2.1 The manufacturer shall annually prepare and submit samples to a qualified laboratory for test in accordance with Practice E1645.
- 9.3 Pipe and fittings shall not be coated with paint containing levels of volatile organic hazardous air pollutants (VOHAPs), which exceed levels of 2.6 lb (0.31 kg/L) of VOHAPs per gallon of solids.
- 9.3.1 A coating shall be sampled at the point of application, in its original state, not after the coating has been cured.
- 9.3.2 The manufacturer shall annually prepare and submit samples to a qualified laboratory for test in accordance with Practice D3960.
- 9.4 The manufacturer shall prepare and submit samples when changing sources of supply or the coating manufacturer changes formulations for the coating.
 - 9.5 Records shall be maintained for a period of seven years.
- 9.6 Copies of the coating test shall be furnished when requested.

10. Sampling

10.1 Chemical and mechanical tests shall be made regularly and at sufficiently close intervals for adequate determinations of the significant chemical constituents and properties of the cast iron. A specimen taken from a finished product often does not produce the same results as a specimen formed by the method used for sample preparation and is not acceptable for



the purposes of testing to this standard. Records of chemical analysis shall be maintained by the manufacturer. Copies of these analyses shall be furnished to the purchaser when requested.

- 10.2 A lot shall consist of one of the following:
- 10.2.1 All the metal poured from a single heating in a batch-type furnace.
- 10.2.2 All the metal from two or more batch-type melting furnaces poured into a single ladle or a single casting.
- 10.2.3 All the metal poured from a continuous melting furnace for a given period of time between changes in charge, processing conditions, or aim-for chemistry or 4 h, whichever is the shorter period.

11. Test Methods

- 11.1 Gray Iron:
- 11.1.1 *Tensile Strength Test*—Test bars shall be cast in accordance with the requirements of Specification A48/A48M. The machined test bar dimensions and drawing and dimensions of as-cast test bars are found in Fig. 4. The tensile strength shall be determined in accordance with Test Methods E8/E8M.
- 11.1.2 Tension test reports shall include breaking load of test bars, machined diameter of test bar, and calculated tensile strength.

12. Inspection

- 12.1 Inspection and Test by the Manufacturer—Pipe and fittings shall be inspected to verify compliance with this specification. The manufacturer shall maintain a record of all inspections.
- 12.2 Pipe Inspection—At regular intervals (not to exceed 12 h) during the course of production, sample pieces of each size of pipe or pipes being produced shall be selected randomly for inspection. Each pipe selected shall be measured by suitable gages and all dimensions detailed in Fig. 1 of this specification verified to comply with the requirements of this specification. The inspection records shall be maintained by the manufacturer for a period of seven years.
- 12.3 Fitting Inspection—At regular intervals (not to exceed twelve hours) during the course of production, sample pieces of each size and configuration of fitting being produced shall be selected randomly for inspection. Each fitting selected shall be measured by suitable gages to verify that the laying length (as detailed in Figs. 4–65), and all applicable dimensions detailed in Figs. 1 and 2 of this specification comply with the requirements of this specification. The inspection records shall be maintained by the manufacturer for a period of seven years.
- 12.4 *Marking Inspection*—Inspection shall include verification that the markings on pipe and fittings comply with Section 14 of this specification.

13. Certification

- 13.1 Upon request the purchaser, design professional, or the administrative authority having jurisdiction where the products are being installed shall be furnished certification, by the manufacturer, stating samples representing each lot have been tested and inspected as indicated in this specification and the requirements have been met. If required by the purchaser, design professional, or the administrative authority having jurisdiction where the products are being installed, certification shall be accompanied by test reports as prepared in accordance with Sections 11 and 12 of this specification. Tension test reports shall include breaking load machined diameters of test bars and calculated tensile strength. Certification shall include legal name and address of the manufacturer.
- 13.2 Third-party certifiers or inspectors shall utilize the procedures detailed in Annex A1 when conducting inspections at the manufacturing locations.

14. Product Marking


- 14.1 Each length of pipe and each fitting shall be plainly marked with the country of origin and the manufacturer's name or manufacturer's registered trademark by which the manufacturer can be readily identified after installation. The marking shall be adequate identification of the manufacturer of the pipe and fittings if it readily identifies the manufacturer to the end user of the product. Other markings on pipes and fittings shall be permitted provided such markings are not misleading with respect to the identification of the manufacturer by the end user.
- 14.1.1 *Pipe Markings*—The pipe shall be marked continuously on the barrel with a minimum of 0.75-in. (19-mm) lettering starting within 3 in. of each end of the pipe. Each pipe shall be marked with the date of manufacture. The marking shall be stenciled on the pipe or otherwise applied so as to be clear and legible.
- 14.1.2 On fittings, the marking shall be cast with raised letters that are not to be located within the "W" dimension, as shown in Fig. 2. Cast markings shall be raised from the wall of the fitting unless otherwise noted.

15. Packaging and Package Marking

15.1 Government Procurement—Unless otherwise specified in the contract, the material shall be packaged in accordance with the supplier's standard practice, which will be acceptable to the carrier at lowest rates. Containers and packing shall comply with Uniform Freight Classification Rules or National Motor Freight Classification Rules. Marking for shipment of such material shall be in accordance with Fed. Std. No. 123 for civil agencies and MIL-STD-129 for military agencies.

16. Keywords

16.1 cast iron; hubless pipe and fittings; no-hub pipe and fittings; soil pipe




*Pipe shall be with or without a spigot bead.

	Ва	rrel	Sp	got			Gasket Po-	Laying
Size	Inside Diameter	Outside Diameter	Outside Diameter	Bead Width ^A	Barrel Thickness, T		sitioning Lug ^A	Length, L ^B
OIZO	В	J	М	N, ±0.13 (3.3)	Nominal	Minimum	W	10 ft ± 0.50 in. (3.0480 m ± 13 mm)
11/2	1.50 ± 0.09	1.90 ± 0.06	1.96 ± 0.06	0.25	0.16	0.13	1.13	120
0	(38.1 ± 2.29)	(48.26 ± 1.52)	(49.78±1.52)	(6.35)	0.10	(3.3)	(28.7)	(3048)
2	1.96 ± 0.09 (49.8 ± 2.29)	2.35± 0.09 (59.69 ± 2.29)	2.41 ± 0.09 (61.21 ± 2.29)	0.25 (6.35)	0.16	0.13 (3.3)	1.13 (28.7)	120 (3048)
3	2.96 ± 0.09	3.35± 0.09	3.41 ± 0.09	0.25	0.16	0.13	1.13	120
Ü	(75.2 ± 2.29)	(85.09 ± 2.29)	(86.61 ± 2.29)	(6.35)	00	(3.3)	(28.7)	(3048)
4	3.94 ± 0.09	4.38 + 0.09	4.44 ± 0.09	0.31	0.19	0.15	1.13	120
	(100.08 ± 2.29)	- 0.05 (111.25 + 2.29) (-1.27)	(112.78 ± 2.29)	(7.87)		(3.81)	(28.7)	(3048)
5	4.94 ± 0.09	5.30 + 0.09 - 0.05	5.36 ± 0.09	0.31	0.19	0.15	1.50	120
	(125.48 ± 2.29)	(134.62 + 2.29) (-1.27)	(136.14 ± 2.29)	(7.87)		(3.81)	(38.1)	(3048)
6	5.94 ± 0.09	6.30 + 0.09 - 0.05	6.36 ± 0.09	0.31	0.19	0.15	1.50	120
	(150.88 ± 2.29)	(160.02 + 2.29) (-1.27)	(161.54 ± 2.29)	(7.87)		(3.81)	(38.1)	(3048)
8	7.94 ± 0.13	8.38 + 0.09	8.44 ± 0.09	0.31	0.23	0.17	2.00	120
		- 0.09						
	(201.68 ± 3.3)	(212.85 + 3.3)	(214.38 ± 2.29)	(7.87)		(4.32)	(50.8)	(3048)
http	s://standards.ite	eh.ai/(-2.29) g/sta	indards/sist/fe2;	0366/-3813-40	166-9db6-18	a1d/U6b114	e/astm-a88	8-1/
10	10.00 ± 0.13 (254 ± 3.3)	10.56 ± 0.09 (268.22 ± 2.29)	10.62 ± 0.09 (269.75 ± 2.29)	0.31	0.28	0.22 (5.59)	2.00 (50.8)	120 (3048)
12	(254 ± 5.5) 11.94 ± 0.13	(200.22 ± 2.29) 12.50 ± 0.13	(209.75 ± 2.29) 12.62 ± 0.13	(7.87) 0.31	0.28	.22	2.75	120
12	(303.28 ± 3.3)	(317.5 ± 3.3)	(320.55 ± 3.3)	(7.87)	0.20	.22 (5.59)	(69.85)	(3048)
15	(303.26 ± 3.3) 15.11 ± 0.13	(517.5 ± 3.3) 15.83 ± 0.13	(320.55 ± 3.5) 16.12 ± 0.13	0.31	0.36	.30	2.75	120
10	(383.79 ± 3.3)	(402.08 ± 3.3)	(409.45 ± 3.3)	(7.87)	0.00	(7.62)	(69.85)	(3048)

FIG. 1 Dimensions and Tolerances in Inches (Millimetres) of Spigots and Barrels for Hubless Pipe and Fittings

A See Fig. 2 for details of the spigot and gasket positioning lug.

B Laying lengths as listed in Fig. 1 shall be for pipe only, and such pipe shall be 10 ft (3 m) long. Laying length for fittings are listed in the applicable tables.



Note 1—Pipe shall be cast with or without the gasket positioning lugs. These lugs, as illustrated above, shall be cast as illustrated or be continuous around the entire circumference.

Note 2—Gasket positioning lugs shall be cast on all fittings except as otherwise noted. These lugs, as illustrated above, shall be cast as illustrated or be continuous around the entire circumference.

Size, in.	Spigot Detail, N in. (mm) ±0.13 (3.3)	Gasket Lug Location, W in. (mm) ±0.13 (3.3)
11/2	0.25 (6)	1.13 (29)
2	0.25 (6)	1.13 (29)
3	0.25 (6)	1.13 (29)
4	AS 1 M 0.31 (8)	1.13 (29)
https://standards6teh.ai/ca	ttalog/standards/sist/fe253(0.31 (8) 813-4d66-9db6-1a10	1706b1f4e/1.50 (38) 1.50 (38)
8	0.31 (8)	2.00 (51)
10	0.31 (8)	2.00 (51)
12	0.31 (8)	2.75 (70)
15	0.31 (8)	2.75 (70)

FIG. 2 Details of Spigot Bead and Gasket Positioning Lug





FIG. 3 Specifying Hand of Fittings with Side Inlets or Outlets





Dimensions, in (mm) G—Length of parallel, min

D-Diameter

R-Radius of fillet, min

A-Length of reduced section, min

L-Overall length, min

C-Diameter of end section, approx

E-Length of shoulder, min

F—Diameter of shoulder

B-Length of end section

Tension Test Specimen B

0.75 (19)

 $0.750 \pm 0.015 (19.0 \pm 0.38)$

1 (25)

1½ (38)

4 (100)

11/4 (32) 1/4 (6)


 $^{15/_{16}} \pm ^{1/_{64}} (25 \pm 0.4)$

	As-Cast Diameter, in. (mm)								
Test Bar	Nominal (Mid- Length)	Minimum (Bottom)	Maximum (Top)	Minimum (Specified)	Maximum (Rec- ommended)				
В	1.20 (30.5)	1.14 (29.0)	1.32 (33.5)	6.0 (150)	9.0 (230)				

A Optional to fit holders on testing machine. If threaded, root diameter shall not be less than dimension F.

FIG. 4 Sample Test Bar






ASA C Group		Size, — in.						
Item No.	\checkmark	— in.	В	D ^B ±1/8 (3.2)	R	W		
0188	7	11/2	1½ (38)	41/4 (108)	23/4 (70)	11/8 (29)		
0190	3	2	1½ (38)	4½ (114)	3 (76)	11/8 (29)		
0192	9	3	1½ (38)	5 (127)	31/2 (89)	11/8 (29)		
0194	5	4	1½ (38)	5½ (140)	4 (102)	11/8 (29)		
0196	0	5//	2 (51)	6½ (165)	<u>4½</u> (114)	1½ (38)		
0198	6	6	2 (51)	7 (178)	5 (127)	1½ (38)		
0200	0	8	21/2 (64)	8½ (216)	6 (152)	2 (51)		

^A For details of barrel, spigot, and gasket positioning lug, see Figs. 1 and 2.

^B Dimension D is laying length.

FIG. 5 1/4 Bend (Corresponds to Table 5 of CISPI Specification 301)




	ASA Code	Group 022			Dimensions, in. (mm) ^A				
	Sizes, in.								
	Item No.	<u>√</u>		В	R	$D^B \pm \frac{1}{8} (3.2)$	$E^B \pm \frac{1}{8} (3.2)$	W	
Fig. (a)	0218	2	4 by 3	1½ (38)	3½ (89)	5½ (140)	5 (127)	11/8 (29)	
Fig. (b)	0218	2	4 by 3	1½ (38)	4 (102)	5½ (140)		11/8 (29)	

^A For details of barrel, spigot, and gasket positioning lug, see Figs. 1 and 2.

(a)

FIG. 6 Reducing 1/4 Bend (Corresponds to Tables 6 and 7 of CISPI Specification 301)



Note 1—For details of 1/4 bend, see Fig. 5.

 $\mbox{\it Note }2\mbox{\it --}\mbox{Inclusion}$ of spigot bead and positioning lug optional with manufacturer based on casting method used.


ASA Code G	aroup 022	2	Dimensions, in. (mm) ^A				
		Sizes, in.					
Item No.	$\sqrt{}$		В	$E^B \pm \frac{1}{8} (3.2)$	D^B		
0236	4	3 by 2	1½ (38)	31/4 (83)	4 (102)		
0238	0	4 by 2	1½ (38)	3¾ (95)	45/16 (110)		

A For details of barrel, spigot, and gasket positioning lug, see Figs. 1 and 2.

FIG. 7 1/4 Bend with Side Opening (Corresponds to Table 8 of CISPI Specification 301)

^B Dimensions D and E are laying lengths.


^B Dimension E is laying length.



ASA Code Grou	up 022		Dimensions, in. (mm) ^A					
		Size, in.						
Item No.	\checkmark		В	$D^B \pm \frac{1}{8} (3.2)$	$E^B \pm \frac{1}{8} (3.2)$	R	W	
0280	2	3 by 2	1½ (38)	5 (127)	27/8 (73)	31/2 (89)	11/8 (29)	
0275	2	3 by 2	1½ (38)	5 (127)	10½ (267)	31/2 (89)	11/8 (29)	
0282	8	4 by 2	11/2 (38)	5½ (140)	31/4 (83)	4 (102)	11/8 (29)	

A For details of barrel, spigot, and gasket positioning lug, see Figs. 1 and 2. B Dimensions D and E are laying lengths.

FIG. 8 $\frac{1}{4}$ Bend with Heel Opening (Corresponds to Table 9 of CISPI Specification 301)




ASA Code Gro	up 022			Dimensions, in. (mm) ^A					
		Size, in.							
Item No.	$\sqrt{}$		В	E	$D^B \pm \frac{1}{8} (3.2)$	R	IPS Tapping C	W	
0324	8	1½ by 1¼	1½ (38)	2 (51)	3 (76)	13/4 (44)	11/4 (32)	11/8 (29)	
0326	3	1½ by 1½	1½ (38)	2 (51)	3 (76)	13/4 (44)	11/2 (38)	11/8 (29)	
0328	9	2 by 11/4	1½ (38)	21/4 (57)	31/4 (83)	13/4 (44)	11/4 (32)	11/8 (29)	
0330	5	2 by 1½	1½ (38)	21/4 (57)	31/4 (83)	13/4 (44)	11/2 (38)	11/8 (29)	
		2 by 2	1½ (38)	21/4 (57)	31/4 (83)	13/4 (44)	2 (51)	11/8 (29)	

A For details of barrel, spigot, and gasket positioning lug, see Figs. 1 and 2.
 B Dimension D is laying length.
 C For details of tapping bosses, see Fig. 58.

FIG. 9 Tapped 1/4 Bend (Corresponds to Table 11 of CISPI Specification 301)






ASA Co Group (Dimension	ns, in. (mm) ^A	
		Size, in.				
Item No.	\vee		$D^B \pm \frac{1}{8} (3.2)$	R	В	W
0402	2	2	4½ (114)	3 (76)	1½ (38)	11/8 (29)
0404	8	3	5 (127)	3½ (89)	11/2 (38)	11/8 (29)
0406	3	4	5½ (140)	4 (102)	11/2 (38)	11/8 (29)

^A For details of barrel, spigot, and gasket positioning lug, see Figs. 1 and 2.

^B Dimension D is laying length.

FIG. 10 Double 1/4 Bend (Corresponds to Table 13 of CISPI Specification 301)




ASA Code Group 022		Size, in.	Dimensions, in. (mm) ^A				
Item No.	$\sqrt{}$	Size, III.	В	$E^B \pm \frac{1}{8} (3.2)$	D ^B ±1/8 (3.2)	R	W
0424	6	2 by 12	1½ (38)	4½ (114)	12 (305)	3 (76)	11/8 (29)
		2 by 14	1½ (38)	4½ (114)	14 (356)	3 (76)	11/8 (29)
0423	8	2 by 16	1½ (38)	4½ (114)	16 (406)	3 (76)	11/8 (29)
0425	3	2 by 18	1½ (38)	4½ (114)	18 (457)	3 (76)	11/8 (29)
		2 by 24	1½ (38)	4½ (114)	24 (610)	3 (76)	11/8 (29)
0426	1	3 by 12	1½ (38)	5 (127)	12 (305)	3½ (89)	11/8 (29)
0427	9	3 by 18	1½ (38)	5 (127)	18 (457)	31/2 (89)	11/8 (29)
0428	7	4 by 12	11/2 (38)	5½ (140)	12 (305)	4 (102)	11/8 (29)
0431	1	4 by 18	1½ (38)	5½ (140)	18 (457)	4 (102)	11/8 (29)

^A For details of barrel, spigot, and gasket positioning lug, see Figs. 1 and 2. ^B Dimensions D and E are laying lengths.

FIG. 11 Long 1/4 Bend (Corresponds to Table 14 of CISPI Specification 301)






	022	Size, in.	Dimensions, in. (mm) ^A				
Item No.		Size, iri.	В	D ^B ±1/8 (3.2)	R	W	
0462	6	2	1½ (38)	6½ (165)	5 (127)	11/8 (29)	
0464	2	3	1½ (38)	7 (178)	5½ (140)	11/8 (29)	
0468	3	4	1½ (38)	7½ (191)	6 (152)	11/8 (29)	
0470	9	5	2 (51)	81/2 (216)	6½ (165)	1½ (38)	
0472	5	6	2 (51)	9 (229)	7 (178)	1½ (38)	
0474	1	8	2½ (64)	10½ (267)	8 (203)	2 (51)	
0475	8	10	3 (76)	12 (305)	9 (229)	2 (51)	
0476	8	12	31/4 (83)	131/4 (337)	10 (254)	23/4 (70)	
0477	8	15	31/4 (83)	143/4 (375)	11½ (292)	23/4 (70)	

			Exte	ended Pattern			
ASA Code Group 022		Sizo in					
Item No.	V	- Size, in	Blall	D ^B ±1/8 (3.2)	$E^B \pm \frac{1}{8} (3.2)$	R	W
0478	7	2 by 12	1½ [38]	6½ [165]	12 [305]	5 [127]	11/8 [29]
0479	7	2 by 14	1½ [38]	6½ [165]	14 [356]	5 [127]	11/8 [29]
0480	7	2 by 16	1½ [38]	6½ [165]	16 [406]	5 [127]	11/8 [29]
0481	7	2 by 18	1½ [38]	6½ [165]	18 [457]	5 [127]	11/8 [29]
0482	7	2 by 24	1½ [38]	6½ [165]	24 [610]	5 [127]	11/8 [29]
0483	7	2 by 34	1½ [38]	6½ [165]	34 [864]	5 [127]	11/8 [29]

A For details of barrel, spigot, and gasket positioning lug, see Figs. 1 and 2.3667-38f3-4d66-9db6-1a1d706b1f4e/astm-a888-17 Dimension D is laying length.


FIG. 12 Short Sweep (Corresponds to Table 15 of CISPI Specification 301)



ASA Code Group 022		Size,	Dimensions, in. (mm) ^A				
Item No.	\vee	– in.	В	D ^B ±½ (3.2)	R	W	
0492	3	11/2	1½ (38)	91/4 (235)	73/4 (197)	11/8 (29)	
0494	9	2	1½ (38)	9½ (241)	8 (203)	11/8 (29)	
0496	4	3	11/2 (38)	10 (254)	81/2 (216)	11/8 (29)	
0498	0	4	1½ (38)	10½ (267)	9 (229)	11/8 (29)	
0500	3	5	2 (51)	11½ (292)	91/2 (241)	1½ (38)	
0502	9	6	2 (51)	12 (305)	10 (254)	1½ (38)	

^A For details of barrel, spigot, and gasket positioning lug, see Figs. 1 and 2.

FIG. 13 Long Sweep (Corresponds to Table 17 of CISPI Specification 301)



^A For details of barrel, spigot, and gasket positioning lug, see Figs. 1 and 2. ^B Dimension D is laying length.

FIG. 14 Reducing Long Sweep (Corresponds to Table 18 of CISPI Specification 301)

ASTM A888-17

https://standards.iteh.ai/catalog/standards/sist/fe253667-38f3-4d66-9db6-1ald706blf4e/astm-a888-1

^B Dimension D is laying length.