



SLOVENSKI STANDARD
SIST ENV 50123-7-1:1998
01-november-1998

Railway applications - Fixed installations - D.C. switchgear - Part 7: Measurement, control and protection devices for specific use in d.c. tractions

Railway applications - Fixed installations - D.C. switchgear -- Part 7-1: Measurement, control and protection devices for specific use in d.c. traction systems -- Application guide

Bahnanwendungen - Ortsfeste Anlagen - Gleichstrom-Schaltanlagen -- Teil 7-1: Meß-, Steuer- und Schutzeinrichtungen in Gleichstrom-Bahnanlagen - Anwendungleitfaden

Applications ferroviaires - Installations fixes - Appareillage à courant continu -- Partie 7-1: Appareils de mesure, de commande et de protection pour utilisation spécifique dans les systèmes de traction à courant continu - Guide d'application

Ta slovenski standard je istoveten z: ENV 50123-7-1:1998

ICS:

29.130.99	Druge stikalne in krmilne naprave	Other switchgear and controlgear
29.280	Ò\ dã } æ\ ^ } æ\] ! ^ { æ	Electric traction equipment

SIST ENV 50123-7-1:1998 en

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST ENV 50123-7-1:1998

<https://standards.iteh.ai/catalog/standards/sist/834c8261-1a6c-447a-8836-9da58c25bcff/sist-env-50123-7-1-1998>

EUROPEAN PRESTANDARD
PRÉNORME EUROPÉENNE
EUROPÄISCHE VORNORM

ENV 50123-7-1

May 1998

ICS 29.120.60; 45.020

Descriptors: Railway equipment, railway fixed equipment, electric traction, direct current, cutouts, electric power supply, definitions, operating requirements, measurements, inspection, protection

English version

**Railway applications - Fixed installations - D.C. switchgear
Part 7: Measurement, control and protection devices for
specific use in d.c. traction systems
Section 1: Application guide**

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST ENV 50123-7-1:1998](https://standards.iteh.ai/catalog/standards/sist/834c8261-1a6c-447a-8836-9da58c25bcff/sist-env-50123-7-1-1998)

<https://standards.iteh.ai/catalog/standards/sist/834c8261-1a6c-447a-8836-9da58c25bcff/sist-env-50123-7-1-1998>

This European Prestandard (ENV) was approved by CENELEC on 1998-01-14 as a prospective standard for provisional application. The period of validity of this ENV is limited initially to three years. After two years the members of CENELEC will be requested to submit their comments, particularly on the question whether the ENV can be converted into a European Standard (EN).

CENELEC members are required to announce the existence of this ENV in the same way as for an EN and to make the ENV available promptly at national level in an appropriate form. It is permissible to keep conflicting national standards in force (in parallel to the ENV) until the final decision about the possible conversion of the ENV into an EN is reached.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: rue de Stassart 35, B - 1050 Brussels

Page 2
ENV 50123-7-1:1998

Foreword

This European Prestandard was prepared by SC 9XC, Electric supply and earthing systems for public transport equipment and ancillary apparatus (fixed installations) of Technical Committee CENELEC TC 9X, Electrical and electronic applications for railways.

A first draft was submitted to the CENELEC enquiry as prEN 50123-7-1. The CENELEC Technical Board agreed that the document be further processed as a prENV.

A revised draft was approved by CENELEC SC 9XC on 1998-01-14 as ENV 50123-7-1.

This document is the first section of part 7 of EN 50123. Part 7 is divided into sections to cover an application guide and a number of protection devices with specific features for d.c. railway applications.

Annexes designated "informative" are given for information only.
In this ENV 50123-7-1 annexes A, B and C are informative.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST ENV 50123-7-1:1998

<https://standards.iteh.ai/catalog/standards/sist/834c8261-1a6c-447a-8836-9da58c25bcff/sist-env-50123-7-1-1998>

Contents

	page
Introduction	4
1 Scope	4
2 References	4
3 Definitions	4
3.1 d.c. sensor	4
3.2 d.c. shunt	5
3.3 isolation transducer	5
3.4 Hall effect sensor	5
3.5 divider	5
4 Measurement	5
4.1 General	5
4.2 Current	5
4.3 Voltage dividers	6
5 Control systems	7
5.1 General	7
5.2 Anti-pumping	7
5.3 Auto-reclose with variable reclose time and final lock out	7
5.4 Line test device	8
5.5 Undervoltage close inhibit	9
6 Protection systems	10
6.1 General	10
6.2 Protection system of line circuit breakers (L)	10
6.3 Protection system for rectifier circuit breaker (R)	11
6.4 Direct acting (series trip)	12
6.5 Indirect acting	14
Annex A (informative) Electronic protection relay features	19
Annex B (informative) Rate of rise and ΔI relay - Examples for fault characteristic and setting parameter selection	21
Annex C (informative) Bibliography on relays in use	24

Introduction

EN 50123-7 is divided in a number of sections as follows:

- Section 1: Application guide
- Section 2: Isolating current transducers and other current measuring devices
- Section 3: Isolating voltage transducers and other voltage measuring devices

This number of sections is subject to future additions whenever a device is considered suitable for inclusion.

Section 1 of Part 7 is a guide and its contents is informative.

Further sections of Part 7 are normative with respect to equipment falling within the scope of that section.

1 Scope

ENV 50123-7-1 provides assistance, guidance and requirements for the design of protection, control and measuring systems in d.c. installations intended to provide a power supply to traction systems. This application guide identifies the characteristics and parameters of equipment used in the measurement, control and protection of d.c. traction systems.

[SIST ENV 50123-7-1:1998](https://standards.iteh.ai/catalog/standards/sist/834c8261-1a6c-447a-8836-31b51237-8337-1:1998)

[https://standards.iteh.ai/catalog/standards/sist/834c8261-1a6c-447a-8836-](https://standards.iteh.ai/catalog/standards/sist/834c8261-1a6c-447a-8836-31b51237-8337-1:1998)

Guidance is given concerning the appropriate application of electrical protection systems.

2 References

This Application Guide makes reference to the other parts of EN 50123, as well as to the other sections¹⁾ of part 7.

3 Definitions

The definitions are given in EN 50123-1:1995, clause 3. The following additional definitions apply:

3.1 d.c. sensor

A device used for detecting a current or a voltage in the d.c. main circuit, which produces an output signal, proportional to and linear (over a range) with the primary input, for connection to a secondary device which acts on the signal.

1) Under preparation.

3.2 *d.c. shunt*

This device is connected in the primary circuit, usually composed of metal grids, that provides a millivolt output proportional to the current flowing in the primary circuit.

3.3 *isolation transducer*

A device which is interposed between the output of a sensor in the main circuit and the input of a secondary device used for measurement or protection, and used to provide an output isolated from the main circuit.

3.4 *Hall effect sensor*

This type of sensor fits around the main circuit current carrying conductor and uses a single or multiple Hall effect devices situated in the magnetic field of an iron circuit, which is energised by the current in the main conductor.

3.5 *divider*

This consists in a bank of resistors connected across the main supply with a footing resistor used as the output, which gives a voltage proportional to the main supply. This output is connected either directly or indirectly through an isolation transducer to the voltage terminals of the secondary device.

SIST ENV 50123-7-1:1998

[https://standards.iteh.ai/catalog/standards/sist/834c8261-1a6c-447a-8836-](https://standards.iteh.ai/catalog/standards/sist/834c8261-1a6c-447a-8836-9da58c25bcff/sist-env-50123-7-1-1998)

4 **Measurement** [9da58c25bcff/sist-env-50123-7-1-1998](https://standards.iteh.ai/catalog/standards/sist/834c8261-1a6c-447a-8836-9da58c25bcff/sist-env-50123-7-1-1998)

4.1 *General*

Two types of measurements are made on traction systems:

- a) Measurements of current and voltage for connections to instruments and metering.
- b) Current and voltage signals used for operating protection devices.

NOTE: Care shall be taken that inductive circuits can alter the inherent di/dt response.

4.2 *Current*

4.2.1 *d.c. shunt*

A shunt is usually used for measurement purposes, but, when used for protection where accuracy of response is required, the device is preferably of the non-inductive type.

Use of an isolation transducer permits operation of secondary devices at lower voltage and with lower rated insulation. This is preferable to taking full mains voltage. into what may otherwise be low voltage compartments.

Page 6

ENV 50123-7-1:1998

It should be noted that shunts can run very hot when carrying their rated normal current, with one terminal hotter than the other, dependant on the direction of current flow. Where they are used inside switchgear assemblies, then temperature rise tests of the assemblies should take this fact into account.

4.2.2 Isolation transducer

See EN 50123-7-2 and EN 50123-7-3.

This device requires an auxiliary power supply which should be derived from a guaranteed source whose loss of supply should initiate an alarm.

The output signal is usually not of the same level as the input and is dependant on the requirements of the secondary device.

4.2.3 Hall effect sensor

This device requires an auxiliary power supply which should be derived from a guaranteed source whose loss of supply should initiate an alarm.

This device provides an isolated output. The primary insulation is generally provided by encapsulation of the iron circuit and sensors. The device is sometimes constructed in a split form for ease of fitting to a main conductor.

The output signal from the device is proportional to the current in the main conductor. This signal is very low in magnitude and usually requires amplification to provide a suitable input to the secondary device. Thus an auxiliary power supply is required.

Reliability and overall accuracy can be improved by using an average value obtained from multiple devices. Placing devices at different locations around a conductor can reduce proximity effects.

4.3 Voltage dividers

Dividers have the same insulation voltage requirements as the main circuit. Isolation transducers should be employed if the secondary device can not withstand the main circuit insulation level.

NOTE: Failure to open circuit of the footing resistor will result in approximately full mains voltage appearing on the output side of the divider. A voltage limiter connected in parallel to the footing resistor may be employed for protection against overvoltages

5 Control systems

5.1 General

Control systems are usually only those which involve the electrical closing of switchgear devices. Their effect is to permit or inhibit a closure depending on the status of the system and the compliance with specified requirements.

5.2 Anti-pumping

This system permits the closing device to effect a single attempt while the signal to close is maintained. If the device fails to complete a satisfactory close operation whilst the close signal is maintained, then attempts at further reclosing (pumping) are inhibited.

Anti-pumping can be achieved in the closing control circuit in various ways, either by using mechanism auxiliary switches or a timing relay. It only allows a single closing pulse to the closing device, which resets when the initial closing signal is released.

Anti-pumping should be explicitly requested by the purchaser and may be applied to all types of switchgear closing device.

5.3 Auto-reclose with variable reclose time and final lock out

Auto-reclose is only applied to the line circuit breaker (L). Its purpose is to reclose the line circuit breaker automatically after an overcurrent release operation.

On traction systems especially light-rail or trolleybus systems, overcurrent release operations are often due to temporary short circuits and an auto-reclose system can enhance the reliability of the system.

Auto-reclose is usually associated with a timing device which initiates several attempts at reclosing with varying adjustable intervals of circuit dead time. After a prescribed number of unsuccessful recloses, then a lock out of the reclosing circuit is instigated. This lock out is either electrically or manually resettable.

The purchaser should specify the need for this requirement and provide the following information:

- a) Number of recloses: e.g. 2 recloses then lock out;
- b) Time interval between each attempt: e.g. 15 s, followed by 60 s, followed by 180 s;
- c) Lock out reset: i.e. local or remote.

5.4 Line test device

This system is used on line circuit breakers (L) before closing, to prevent the line circuit breaker closing onto a close up or a maximum energy short circuit at a location close to a circuit breaker. A typical basic line test device circuit is shown in figure 1.




Figure 1: Basic circuit for line test device

This is achieved by inserting a resistor by means of a suitably rated contactor between the switchboard busbars and the contact line. An auxiliary supply is alternatively used as the test voltage. The load impedance acts as a footing resistance to the inserted resistor and, by measuring the voltage between feeder and return circuit, it can allow/inhibit a close signal.

When the measured voltage is below a prescribed level, then there is an overload on the line and the close is inhibited. When this voltage is above a prescribed level, a close is permitted.

Line test device systems may be either of the low resistance or the high resistance type. The problem with line testing measurements is the effect of the negative voltage drop which can appear on the return circuit, due to currents in the return circuit from loads external to the line test device zone, which can give misleading interpretation of the line testing measurements. Where negative voltage drop in the return circuit can give this effect, it can be minimised by resorting to the low resistance system which tends to swamp out this effect.

The line test device can be coupled with auto-reclose schemes, thereby inhibiting a reclose if the original trip was due to a fault which had not cleared itself in the dead time.

The line test device can be by-passed if the line is already live from the line circuit breaker at the remote end.

The purchaser should specify the need for a Line test device system and provide the following information:

- a) High or low value of the resistor: i.e. involving a current value to be chosen from 1 A to 400 A;
- b) Whether line test device is combined with auto-reclose.

ITeh STANDARD PREVIEW
(standards.iteh.ai)

5.5 Undervoltage close inhibit

SIST ENV 50123-7-1:1998

Operation of undervoltage close inhibit is usually achieved by the fitting of an undervoltage release to the circuit breaker. Alternatively undervoltage relays with accurate pick up and drop off voltage levels, operating on to shunt trip devices and close inhibits, can achieve similar effects.

When fitted to a rectifier circuit breaker, this device has the effect that the circuit breaker cannot be closed unless the rectifier is live. The voltage source is the output of the rectifier.

When fitted to a line circuit breaker, the voltage source is that of the busbar. Unless the busbar is live the circuit breaker cannot be closed.

The purchaser should specify the requirements for undervoltage close inhibit and provide the following information:

- a) Direct acting undervoltage trip relay or
- b) Indirect acting via undervoltage relay
- c) Minimum pick up voltage (V);
- d) Maximum drop off voltage (V).

NOTE: Direct acting devices require a very wide operating voltage range.