



Designation: D6157 – 97 (Reapproved 2017)^{ε1}

Standard Practice for Determining the Performance of Oil/Water Separators Subjected to a Sudden Release¹

This standard is issued under the fixed designation D6157; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

^{ε1} NOTE—The Keywords Section was added editorially in December 2017.

1. Scope

1.1 This practice describes the testing procedure, any necessary related apparatus, and the sampling technique to be used in determining the performance characteristics of an oil/water separator subjected to the sudden release of a relatively large quantity of hydrocarbons that may appear in its influent in pure form or at high concentration.

1.2 This practice does not address the determination of the performance characteristics of an oil/water separator subjected to surface run-off resulting from rain water draining from improved or unimproved land. In this case, refer to Practice D6104.

1.3 This practice does not address the determination of the performance characteristics of an oil/water separator subjected to a mechanically emulsified influent such as provided by a pump.

1.4 This practice does not investigate the ability of the separator to handle debris or suspended solids, that is, grit or tree leaves.

1.5 While the effluent may meet code requirements for total oil and grease content, this practice does not address the presence of soluble organics, that is, benzene, toluene, ethylbenzene, and xylene (BTEXs) that may be detected in the effluent. It also does not make any provisions for the effects of detergents, surfactants, soaps or any water soluble matter (that is, salts) or any portion of an essentially insoluble matter that may be found in solution on separation. (Effects of certain water soluble chemicals or solids may be investigated by adding them to the water at predetermined constant concentrations.)

1.6 In order to estimate the effect of water temperature on the performance of the separator, the tests described in this

practice must be performed at two water temperatures. The selected temperatures must be at least 10°C (18°F) apart, with the temperature ranging from a minimum of 0°C (32°F) to a maximum of 50°C (122°F).

1.7 This practice does not make any provisions for the variation of pH or temperature during a test run. Refer to Appendix X1 for further detail.

1.8 This practice can be used with a variety of hydrocarbons. It adopts No. 2 fuel oil with a density² of 845 kg/m³ (52.73 lb_m/ft³) and a viscosity² of 1.9 to 4.1 centistokes at 40°C (104°F) and SAE 90 lubricating oil with a density (See SAE J313) of 930 kg/m³ (58 lb_m/ft³) at 15.5°C (60°F) and a viscosity (see SAE J306) of 13.5 to <24 centistokes at 100°C (212°F) as the comparative testing media. It is understood that the results obtained from this practice are only directly applicable to No. 2 fuel oil and SAE 90 lubricating oil for the tested concentrations and only careful interpolation or extrapolation, or both, is allowed to other hydrocarbons. Low viscosity or high density hydrocarbons or hydrocarbons that contain a larger fraction of highly soluble compounds may need to be tested separately.

NOTE 1—No extrapolation outside the range of the tested influent or effluent oil concentrations is allowed as performance may not be linear. Hence, to establish performance at a higher or lower concentration, the separator shall be tested for that specific condition. In addition, linearity must be established prior to using linear interpolation.

1.9 Since regulations are based on effluent total hydrocarbon content, this practice does not set forth any lower limits on oil particle size for the evaluation of separator efficiency. However, a standardized means for mixing oil and water shall be specified to ensure repeatability. It must be noted however that smaller particles, having a greater surface area to volume ratio, rise at a slower rate than their larger counterparts. (Guide F933 requires that 20 % of all oil particles be smaller than or equal to 50 μm and IMO MEPC 60 (30) does not mention any particle size requirements but asks the user to avoid emulsion causing chemicals.)

¹ This practice is under the jurisdiction of ASTM Committee D19 on Water and is the direct responsibility of Subcommittee D19.06 on Methods for Analysis for Organic Substances in Water.

Current edition approved Dec. 15, 2017. Published January 2018. Originally approved in 1997. Last previous edition approved in 2011 as D6157 – 97 (2011). DOI: 10.1520/D6157-97R17E01.

² Bolz, R. E., and Tuve, G. L., *CRC Handbook of Tables for Applied Engineering Science*, 2nd Edition, CRC Press, 1991.

1.10 Although the tests described in this practice intend to simulate the performance of a separator subjected to a sudden release, they do not cover all possible applications. It is the end user's responsibility to determine whether his separation requirements are within the scope of this practice.

1.11 A product different from the general description herein may be tested and found to be in compliance with the performance criteria set forth.

1.12 The values stated in SI units are to be regarded as standard. The values given in parentheses are mathematical conversions to inch-pound units that are provided for information only and are not considered standard.

1.13 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety, health, and environmental practices and determine the applicability of regulatory limitations prior to use.*

1.14 *This international standard was developed in accordance with internationally recognized principles on standardization established in the Decision on Principles for the Development of International Standards, Guides and Recommendations issued by the World Trade Organization Technical Barriers to Trade (TBT) Committee.*

2. Referenced Documents

2.1 ASTM Standards:³

[D1129 Terminology Relating to Water](#)

[D3370 Practices for Sampling Water from Closed Conduits](#)

[D4281 Test Method for Oil and Grease \(Fluorocarbon Extractable Substances\) by Gravimetric Determination \(Withdrawn 2012\)⁴](#)

[D6104 Practice for Determining the Performance of Oil/Water Separators Subjected to Surface Run-Off](#)

[F933 Guide for Evaluation of Oil Water Separation Systems for Spilled Oil Recovery Applications \(Discontinued 2001\) \(Withdrawn 2001\)⁴](#)

2.2 EPA Standards:⁵

[EPA-413.1 "Methods for Chemical Analysis of Water and Wastes," EPA 600/4-79-020](#)

[EPA-413.2 "Methods for Chemical Analysis of Water and Wastes," EPA 600/4-79-020](#)

[EPA-1664 H-Hexane Extractable Material \(HEM\) and Silica Gel Treated N-Hexane Extractable Material \(SGT-HEM\) by Extraction and Gravimetry \(Oil and Grease and Total Petroleum Hydrocarbons\) EPA-821-B-94-004B](#)

[40 CFR Ch. 1 \(7-1-95 Edition\)⁵](#)

³ For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

⁴ The last approved version of this historical standard is referenced on www.astm.org.

⁵ Available from United States Environmental Protection Agency (EPA), William Jefferson Clinton Bldg., 1200 Pennsylvania Ave., NW, Washington, DC 20460, <http://www.epa.gov>.

2.3 SAE Standards:⁶

[SAE J306 Axle and Manual Transmission Lubricant Viscosity Classification](#)

[SAE J313 Surface Vehicle Recommended Practice — \(R\) Diesel Fuels](#)

3. Terminology

3.1 Definitions:

3.1.1 For definitions of terms used in this standard, refer to Terminology [D1129](#).

3.2 Definitions of Terms Specific to This Standard:

3.2.1 *calibration, n*—the certified evaluation of the accuracy of a measuring instrument as performed by its manufacturer or an independent licensed or accredited third party.

3.2.2 *contaminated run-off, n*—rain water which has collected oily contaminants from the surfaces it came in contact with and which may appear in the influent to a separator. Unlike a release, the level of contamination in this case is much lower.

3.2.3 *effluent, n*—the aqueous release from a separator.

3.2.4 *flow totalizer, n*—a counter, usually attached to a flow meter, that evaluates the total volume of the fluid that has flowed through over a given time period.

3.2.5 *influent, n*—the oily aqueous input to a separator.

3.2.6 *oily discharge, n*—any release of oily contaminants into the environment that exceeds the allowable limit.

3.2.7 *re-entrainment, n*—the condition in which the level of contamination of the effluent water of a separator containing oil is higher than the influent contamination level due to internal remixing. This definition usually applies to situations where clean water passes through a separator that already contains Hydrocarbons stored within and atop the water so as to form an interface.

3.2.8 *release, n*—any sudden discharge of an oily substance from vessels that are specifically designed to store, contain, or transfer oily products such as storage tanks, pipelines, diked areas, and transfer equipment and which may appear in the influent to a separator.

3.2.9 *separator, n*—a flow through primary treatment device the primary purpose of which is to separate oil from water.

4. Summary of Practice

4.1 The practice evaluates a separator's ability to inhibit a sudden release from escaping into its effluent. For this, a quantity of hydrocarbon constituting at least the rated oil storage capacity of the separator is released at the separator's rated flow for the test conditions, either in pure form or mixed with water to form a 500 000-mg/L concentration. It is then immediately followed with fresh water. The corresponding effluent hydrocarbon content is determined by obtaining and analyzing grab samples.

4.2 The data generated in this practice are considered valid for the separators tested only. However, the results of these

⁶ Available from SAE International (SAE), 400 Commonwealth Dr., Warrendale, PA 15096, <http://www.sae.org>.