



**Environmental Engineering (EE);
Monitoring and control interface for infrastructure equipment
(power, cooling and building environment systems used in
telecommunication networks);
Part 12: ICT equipment power, energy and environmental
parameters monitoring information model**

<https://standards.iteh.ai/catalog/standards/etsi/c1d94dc5-be04-46da-81a5-2873dde75425/etsi-es-202-336-12-v1-3-1-2025-09>

Reference

RES/EE-02106

Keywords

control, energy efficiency, interface, management,
network monitoring, power, system

ETSI

650 Route des Lucioles
F-06921 Sophia Antipolis Cedex - FRANCE

Tel.: +33 4 92 94 42 00 Fax: +33 4 93 65 47 16

Siret N° 348 623 562 00017 - APE 7112B
Association à but non lucratif enregistrée à la
Sous-Préfecture de Grasse (06) N° w061004871

Important notice

The present document can be downloaded from the
[ETSI Search & Browse Standards](#) application.

The present document may be made available in electronic versions and/or in print. The content of any electronic and/or print versions of the present document shall not be modified without the prior written authorization of ETSI. In case of any existing or perceived difference in contents between such versions and/or in print, the prevailing version of an ETSI deliverable is the one made publicly available in PDF format on [ETSI deliver](#) repository.

Users should be aware that the present document may be revised or have its status changed, this information is available in the [Milestones listing](#).

If you find errors in the present document, please send your comments to the relevant service listed under [Committee Support Staff](#).

If you find a security vulnerability in the present document, please report it through our [Coordinated Vulnerability Disclosure \(CVD\)](#) program.

Notice of disclaimer & limitation of liability

The information provided in the present deliverable is directed solely to professionals who have the appropriate degree of experience to understand and interpret its content in accordance with generally accepted engineering or other professional standard and applicable regulations.

No recommendation as to products and services or vendors is made or should be implied.

No representation or warranty is made that this deliverable is technically accurate or sufficient or conforms to any law and/or governmental rule and/or regulation and further, no representation or warranty is made of merchantability or fitness for any particular purpose or against infringement of intellectual property rights.

In no event shall ETSI be held liable for loss of profits or any other incidental or consequential damages.

Any software contained in this deliverable is provided "AS IS" with no warranties, express or implied, including but not limited to, the warranties of merchantability, fitness for a particular purpose and non-infringement of intellectual property rights and ETSI shall not be held liable in any event for any damages whatsoever (including, without limitation, damages for loss of profits, business interruption, loss of information, or any other pecuniary loss) arising out of or related to the use of or inability to use the software.

Copyright Notification

No part may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm except as authorized by written permission of ETSI.

The content of the PDF version shall not be modified without the written authorization of ETSI.

The copyright and the foregoing restriction extend to reproduction in all media.

© ETSI 2025.
All rights reserved.

Contents

Intellectual Property Rights	4
Foreword.....	4
Executive summary	5
Modal verbs terminology.....	5
Introduction	5
1 Scope	6
2 References	6
2.1 Normative references	6
2.2 Informative references.....	7
3 Definition of terms, symbols and abbreviations.....	8
3.1 Terms.....	8
3.2 Symbols.....	10
3.3 Abbreviations	10
4 ICT power, energy and environmental parameters monitoring system.....	11
4.1 General description.....	11
4.2 Complementarity to existing site power and air-conditioning measurements.....	13
4.3 Different site cases	13
4.3.1 Simple site case.....	13
4.3.2 Complex site case	14
4.4 Measurement and monitoring description	15
4.4.0 General description.....	15
4.4.1 Internal measurements type 1 (Built-in in ICT equipment)	15
4.4.2 External measurements type 2 (external sensors) for ICT equipment	16
4.4.3 Common requirements for external (type 2) and internal (type 1) measurement	17
4.5 PEE data analysis services.....	17
Annex A (normative): Summary of mandatory monitoring / supervision information and functions.....	19
A.0 General description of mandatory monitoring / supervision information and functions tables	19
A.1 Table for ICT equipment power, energy and environmental parameters measurements	20
Annex B (informative): Summary of non-mandatory monitoring / supervision information and functions	22
B.0 General description of non mandatory monitoring / supervision information and functions tables	22
B.1 Table for ICT equipment power, energy and environmental parameters.....	23
Annex C (informative): 3GPP NR Management reference model and generic management service definitions.....	25
Annex D (informative): Bibliography.....	26
Annex E (informative): Change history	27
History	28

Intellectual Property Rights

Essential patents

IPRs essential or potentially essential to normative deliverables may have been declared to ETSI. The declarations pertaining to these essential IPRs, if any, are publicly available for **ETSI members and non-members**, and can be found in ETSI SR 000 314: *"Intellectual Property Rights (IPRs); Essential, or potentially Essential, IPRs notified to ETSI in respect of ETSI standards"*, which is available from the ETSI Secretariat. Latest updates are available on the [ETSI IPR online database](https://standards.itsc.ai).

Pursuant to the ETSI Directives including the ETSI IPR Policy, no investigation regarding the essentiality of IPRs, including IPR searches, has been carried out by ETSI. No guarantee can be given as to the existence of other IPRs not referenced in ETSI SR 000 314 (or the updates on the ETSI Web server) which are, or may be, or may become, essential to the present document.

Trademarks

The present document may include trademarks and/or tradenames which are asserted and/or registered by their owners. ETSI claims no ownership of these except for any which are indicated as being the property of ETSI, and conveys no right to use or reproduce any trademark and/or tradename. Mention of those trademarks in the present document does not constitute an endorsement by ETSI of products, services or organizations associated with those trademarks.

DECT™, **PLUGTESTS™**, **UMTS™** and the ETSI logo are trademarks of ETSI registered for the benefit of its Members. **3GPP™**, **LTE™** and **5G™** logo are trademarks of ETSI registered for the benefit of its Members and of the 3GPP Organizational Partners. **oneM2M™** logo is a trademark of ETSI registered for the benefit of its Members and of the oneM2M Partners. **GSM®** and the GSM logo are trademarks registered and owned by the GSM Association.

Foreword

This ETSI Standard (ES) has been produced by ETSI Technical Committee Environmental Engineering (EE).

The present document is part 12 of a multi-part deliverable covering monitoring and control interface for infrastructure equipment (power, cooling and building environment systems used in telecommunication networks), as identified below:

- Part 1: "Generic Interface";
- Part 2: "DC power system control and monitoring information model";
- Part 3: "AC UPS power system control and monitoring information model";
- Part 4: "AC distribution power system control and monitoring information model";
- Part 5: "AC diesel back-up generator system control and monitoring information model";
- Part 6: "Air Conditioning System control and monitoring information model";
- Part 7: "Other utilities system control and monitoring information model";
- Part 8: "Remote Power Feeding System control and monitoring information model";
- Part 9: "Alternative Power Systems";
- Part 10: "AC inverter power system control and monitoring information model";
- Part 11: "Battery system with integrated control and monitoring information model";
- Part 12: "ICT equipment power, energy and environmental parameters monitoring information model".**