

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Rotating electrical machines –
Part 22: AC generators for reciprocating internal combustion (RIC) engine driven
generating sets**

**Machines électriques tournantes –
Partie 22: Génératrices à courant alternatif pour groupes électrogènes entraînés
par un moteur à combustion interne**



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2009 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland
Email: inmail@iec.ch
Web: www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: www.iec.ch/searchpub

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: www.iec.ch/online_news/justpub

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: www.iec.ch/webstore/custserv

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: csc@iec.ch

Tel.: +41 22 919 02 11

Fax: +41 22 919 03 00

A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

- Catalogue des publications de la CEI: www.iec.ch/searchpub/cur_fut-f.htm

Le Catalogue en-ligne de la CEI vous permet d'effectuer des recherches en utilisant différents critères (numéro de référence, texte, comité d'études,...). Il donne aussi des informations sur les projets et les publications retirées ou remplacées.

- Just Published CEI: www.iec.ch/online_news/justpub

Restez informé sur les nouvelles publications de la CEI. Just Published détaille deux fois par mois les nouvelles publications parues. Disponible en-ligne et aussi par email.

- Electropedia: www.electropedia.org

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International en ligne.

- Service Clients: www.iec.ch/webstore/custserv/custserv_entry-f.htm

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions, visitez le FAQ du Service clients ou contactez-nous:

Email: csc@iec.ch

Tél.: +41 22 919 02 11

Fax: +41 22 919 03 00

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Rotating electrical machines –
Part 22: AC generators for reciprocating internal combustion (RIC) engine driven
generating sets**

**Machines électriques tournantes –
Partie 22: Génératrices à courant alternatif pour groupes électrogènes entraînés
par un moteur à combustion interne**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

PRICE CODE
CODE PRIX

R

ICS 29.160

ISBN 978-2-88910-020-0

CONTENTS

FOREWORD.....	3
1 Scope.....	5
2 Normative references.....	5
3 Terms and definitions	5
4 Rating.....	9
5 Limits of temperature and temperature rise	10
5.1 Base continuous rating	10
5.2 Peak continuous rating	10
6 Parallel operation.....	10
6.1 General	10
6.2 Effect of electromechanical vibration and its frequency.....	11
7 Special load conditions	11
7.1 General	11
7.2 Unbalanced load current	11
7.3 Sustained short-circuit current (see also 8.3)	11
7.4 Occasional excess current capability.....	11
7.5 Total harmonic distortion (THD).....	11
7.6 Radio interference suppression.....	12
8 Asynchronous generators with excitation equipment.....	12
8.1 General	12
8.2 Rated speed and rated slip.....	12
8.3 Sustained short-circuit current	12
8.4 Range of voltage setting (see also 3.9)	12
8.5 Parallel operation (see also Clause 6).....	12
9 Operating limit values	12
10 Rating plate	13
Annex A (informative) AC generator transient voltage characteristic following a sudden change in load	15
Bibliography.....	20
Figure A.1 – Generator transient voltage versus time for sudden load application and removal: r.m.s. voltage versus time	17
Figure A.2 – Generator transient voltage versus time for sudden load applications: instantaneous voltage versus time.....	18
Figure A.3 – Performance curves (step loading) ($\cos \phi \leq 0,4$)	19
Table 1 – Operating limit values	13

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ROTATING ELECTRICAL MACHINES –

**Part 22: AC generators for reciprocating internal combustion (RIC)
engine driven generating sets**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60034-22 has been prepared by IEC technical committee 2: Rotating machinery.

This second edition cancels and replaces the first edition published in 1996 and constitutes a technical revision.

The technical changes with regard to the previous edition include:

- Clause 2: The standards which were not referenced in the text have been deleted.
- Clause 3: Technical and editorial changes to many of the definitions have been made.
- Clause 4: In the NOTE, the quantity T_L has been replaced by TL .
- Clause 7: Technical and editorial changes to many clauses have been made.
- Clause 9: Table 1 has been revised.
- Annex A: This annex has been revised.

The text of this standard is based on the following documents:

FDIS	Report on voting
2/1568/FDIS	2/1573/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of IEC 60034 series, under the general title, *Rotating electrical machines*, can be found on the IEC website.

NOTE A table of cross-references of all IEC TC 2 publications can be found in the IEC TC 2 dashboard on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

Sample Document

get full document from standards.iteh.ai

ROTATING ELECTRICAL MACHINES –

Part 22: AC generators for reciprocating internal combustion (RIC) engine driven generating sets

1 Scope

This part of IEC 60034 establishes the principal characteristics of a.c. generators under the control of their voltage regulators when used for reciprocating internal combustion (RIC) engine driven generating set applications and supplements the requirements given in IEC 60034-1. It covers the use of such generators for land and marine use, but excludes generating sets used on aircraft or used to propel land vehicles and locomotives.

NOTE 1 For some specific applications (e.g. essential hospital supplies, high-rise buildings, etc.) supplementary requirements may be necessary. The provisions of this standard should be regarded as a basis for such requirements.

NOTE 2 Attention is drawn to the need to take note of additional regulations or requirements imposed by various regulatory bodies. Such regulations or requirements may form the subject of agreement between the customer and the manufacturer when conditions of use of the end product invoke such requirements.

NOTE 3 Examples of regulatory authorities:

- classification societies, for generating sets used on ships and offshore installations;
- government agencies;
- inspection agencies, local utilities, etc.

Annex A discusses the behaviour of generators covered by this standard when subjected to sudden load changes.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60034-1:2004, *Rotating electrical machines – Part 1: Rating and performance*

IEC 60085, *Electrical insulation – Thermal evaluation and designation*

CISPR 11, *Industrial, scientific and medical equipment – Radio-frequency disturbance characteristics – Limits and methods of measurement*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply:

NOTE 1 In this standard, suffix “N” is used for “rated” in accordance with IEC 60027-1 and IEC 60027-4 whereas in ISO 8528, suffix “r” is so used.

NOTE 2 Voltage terms relate to a generator running at constant (rated) speed under the control of the normal excitation and voltage control system.

3.1

rated output

S_N

the product of the rated r.m.s. voltage, the rated r.m.s. current and a constant m , expressed in volt-amperes (VA) or its decimal multiples

where

$m = 1$ for single-phase;

$m = \sqrt{2}$ for two-phase;

$m = \sqrt{3}$ for three-phase

3.2

rated active power

P_N

the product of the rated r.m.s. voltage, the in-phase component of the rated r.m.s. current and a constant m , expressed in watts (W) or its decimal multiples

where

$m = 1$ for single-phase;

$m = \sqrt{2}$ for two-phase;

$m = \sqrt{3}$ for three-phase

3.3

rated power factor

$\cos \phi_N$

the ratio of the rated active power to the rated output

$$\cos \phi_N = \frac{P_N}{S_N}$$

3.4

rated reactive power

Q_N

the geometrical difference of the rated apparent power and the rated active power expressed in volt-amperes reactive (var) or its decimal multiples

$$Q_N = \sqrt{(S_N^2 - P_N^2)}$$

3.5

rated speed of rotation

n_N

the speed of rotation necessary for voltage generation at rated frequency

NOTE 1 For a synchronous generator, the rated speed of rotation is given by:

$$n_N = \frac{f_N}{p}$$

where

p is the number of pole pairs;

f_N is the rated frequency (according to load requirements).

For an asynchronous generator the rated speed of rotation is given by:

$$n_N = \frac{f_N}{p} (1 - s_N)$$

where

p is the number of pole pairs;

f_N is the rated frequency (according to load requirements);

s_N is the rated slip.

NOTE 2 Since the slip of an asynchronous generator is always negative, the rated speed is above the synchronous speed.

3.6

rated slip

s_N

the difference between the synchronous speed and the rated speed of the rotor divided by the synchronous speed, when the generating set is giving its rated active power

$$s_N = \frac{\frac{f_N}{p} - n_N}{\frac{f_N}{p}}$$

NOTE Rated slip s_N is only relevant to an asynchronous generator.

3.7

rated voltage

U_N

the line-to-line voltage at the terminals of the generator at rated frequency

NOTE Rated voltage is the voltage assigned by the manufacturer for operating and performance characteristics.

3.8

no-load voltage

U_0

the line-to-line voltage at the terminals of the generator at rated frequency and no-load

3.9

range of voltage setting

ΔU_s

the range of possible upward and downward adjustment of voltage at generator terminals (ΔU_{sup} and ΔU_{sdo} , where U_{sup} is the upper limit of voltage setting and U_{sdo} is the lower limit of voltage setting) at rated frequency, for all loads between no-load and rated output.

$$\Delta U_s = |\Delta U_{sup}| + |\Delta U_{sdo}|$$

The voltage setting range is expressed as a percentage of the rated voltage.

a) upward range, ΔU_{sup}

$$\Delta U_{sup} = \frac{U_{sup} - U_N}{U_N} \times 100 \%$$

b) downward range, ΔU_{sdo}

$$\Delta U_{sdo} = \frac{U_{sdo} - U_N}{U_N} \times 100 \%$$

3.10

steady-state voltage tolerance band

ΔU ¹⁾

the agreed voltage band about the steady-state voltage that the voltage may reach within a given voltage recovery time after a specified sudden increase or decrease of load

3.11

steady-state voltage regulation

ΔU_{st} ¹⁾

the change in steady-state voltage for all load changes between no-load and rated output, taking into account the influence of temperature but not considering the effect of quadrature current compensation voltage droop.

NOTE The initial set voltage is usually rated voltage, but may be anywhere within the range of voltage setting, ΔU_s . See 3.9.

The steady-state voltage regulation is expressed as a percentage of the rated voltage.

$$\Delta U_{st} = \frac{U_{st,max} - U_{st,min}}{U_N} \times 100\%$$

3.12

transient voltage regulation

δ_{dynU}

the maximum voltage change following a sudden change of load, expressed as a percentage of the rated voltage.

- a) With load increase

maximum transient voltage drop δ_{dynU}^-

the voltage drop when the generator, initially at rated voltage, is switched onto a symmetrical load which absorbs a specified current at rated voltage at a given power factor or range of power factors.

$$\delta_{dynU}^- = \frac{U_{dyn,min} - U_N}{U_N} \times 100\%$$

- b) With load decrease

maximum transient voltage rise δ_{dynU}^+

the voltage rise when a specified load at a given power factor is suddenly switched off.

$$\delta_{dynU}^+ = \frac{U_{dyn,max} - U_N}{U_N} \times 100\%$$

3.13

voltage recovery time

t_{rec} ¹⁾

the time interval from the time at which a load change is initiated (t_0) until the time when the voltage returns to and remains within the specified steady-state voltage tolerance band ($t_{u, in}$)

$$t_{rec} = (t_{u, in}) - (t_0)$$

1) For an explanation of these terms and examples of their use, see Annex A.

3.14**recovery voltage U_{rec}** ²⁾

the final steady-state voltage for a specified load condition

NOTE Recovery voltage is normally expressed as a percentage of the rated voltage. For loads in excess of rated, recovery voltage is limited by saturation and exciter-regulator field forcing capability.

3.15**voltage modulation** **$\hat{U}_{\text{mod}}$**

the quasi-periodic voltage variation (peak-to-valley) about a steady-state voltage having typical frequencies below the fundamental generation frequency expressed as a percentage of average peak voltage at rated frequency and uniform drive

$$\hat{U}_{\text{mod}} = 2 \times \frac{\hat{U}_{\text{mod: max}} - \hat{U}_{\text{mod: min}}}{\hat{U}_{\text{mod: max}} + \hat{U}_{\text{mod: min}}} \times 100 \%$$

3.16**voltage unbalance** **U_{ubal}**

the rms value of the unbalanced phase voltages between consecutive phases in a three-phase system that may occur.

Voltage unbalance is expressed as a percentage of the mean voltage

$$\hat{U}_{\text{ubal}} = \frac{\hat{U}_{\text{max}} - \hat{U}_{\text{mean}}}{\hat{U}_{\text{mean}}} \times 100 \%$$

3.17**voltage regulation characteristics**

curves of terminal voltage as a function of load current at a given power factor under steady-state conditions at rated speed without any manual adjustment of the voltage regulation system

3.18**relative thermal life expectancy factor** **TL**

the relative thermal life expectancy related to the thermal life expectancy in case of duty type S1 with rated output (see Annex A of IEC 60034-1)

4 Rating

The generator rating class shall be specified in accordance with IEC 60034-1. In the case of generators for RIC engine driven generating sets, continuous ratings (duty type S1) or ratings with discrete constant loads (duty type S10) are applicable.

For the purpose of this standard, the maximum continuous rating based on duty type S1 is named the base continuous rating (BR).

Additionally, for duty type S10, there is a peak continuous rating (PR), where the permissible generator temperature rises are increased by a specific amount according to the thermal classification.

NOTE In the case of duty type S10, operation at the peak continuous rating (PR) thermally ages the generator insulation systems at an increased rate. Quantity TL for the relative thermal life expectancy of the insulation system is therefore an important integral part of the rating class (see 4.2.10 of IEC 60034-1).

²⁾ For an explanation of these terms and examples of their use, see Annex A.

5 Limits of temperature and temperature rise

5.1 Base continuous rating

The generator shall be capable of delivering its base continuous rating (BR) over the whole range of operating conditions (e.g. minimum to maximum coolant temperatures) with total temperatures not exceeding the sum of 40 °C and the temperature rises specified in Table 6 of IEC 60034-1. See Note 1 below.

5.2 Peak continuous rating

At the generator peak continuous rating (PR), the total temperatures may be increased by the following allowances (see Notes 1 and 2).

Thermal classification in accordance with IEC 60085	Rating <5 MVA	Rating ≥5 MVA
A or E	15 °C	10 °C
B or F	20 °C	15 °C
H	25 °C	20 °C

For ambient temperatures below 10 °C, the limit of total temperature shall be reduced by 1 °C for each °C by which the ambient temperature is below 10 °C.

NOTE 1 The RIC engine output may vary with changes of ambient air temperature. In operation, the generator total temperature will depend upon its primary coolant temperature which is not necessarily related to the RIC engine inlet air temperature.

NOTE 2 When the generator operates at these higher temperatures, the generator insulation system will age thermally at between 2 to 6 times the rate which occurs at the generator base continuous rating temperature rise values (depending on the temperature increase and specific insulation system). For example, the thermal ageing relevant to operation for 1 h at peak continuous rating is approximately equal to that obtained with operation for 2 h to 6 h at base continuous rating. It is essential that the value of T_L be determined by the manufacturer and marked on the rating plate in accordance with item b) of Clause 10.

6 Parallel operation

6.1 General

When running in parallel with other generator sets or with another source of supply, means shall be provided to ensure stable operation and correct sharing of reactive power.

This is most often effected by influencing the automatic voltage regulator by a sensing circuit with an additional reactive current component. This causes a voltage droop characteristic for reactive loads.

The grade of quadrature current compensation (QCC) voltage droop δ_{qcc} is the difference between the no-load voltage U_0 and the voltage at the rated current at the power factor zero (overexcited) U_Q when running isolated, expressed as a percentage of rated voltage U_N .

$$\delta_{qcc} = \frac{U_0 - U_Q}{U_N} \times 100 \%$$

NOTE 1 Unity power factor loads produce virtually no droop.

NOTE 2 Identical a.c. generators with identical excitation systems may operate in parallel without requiring voltage droop when their field windings are connected by equalizer links. Adequate reactive load sharing is achieved when there is correct active load sharing.