



IEC 60079-0

Edition 8.0 2026-06

INTERNATIONAL STANDARD

REDLINE VERSION

Explosive atmospheres -
Part 0: Equipment - General requirements

Sample Document

get full document from standards.iteh.ai



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2026 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Secretariat
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search -

webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews, graphical symbols and the glossary. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 500 terminological entries in English and French, with equivalent terms in 25 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD	8
1 Scope	18
2 Normative references	20
3 Terms and definitions	22
4 Equipment grouping	46
4.1 General	46
4.2 Group I	46
4.3 Group II	46
4.4 Group III	46
4.5 Equipment for a particular explosive gas atmosphere	47
5 Temperatures	47
5.1 Environmental influences	47
5.1.1 Ambient temperature	47
5.1.2 External source of heating or cooling	48
5.2 Service temperature	48
5.3 Maximum surface temperature	48
5.3.1 Determination of maximum surface temperature	48
5.3.2 Limitation of maximum surface temperature	49
5.3.3 Small component temperature for Group I or Group II electrical equipment	50
5.3.4 Component temperature of smooth surfaces for Group I or Group II equipment	51
6 Requirements for all equipment	52
6.1 General	52
6.2 Mechanical strength of equipment	52
6.3 Opening times	52
6.4 Circulating currents in enclosures (e.g. of large electric machines)	53
6.5 Gasket retention	53
6.6 Electromagnetic and ultrasonic energy radiating equipment	54
6.6.1 General	54
6.6.2 Radio frequency sources	54
6.6.3 Ultrasonic sources	55
6.6.4 Lasers, luminaires, and other non-divergent continuous wave optical sources	55
7 Non-metallic enclosures and non-metallic parts of enclosures	56
7.1 General	56
7.1.1 Applicability	56
7.1.2 Specification of materials	56
7.2 Thermal endurance	57
7.2.1 Tests for thermal endurance	57
7.2.2 Material selection	57
7.2.3 Alternative qualification of elastomeric sealing O-rings	58
7.3 Resistance to ultraviolet light	58
7.4 Electrostatic charges on external non-metallic materials	59
7.4.1 Applicability	59
7.4.2 Avoidance of a build-up of electrostatic charge for Group I, Group II, or Group III	60

7.5	Attached external conductive parts	68
7.6	Electrostatic charges of cable sheaths	69
8	Metallic enclosures and metallic parts of enclosures.....	69
8.1	Material composition	69
8.2	Group I	70
8.3	Group II	70
8.4	Group III	70
8.5	Copper Alloys	71
9	Fasteners	71
9.1	General requirements for fasteners	71
9.2	Special fasteners	71
9.2.1	General	71
9.2.2	Holes for special fasteners	72
9.4	Hexagon socket set screws	72
10	Interlocking devices	73
11	Bushings	73
12	(Reserved for future use).....	74
13	Ex Components	74
13.1	General.....	74
13.2	Mounting.....	74
13.3	Internal mounting	74
13.4	External mounting	74
13.5	Ex Component certificate	74
14	Connection facilities	75
14.1	General.....	75
14.2	Type of Protection.....	75
14.3	Creepage and clearance	75
15	Connection facilities for earthing or bonding conductors	75
15.1	Equipment requiring earthing or bonding.....	75
15.1.1	Internal earthing	75
15.1.2	External bonding	75
15.1.3	Electrostatic bonding	76
15.2	Equipment not requiring earthing	76
15.3	Size of protective earthing conductor connection	76
15.4	Size of equipotential bonding conductor connection	76
15.5	Protection against corrosion.....	76
15.6	Secureness of electrical connections	77
15.7	Internal earth continuity plate.....	77
16	Entries into enclosures	77
16.1	General.....	77
16.2	Identification of entries.....	77
16.3	Cable glands.....	77
16.4	Blanking Elements	78
16.5	Thread adapters	78
16.6	Temperature at the entry point and the branching point of conductors	78
16.7	Electrostatic charges of cable sheaths	78
17	Supplementary requirements for electric machines	80
17.1	General.....	80

17.2	Ventilation and cooling	80
17.2.1	Ventilation Openings	80
17.2.2	Materials for External fans	80
17.2.3	Auxiliary motor cooling fans	81
17.2.4	Room ventilating fans	81
17.3	Bearings	82
18	Supplementary requirements for switchgear	83
18.1	Flammable dielectric	83
18.2	Disconnectors	83
18.3	Group I – Provisions for locking	83
18.4	Doors and covers	83
19	Reserved for future use Supplementary requirements for factory wiring between enclosures	84
20	Supplementary requirements for external plugs, socket-outlets and connectors for field wiring connection appliance inlets	84
20.1	General	84
20.2	Explosive gas atmospheres	85
20.3	Explosive dust atmospheres	85
20.4	Energized plugs	85
21	Supplementary requirements for luminaires	85
21.1	General	85
21.2	Covers for luminaires of EPL Mb, EPL Gb, or EPL Db	86
21.3	Covers for luminaires of EPL Gc or EPL Dc	86
21.4	Sodium lamps	86
21.5	Replacement lamps	87
22	Supplementary requirements for caplights and handlights	87
22.1	Group I caplights	87
22.2	Group II and Group III caplights and handlights	87
23	Equipment incorporating cells and batteries	87
23.1	General	87
23.2	Interconnection of cells to form batteries	87
23.3	Cell types Electrochemical systems of cells and batteries	87
23.4	Cells in a battery	90
23.5	Ratings of batteries	90
23.6	Interchangeability	90
23.7	Prohibition of charging of primary batteries	90
23.8	Leakage	90
23.9	Connections	91
23.10	Orientation	91
23.11	Replacement of cells or batteries	91
23.12	Replaceable battery pack	91
24	Documentation	91
24.1	Schedule drawings	91
24.2	Related drawings	91
25	Compliance of prototype or sample with documents	92
26	Type tests	92
26.1	General	92
26.2	Test configuration	92

26.3	Tests in explosive test mixture	92
26.4	Tests of enclosures	92
26.4.1	Order of tests	92
26.4.2	Resistance to impact	94
26.4.3	Drop test	97
26.4.4	Acceptance criteria	98
26.4.5	Degree of protection (IP Code) by enclosures	98
26.5	Thermal tests	99
26.5.1	Temperature measurement	99
26.5.2	Thermal shock test	102
26.5.3	Small component ignition test (Group I and Group II)	103
26.6	Torque test for bushings	104
26.6.1	Test procedure	104
26.6.2	Acceptance criteria	104
26.7	Non-metallic enclosures or non-metallic parts of enclosures	105
26.7.1	General	105
26.7.2	Test temperatures	105
26.8	Thermal endurance to heat	105
26.9	Thermal endurance to cold	106
26.10	Resistance to UV light	106
26.10.1	General	106
26.10.2	Light exposure	107
26.10.3	Acceptance criteria	107
26.11	Resistance to chemical agents for Group I equipment	107
26.12	Earth continuity	108
26.13	Surface resistance test of parts of enclosures of non-metallic materials	109
26.14	Measurement of capacitance	111
26.14.1	General	111
26.14.2	Test procedure	111
26.15	Verification of ratings of ventilating fans	112
26.16	Alternative qualification of elastomeric sealing O-rings	112
26.17	Transferred charge test	113
26.17.1	Test equipment	113
26.17.2	Test sample	116
26.17.3	Test procedure	117
27	Routine tests	118
28	Manufacturer's responsibility	119
28	Certificate	119
29	Marking	119
29.1	Applicability	119
29.2	Location	119
29.3	General	120
29.4	Ex marking for explosive gas atmospheres	121
29.5	Ex marking for explosive dust atmospheres	123
29.6	Combined Types (or Levels) of Protection	126
29.7	Multiple Types of Protection	126
29.8	Ga equipment using two independent Gb Types (or Levels) of Protection	127
29.9	Boundary wall	127

29.10	Ex Components	127
29.11	Small Ex Equipment and small Ex Components	128
29.12	Extremely small Ex Equipment and extremely small Ex Components	128
29.13	Alternative marking of Ex Equipment and Ex Components using digital technology	129
29.14	Warning markings	129
29.15	Cells and batteries	129
29.16	Electric machines operated with supplied by a converter	130
29.17	Examples of marking	130
30	Instructions	135
30.1	General	135
30.2	Cells and batteries	136
30.3	Electric machines	137
30.4	Ventilating fans	138
30.5	Cable glands	138
Annex A	(normative) Supplementary requirements for cable glands and cable transit devices	139
A.1	General	139
A.2	Constructional requirements	140
A.2.1	Cable sealing	140
A.2.2	Filling compounds	140
A.2.3	Clamping	140
A.2.4	Lead-in of cable	141
A.2.5	Release by a tool	141
A.2.6	Fixing	141
A.2.7	Degree of protection (IP Code) rating	141
A.3	Type tests	142
A.3.1	Tests of clamping of non-armoured and braided cables	142
A.3.2	Tests of clamping of armoured cables	145
A.3.3	Type test for resistance to impact	146
A.3.4	Test for degree of protection (IP Code) rating of cable glands	147
A.4	Marking	148
A.4.1	Marking of cable glands	148
A.4.2	Identification of cable-sealing rings	148
A.5	Instructions	149
Annex B	(normative) Requirements for Ex Components	150
Annex C	(informative) Example of rig for resistance to impact test	153
Annex D	(informative) Electric machines connected to converters supplied by a converter	154
Annex E	(informative) Temperature evaluation of electric machines	155
Annex F	(informative) Guidance flowchart for tests of non-metallic enclosures or non-metallic parts of enclosures (26.4)	158
Annex G	(informative) Guidance flowchart for tests of cable glands	161
Annex H	(informative) Shaft voltages resulting in motor bearing or shaft brush sparking discharge energy calculation	163
H.1	General	163
H.2	Assessment of the risk possibility of ignition using ignition energy calculation	163
H.3	Shaft voltage determination for a rotating machine	164
H.4	Capacitance "C" calculation for a rotating machine	165

H.5	Energy "E" calculation for a rotating machine	167
H.6	Assessment using reference curves	167
	Bibliography	169
Figure 1	– Typical battery examples	24
Figure 2	– Typical battery compartment	26
Figure 3	– Typical replaceable battery pack	27
Figure 4	– Shield with electrostatic bonding	65
Figure 5	– Cylindrical shield with electrostatic bonding	65
Figure 6	– Tolerances and clearance for threaded fasteners	72
Figure 7	– Contact surface under head of fastener with a reduced shank	73
Figure 8	– Cable gland	79
Figure 9	– Conduit entry	79
Figure 10	– Assembly of test sample for earth-continuity test	109
Figure 11	– Test piece with painted electrodes	110
Figure 12	– Compression set of an O-ring	112
Figure 13	– Example of non-oscillating pulse trace (1)	114
Figure 14	– Example of faulty oscillating pulse trace (1)	114
Figure 15	– Shunt with four parallel resistors	115
Figure 16	– Schematic drawing of the method shunt and oscilloscope	115
Figure 17	– Zero-line trace (1) with low noise	116
Figure A.1	– Illustration of the terms used for cable glands Cable sealing and clamping	140
Figure A.2	– Rounded edge of the point of entry of the flexible cable	141
Figure A.3	– Example of a seal with multiple openings	142
Figure A.4	– Example of rig for resistance to impact test	147
Figure C.1	– Example of rig for resistance to impact test	153
Figure F.1	– Non-metallic enclosures or non-metallic parts of enclosures	160
Figure G.1	– Guidance flowchart for tests of cable glands	162
Figure H.1	– Capacitance stored in bearing clearance of sleeve bearing between journal and outer bearing housing	166
Figure H.2	– Air-gap between stator and rotor	166
Figure H.3	– Typical surfaces that form capacitors from the motor shaft to ground earth	167
Figure H.4	– Capacitive ignition curves	168
Table 1 – Ambient temperatures in service and additional marking		
Table 1	– Classification of maximum surface temperatures Group II electrical equipment	49
Table 2	– Assessment of temperature classification according to component size	51
Table 3	– Assessment of temperature classification Component surface area $\geq 20 \text{ mm}^2$	51
Table 4	– Threshold power	54
Table 5	– Threshold energy	54
Table 6	– Limitation of surface areas	65
Table 7	– Maximum diameter or width	66
Table 8	– Limitation of thickness of non-metallic layer	66

Table 9 – Maximum transferred charge	66
Table 10 – Maximum capacitance of unearthed conductive parts	69
Table 11 – Minimum cross-sectional area of PE conductors	76
Table 12 – Primary cells	88
Table 13 – Secondary cells	89
Table 14 – Tests for resistance to impact Impact tests	96
Table 15 – Torque to be applied to the stem of bushing used for connection facilities	104
Table 16 – Thermal endurance test	105
Table 17 – Thermal endurance tests – personal or portable equipment	106
Table 18 – Text of warning markings	129
Table 19 – Example of type-test converter parameters	137
Table B.1 – Applicability of clauses to Ex Components	150
Table H.1 – Maximum permitted energy	164

Sample Document

get full document from standards.iteh.ai

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**Explosive atmospheres -
Part 0: Equipment - General requirements**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 60079-0 has been prepared by IEC technical committee 31: Equipment for explosive atmospheres. It is an International Standard.

This eighth edition cancels and replaces the seventh edition, published in 2017. This edition constitutes a technical revision.

Users of this document are advised that interpretation sheets clarifying the interpretation of this document can be published. Interpretation sheets are available from the IEC webstore and can be found in the "history" tab of the page for each document.

The significance of the changes between IEC 60079-0:2017 (Edition 7) and IEC 60079-0:— (Edition 8) are as listed below:

Explanation of the significance of the changes	Clause	Type		
		Minor and editorial changes	Extension	Major technical changes
<i>Equipment</i> replaced by <i>Ex Equipment</i> where appropriate	General	X		
<i>Electrical equipment</i> replaced by <i>equipment</i> where appropriate	General	X		
Use of term <i>degree of protection (IP Code)</i> reviewed throughout the document for consistency	General	X		
Clarify the use of <i>volume fraction</i> terms	General	X		
Clarified the <i>documentation</i> is more clearly specified as <i>schedule drawings</i> .	General	X		
Added NOTE 4 to address short-term thermal excursions	1	X		
IEC TS 60079-46 added	1	X		
IEC TS 60079-47 is added	1	X		
IEC 62784 is added	1	X		
ISO 80079-37 is added	1	X		
IEC 60079-20-1 is replaced by ISO/IEC 80079-20-1	2	X		
IEC 60243-2 is added	2	X		
Admitted term <i>minimum ignition temperature of an explosive gas atmosphere</i> added. Standard number corrected	3.6	X		
Definition for <i>reverse charging</i> clarified	3.7.10	X		
Figure added to typical <i>battery compartment</i>	3.7.14			
Definition for <i>brush discharge</i> added	3.8	X		
Definition for <i>bushing</i> clarified to be an insulating device	3.10	X		
Note 1 to entry for <i>certificate</i> revised to use declaration, acceptance, and certification terms in accordance with ISO/IEC 17000	3.13	X		
Note 1 to entry for <i>coating</i> added to clarify application in standards for explosive atmospheres	3.14	X		
Definition for <i>continuous operating temperature</i> revised to show that it is a manufacturer defined property. Added admitted term <i>continuous service temperature</i>	3.21	X		
Term <i>comparable converter</i> added along with domain <for use with electric machines> added	3.22.2	X		
Definition for dust clarified along with Note 1 to entry	3.25	X		
Note 2 to entry for <i>conductive dust</i> added to clarify how metal dust is considered	3.25.2	X		
Term <i>electrostatic bonding</i> along with admitted terms <i>electrostatic bonded</i> and <i>electrostatically bonded</i> added	3.30	X		
Note 1 to entry for <i>portable equipment</i> clarified to include equipment that is carried, but intended to be hand-held when in use	3.33.5	X		
Term <i>EPL G-</i> added	3.35.7	X		
Term <i>EPL D-</i> added	3.35.11	X		
Term and definition for <i>explosion-protected</i> added	3.36	X		
Definition for <i>Ex Component</i> clarified	3.39	X		

Explanation of the significance of the changes	Clause	Type		
		Minor and editorial changes	Extension	Major technical changes
Definition for <i>Ex Component Enclosure</i> added	3.40	X		
Definition for <i>explosive atmosphere</i> revised to include mist in accordance with IEC 60079-10-1	3.42	X		
Note 1 to entry for <i>free space</i> clarified to address space in components	3.48	X		
Term and definition for <i>insulation coordination</i> added from IEC 60050-442-09-01	3.55	X		
Term and definition for <i>isolated circuit</i> added	3.55.1	X		
Term and definition for <i>macro-environment</i> added	3.55.2	X		
Definition for <i>mains circuit</i> clarified	3.55.3	X		
Note 2 to entry for <i>mains supply</i> clarified to address transients	3.55.4	X		
Term and definition for <i>micro-environment</i> added	3.55.5	X		
Term and definition for <i>overvoltage category</i> relocated to part of <i>insulation coordination</i>	3.55.6	X		
Term and definition for <i>pollution</i> added	3.55.7	X		
Term and definition for <i>pollution degree category</i> relocated to part of <i>insulation coordination</i>	3.55.8	X		
Term and definition for <i>local temperature</i> relocated from Table 3	3.59	X		
Definition for <i>propagating brush discharge</i> revised for clarity	3.67	X		
Term and definition for <i>Schedule of Limitations</i> added	3.79	X		
Definition for <i>special fasteners</i> revised to clarify they are used when a Type of Protection requires them	3.85	X		
Term and definition for <i>Specific Conditions of Use</i> added	3.86	X		
Term and definition for <i>supercapacitor</i> , including admitted term <i>electrochemical capacitor</i> added from IEC 60050-114-03-03	3.87	X		
Term and definition for "X" clarified. Note 2 to entry added to show that these are in addition to requirements for the installation design, selection, erection, inspection, maintenance, repair, and overhaul requirements	3.89	X		
General term <i>wiring</i> added	3.99	X		
Term and definition added for <i>field wiring</i>	3.99.1	X		
Term and definition added for <i>factory wiring</i>	3.99.2	X		
Term and definition added for <i>factory wiring within enclosures</i>	3.99.2.1	X		
Term and definition added for <i>factory wiring between enclosures</i>	3.99.2.2	X		
Term and definition for <i>worst-case</i> , including admitted terms <i>most unfavourable</i> and <i>most onerous</i> added	3.101	X		
Clarified that Equipment Groups is the correct term in accordance with the TC31 Good Working Practice	4.1	X		
Clarified the situation when equipment is evaluated for a particular gas atmosphere.	4.5	X		
The ambient temperature range is now a required marking. Where there are multiple ambient temperature range, and it is impractical to include all	5.1.1			C1

Explanation of the significance of the changes	Clause	Type		
		Minor and editorial changes	Extension	Major technical changes
the ranges in the marking, a Specific Condition Use is used to provide the information.				
Clarified that the dust thickness is considered a layer	5.2	X		
Clarified the marking for Da uses the temperature marking prefix T ₂₀₀	5.3.2.3.1	X		
Clarified the marking for Db	5.3.2.3.2	X		
Clarified the small component temperature requirements for where the electrical connection leads or thermal heat transfer connections are integrated into the body of part	5.3.3		X	
Clarified the application of the safety margin	5.3.4	X		
Added NOTE 3 to caution about cyber security risk	6.1	X		
Clarified the requirement for general fasteners in accordance with 9.1	6.2	X		
Clarified that the limit could be a temperature class or a maximum surface temperature	6.3	X		
Clarified that this sub-clause applies to large electric machines	6.4	X		
Clarified the requirements for a gasket adhesive	6.5	X		
Added NOTES 2 and 3, and deleted 6.6.3 to clarify the applicability for the standard to optical radiation	6.6.1	X		
Clarified applicability of user-controlled limit settings	6.6.1	X		
Included material specifications for other than plastics, elastomers, and cements	7.1.2.5		X	
Clarified in a NOTE why there are no requirements for minimum COT specification	7.2.2	X		
Introduced a reduced margin for TI or RTI of battery powered portable or personal equipment.	7.2.2		X	
Clarified protection from UV damage	7.3	X		
Clarified applicability of electrostatic charges on external non-metallic materials	7.4.1	X		
Clarified options available to avoid electrostatic charges	7.4.2	X		
Clarified and expanded the techniques that can be used to avoid electrostatic charges	7.4.2.2		B1	
Clarified and expanded the techniques that can be used to avoid brush discharges for Group I or Group II equipment	7.4.2.3		B2	
Clarified and expanded the techniques that can be used to avoid electrostatic charges for Group III equipment	7.4.2.4		B3	
Clarified and expanded the techniques that can be used to avoid brush discharges for Group III equipment	7.4.2.4		B4	
Clarified the requirements for external conductive parts	7.5			C2
Clarified the title of 9.1 to facilitate a clear reference to these requirements from other Type of Protection standards. Relocated the hex set screw requirements	9.1	X		
Combined all of the requirements for special fasteners into 9.2	9.2	X		
Changed the former NOTE 1 to a requirement to include the temperature range as part of the Schedule of Limitations	13.5			C3

Explanation of the significance of the changes	Clause	Type		
		Minor and editorial changes	Extension	Major technical changes
Added new sub-clause on electrostatic bonding	15.1.3 15.2			C4
Clarified text to remove "for example" as metric and NPT are the only two permitted entry threads	16.2	X		
Added text to clarify the determination of branching point and entry point temperature for electric machines. This is consistent With IECEx DS/2018/002	16.6	X		
Clarified that "this standard" meant IEC 60079-34 as stated in the first paragraph	17.1	X		
Sub-clause 17.2 was reorganized to apply to ventilation and cooling. With the exception of 17.2.3, there was no intent to change requirements, only to better define for consistent application	17.2	X		
Requirements for thermal protection were added	17.2.3			C5
New clarifications for factory-wiring between enclosures	19			C6
Additional options for securing Gc or Dc connectors	20.1 c)		X	
Additional requirements for maintaining the degree of protection (IP Code) on an enclosure where an appliance inlet or socket-outlet is mounted. This is consistent with IECEx DS/2015/003	20.1			C7
Added reference to IEC 60079-17 and IEC 60079-19 for the use of replacement lamps.	21.5	X		
Added clarification that specific Type of Protection standards permit the connection of cells in parallel. This was previously a NOTE.	23.2	X		
Minor corrections to nominal voltage and maximum open-circuit voltage in accordance with latest cell standards	23.3	X		
Added Sodium Nickel Chloride cells	Table 13		X	
Added requirements for temperature considerations when using Sodium Nickel Chloride cells	23.5		X	
Clarified requirements for replacement cells or batteries	23.11	X		
Split Clause 24 into 24.1 schedule drawings and 24.2 related drawings	24	X		
Add 24.2 for related drawings	24.2	X		
Added clarification that, at the request of the manufacturer, more onerous tests than those specified may be performed.	26.1		X	
Clarified NOTE 2 to explain the logic of testing cemented joint windows	26.4.1	X		
Revise text to ensure that when the equipment is to be protected from impact or only has a low risk of mechanical danger, that the necessary information is provided to the end user via clearly worded "X" conditions.	26.4.2	X		
Clarify Table applicability to ensure consistent application	Table 14	X		
Specifically exclude non-metallic materials of glass and ceramic	26.4.3		X	
Clarify marking of degree of protection (IP Code)	26.4.5.2	A1		
Specifically exclude enclosures with no free internal volume.	26.4.5.1		X	

Explanation of the significance of the changes	Clause	Type		
		Minor and editorial changes	Extension	Major technical changes
Clarify the reasons for specifying permitted positions of equipment with respect to temperature rise, and providing that information to the end user via an "X" condition.	26.5.1.1	X		
Clarify the need to consider both maximum and minimum service temperature	26.5.1.2	X		
Add permission to consider load diversity with respect to temperature.	26.5.1.2		X	
Clarify test voltages with respect to rated voltages	26.5.1.3	X		
Add clear permission for linear correction of temperature test results from different ambient temperatures. It is recognized that this has been common practice for many years.	26.5.1.3		X	
Clarify the requirements for test dust based on material rather than thermal conductivity.	26.5.1.3	X		
Clarification of test procedure to ensure consistent results.	26.5.3.2	X		
Added NOTE to refer back to 26.1 for permission to test at more onerous test temperatures.	26.7.2	X		
Added NOTE to refer back to 26.1 for permission to test at more onerous test temperatures.	26.8	X		
Clarified Table heading to be maximum service temperature	Table 16	X		
Added new Table 17 for thermal endurance tests specific to personal and portable equipment	Table 17		X	
Surface resistance test Clarify test procedure to ensure consistent results. Any prior test results from the procedure in Edition 7 and earlier are considered equivalent to the test procedure as revised in Edition 8.	26.13	X		
Measurement of capacitance Clarify test procedure to ensure consistent results. Any prior test results from the procedure in Edition 7 and earlier are considered equivalent to the test procedure as revised in Edition 8.	26.14	X		
Transferred charge test Clarify test procedure to ensure consistent results. Any prior test results from the procedure in Edition 7 and earlier are considered equivalent to the test procedure as revised in Edition 8.	26.17		X	
Removal of the permission to use an advisory marking in place of an "X" condition.	29.3e)			C8
Clarification of marking when Ex associated equipment or associated apparatus when combined for both gas and dust atmospheres.	29.3f)	X		
Added "h", "qb", "60079-30-1", and "60079-46" to align with the markings in those IEC 60079 and ISO/IEC 80079 series standards.	29.4b)		X	
Clarification of 29.4 on how to provide temperature information when multiple ambient temperature and external source of heating and cooling are present	29.4d)	X		
Removal of the option to use an "X" condition for ambient temperature rating. It is now a required marking per Clause 5.	29.4f)		X	