

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Explosive atmospheres –
Part 26: Equipment with Equipment Protection Level (EPL) Ga**

**Atmosphères explosives –
Partie 26: Matériel d'un niveau de protection du matériel (EPL) Ga**



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2014 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

IEC Catalogue - webstore.iec.ch/catalogue

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

IEC publications search - www.iec.ch/searchpub

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 30 000 terms and definitions in English and French, with equivalent terms in 14 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

More than 55 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Catalogue IEC - webstore.iec.ch/catalogue

Application autonome pour consulter tous les renseignements bibliographiques sur les Normes internationales, Spécifications techniques, Rapports techniques et autres documents de l'IEC. Disponible pour PC, Mac OS, tablettes Android et iPad.

Recherche de publications IEC - www.iec.ch/searchpub

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire en ligne de termes électroniques et électriques. Il contient plus de 30 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans 14 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Glossaire IEC - std.iec.ch/glossary

Plus de 55 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: csc@iec.ch.

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Explosive atmospheres –
Part 26: Equipment with Equipment Protection Level (EPL) Ga**

**Atmosphères explosives –
Partie 26: Matériel d'un niveau de protection du matériel (EPL) Ga**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

PRICE CODE
CODE PRIX

Q

ICS 29.260.20

ISBN 978-2-8322-1903-4

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	3
1 Scope.....	6
2 Normative references.....	6
3 Terms and definitions	7
4 Requirements for design and construction.....	7
4.1 Protection measures against ignition hazards of the electrical circuits	7
4.1.1 General	7
4.1.2 Application of two independent Types of Protection providing EPL Gb.....	7
4.1.3 Application of a Type of Protection providing EPL Gb and a separation element	8
4.2 Equipment with moving parts	12
4.2.1 Frictional heating	12
4.2.2 Damage arising from failure of moving parts	12
4.2.3 Light metals	12
4.3 Process connection	13
5 Type tests	13
5.1 Standardized types of protection	13
5.2 Separation elements	13
5.3 Temperature evaluation.....	13
6 Marking	14
6.1 General.....	14
6.2 Examples of marking	14
7 Instructions.....	14
7.1 Separation elements:	14
7.2 Process connection:	15
7.3 EPL allocation	15
Bibliography	16
Figure 1 – Example of a partition wall with a conductor bushing considered as gas diffusion tight.....	9
Figure 2 – Example of a separation element with a cylindrical shaft joint and natural ventilation	12
Table 1 – Separation elements.....	11

INTERNATIONAL ELECTROTECHNICAL COMMISSION

EXPLOSIVE ATMOSPHERES –

**Part 26: Equipment with Equipment Protection Level
(EPL) Ga**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60079-26 has been prepared by IEC technical committee 31: Equipment for explosive atmospheres.

This third edition cancels and replaces the second edition published in 2006 and constitutes a technical revision.

This edition includes the following significant changes with respect to the previous edition:

Changes	Clause	Type		
		Minor and editorial changes	Extension	Major technical changes
Notes deleted	1	X		
Reference to associated apparatus deleted	1	X		
Additional normative references included	3	X		
Requirements against mechanical and electrostatic ignition hazards deleted (now covered in IEC 60079-0)	4.1	X		
Requirement for separation element detailed regarding external influences	4.1.3.2	X		
Intrinsic safety Ex ia as single type of protection including associated apparatus deleted (now covered by EPL)	4.2.2 (ed.2)	X		
Encapsulation Ex ma as single type of protection deleted (now covered by EPL)	4.2.3 (ed.2)	X		
Conditions a) and b) linked with an "and", therefore requirement of "flameproof joint" deleted in following clause. Both requirements already covered by separation elements and standardised process connections.	4.3	X		
Process connection requires a sufficiently tight joint: IP66 added alternatively to IP67	4.3		X	
Requirement for isolated conductive components deleted (now covered in IEC 60079-0)	4.4 (ed.2)	X		
Requirements for non-conductive enclosures deleted (now covered in IEC 60079-0)	4.5 (ed.2)	X		
Test of partition walls according to 4.1.3.2 b) is specified in more detail	5.2			C1
Marking example for associated apparatus deleted	6.2 b)	X		
Note 3 with an additional example added	6.2	X		
Specification of material of partition wall required in instructions (also required in 4.1.3.2)	7	X		
Alternative risk assessment method deleted (is now generally introduced)	AnnexA (ed.2)	X		

NOTE The technical changes referred to include the significance of technical changes in the revised IEC Standard, but they do not form an exhaustive list of all modifications from the previous version.

Explanation of the types of changes:

A) Definitions

1) Minor and editorial changes:

- Clarification
- Decrease of technical requirements
- Minor technical change
- Editorial corrections

These are changes which modify requirements in an editorial or a minor technical way. They include changes of the wording to clarify technical requirements without any technical change, or a reduction in level of existing requirement.

2) Extension: Addition of technical options

These are changes which add new or modify existing technical requirements, in a way that new options are given, but without increasing requirements for equipment that was fully compliant with the previous standard. Therefore, these will not have to be considered for products in conformity with the preceding edition.

3) Major technical changes:

- addition of technical requirements
- increase of technical requirements

These are changes to technical requirements (addition, increase of the level or removal) made in a way that a product in conformity with the preceding edition will not always be able to fulfil the requirements given in the later edition. These changes have to be considered for products in conformity with the preceding edition. For these changes additional information is provided in Clause B below.

NOTE These changes represent current technological knowledge. However, these changes should not normally have an influence on equipment already placed on the market.

B) Information about the background of 'Major technical changes'

C1: Introduction of type tests for separation elements according to "4.1.3.2 b)"

The text of this standard is based on the following documents:

FDIS	Report on voting
31/1146/FDIS	31/1155/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 60079 series, published under the general title *Explosive atmospheres*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

EXPLOSIVE ATMOSPHERES –

Part 26: Equipment with Equipment Protection Level (EPL) Ga

1 Scope

This part of IEC 60079 specifies alternative requirements for construction, test and marking for electrical equipment that provides Equipment Protection Level (EPL) Ga when single standardised Types of Protection (e.g. Ex “ia”, Ex “ma”, Ex “da”) cannot be applied. This standard also applies to equipment mounted across a boundary where different Equipment Protection Levels may be required.

EXAMPLE: Equipment installed in the wall of a storage vessel containing Zone 0 (requiring EPL Ga) inside an area defined as Zone 1 (requiring EPL Gb).

This electrical equipment, within the operational parameters specified by the manufacturer, ensures a very high Level of Protection that includes rare malfunctions related to the equipment or two malfunctions occurring independently of each other.

NOTE A malfunction may result from a failure of the component parts of the electrical equipment or from anticipated externally applied influences. Two independent malfunctions which may occur more frequently and which, separately, would not create an ignition hazard but which, in combination, could create a potential ignition hazard, are regarded as occurring together to form a rare malfunction.

This standard supplements and modifies the general requirements of IEC 60079-0. Where a requirement of this standard conflicts with a requirement of IEC 60079-0, the requirement of this standard takes precedence.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60079-0, *Explosive atmospheres – Part 0: Equipment – General requirements*

IEC 60079-1, *Explosive atmospheres – Part 1: Equipment protection by flameproof enclosures “d”*

IEC 60079-11, *Explosive atmospheres – Part 11: Equipment protection by intrinsic safety “i”*

IEC 60695-11-10, *Fire hazard testing – Part 11-10: Test flames – 50 W horizontal and vertical flame test methods*

IEC 60529, *Degrees of protection provided by enclosures (IP Code)*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 60079-0 and the following apply.

NOTE Additional definitions applicable to explosive atmospheres can be found in IEC 60050-426.

3.1

separation element

mechanical element inside the equipment, which separates different parts of the equipment with different EPLs

Note 1 to entry: A separation element consists of a mechanical partition wall, which may be combined with a flameproof joint or a natural ventilation

4 Requirements for design and construction

4.1 Protection measures against ignition hazards of the electrical circuits

4.1.1 General

The equipment shall comply with the requirements of 4.1.2 or 4.1.3 in the event of a failure of one equipment means of protection, by the provision of a second independent means of protection.

NOTE 1 Types of Protection according to EPL Ga do not require a second independent means of protection, e.g. Ex "ia" (IEC 60079-11), Ex "ma" (IEC 60079-18), Ex "da" (IEC 60079-1).

Electrical connections and permanently connected cables of the equipment sited within an area requiring EPL Ga equipment shall comply with the same Level of Protection required by this standard, for example a cable suitable for EPL Gb containing non-Ex "ia" circuits additionally protected by a flameproof conduit or a cable suitable for EPL Gb provided with earth leakage protection.

NOTE 2 Detailed cable and installation requirements for Types of Protection accepted as achieving EPL Ga beyond intrinsically safe circuits are under consideration in IEC 60079-14.

NOTE 3 Because of ignition hazards which can arise from faults and/or transient circulating currents in the potential equalization system, galvanic isolation in the power and signal connections to the equipment according to 4.1.2 and 4.1.3 is commonly applied along with minimizing the effect of transient fault currents in the potential equalization network by the use of electrical protection equipment such as sensitive earth leakage monitors.

4.1.2 Application of two independent Types of Protection providing EPL Gb

Electrical equipment shall comply with the requirements of two independent Types of Protection that provide EPL Gb. If one Type of Protection fails, the other Type of Protection shall continue to function. The independent Types of Protection shall not have a common mode of failure, except as specified in this clause. Combined types of protection providing EPL Gb shall depend on different physical protection principles.

NOTE 1 An example of a common mode of failure is if an Ex "d" enclosure containing arcing components is installed inside an Ex "e" enclosure. Should the Ex "d" enclosure be compromised, it would also compromise the Ex "e" enclosure.

NOTE 2 The combination of Ex "d" and Ex "q" both depend on the avoidance of flame propagation (same physical protection principle) and may not be useful in combination. In practice, some combinations may not be useful, for example the combination of oil immersion "o" and powder filling "q".

Where combined types of protection are used, it shall be possible for each Type of Protection to be tested individually (see 5.1).

Both Types of Protection shall be assessed using the most arduous fault condition of the other Type of Protection. When combining intrinsic safety, Type of Protection "ib", with other