

INTERNATIONAL STANDARD

**Secondary cells and batteries containing alkaline or other non-acid electrolytes -
Vented nickel-cadmium prismatic rechargeable cells and batteries for use in
industrial applications**

get full document from standards.iteh.ai



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2026 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Secretariat
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search -

webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews, graphical symbols and the glossary. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 500 terminological entries in English and French, with equivalent terms in 25 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	5
1 Scope.....	7
2 Normative references.....	7
3 Terms, definitions, symbols and abbreviated terms	7
3.1 Terms and definitions.....	7
3.2 Symbols and abbreviated terms	10
4 Parameter measurement tolerances	11
5 Designation and marking	11
5.1 Cell designation (mandatory)	11
5.2 Cell designation (optional)	11
5.3 Cell termination	12
5.4 Battery designation	12
5.4.1 Battery structure formulation	12
5.4.2 Definitions of components of a battery system	12
5.4.3 Classes of usage of battery system.....	15
5.5 Marking	16
5.6 Safety recommendations	16
6 Dimensions	16
7 Electrical tests for cells	18
7.1 General	18
7.2 Charging procedure for test purposes	18
7.2.1 General.....	18
7.2.2 Charge procedure based on constant current.....	19
7.2.3 Charge procedure based on constant voltage at a given current	19
7.3 Discharge performances.....	19
7.3.1 General.....	19
7.3.2 Discharge performance at 20 °C.....	20
7.3.3 Discharge performance at +5 °C.....	20
7.3.4 Discharge performance at -18 °C.....	21
7.3.5 Discharge performance at low temperature.....	22
7.3.6 Discharge performance at high temperature.....	22
7.3.7 High-rate current test	23
7.3.8 Measurement of the internal DC resistance.....	24
7.3.9 Pulse power calculation	25
7.3.10 Constant power measurement test.....	26
7.4 Charge retention.....	27
7.4.1 Test method	27
7.4.2 Acceptance criterion.....	27
7.5 Endurance for cells.....	27
7.5.1 Test conditions	27
7.5.2 Endurance in cycles	28
7.5.3 Final test after completion of endurance in cycles test	29
7.5.4 Determination of durability parameters	30
7.5.5 Permanent charge endurance (optional).....	31
7.6 Charge acceptance at constant voltage.....	31
7.6.1 Test method	31

7.6.2	Acceptance criterion.....	32
7.7	Vent plug operation.....	32
7.8	Electrolyte retention test.....	32
7.8.1	General.....	32
7.8.2	Test method	32
7.8.3	Acceptance criteria	32
7.9	Storage	33
7.9.1	Test method	33
7.9.2	Acceptance criteria	33
7.10	Overcharge	33
8	Mechanical tests.....	33
9	Physical appearance.....	33
10	Requirements at battery level.....	33
10.1	General requirements.....	33
10.2	Environmental conditions.....	33
10.3	Operating voltage range of the battery system	34
10.4	Optional additional components to battery system.....	35
10.4.1	General.....	35
10.4.2	Battery information system.....	35
10.4.3	Battery heater.....	35
10.4.4	Thermostat or cut-off switch	35
10.4.5	Mounting racks	35
10.4.6	Deported components	35
11	Performance requirement for the battery system	36
11.1	Design energy and power calculation methodology	36
11.1.1	General.....	36
11.1.2	Requirements for battery capacity sizing	37
11.1.3	Expected lifetime in years for the battery system	38
11.1.4	Deep discharge of batteries	38
11.1.5	Documentation	39
11.2	End of life performance	39
12	Conditions for approval and acceptance.....	39
12.1	Type approval	39
12.2	Batch acceptance	40
Annex A (normative)	CCCV charge methodology	42
Annex B (normative)	NiCd load profile verification documentation.....	45
B.1	General	45
B.2	General methodology	45
B.3	Battery sizing documentation	46
B.4	Operational verification (load profile test)	46
B.5	Test report	47
Annex C (informative)	Battery structure information	48
Annex D (informative)	Declaration of cell model range representative of the testing	53
Bibliography.....		54

Figure 1 – Definition of cell(s), monobloc battery, crate, tray, and box - Example of mobile application.....	13
Figure 2 – Definition of cell(s), crate/block/module, battery, cabinet - Example of stationary application for telecom.....	14
Figure 3 – Definition of cell(s), crate/block/module, battery, rack - Example of stationary application.....	15
Figure 4 – Example of a vented prismatic cell in steel container with two terminals and four lugs.....	17
Figure 5 – Pulse discharge graph: voltage behaviour under a current pulse.....	26
Figure 6 – Example of a NiCd cell discharge curve at various constant discharge currents based on percentage of capacity.....	34
Figure A.1 – Overview of charging characteristic of NiCd.....	44
Figure C.1 – Cells connected in series.....	49
Figure C.2 – Two cells connected in parallel.....	49
Figure C.3 – Three cells connected in series, with two series strings connected in parallel.....	49
Figure C.4 – Two cells connected in parallel, with four parallel strings connected in series.....	50
Figure C.5 – Two cells connected in parallel, with four parallel strings connected in series, and with three parallel and series connected strings connected in parallel.....	50
Figure C.6 – Two cells connected in parallel, with four parallel strings connected in series, and with three parallel and series connected strings connected in parallel.....	51
Figure C.7 – Three cells connected in series, with two series strings connected in parallel, and with three series and parallel connected strings connected in parallel.....	51
Figure C.8 – Four monoblocs connected in series, with each monobloc comprising five cells.....	51
Figure C.9 – Three cells connected in series, with two series strings connected in parallel, and with three series and parallel connected strings connected in parallel.....	52
Table 1 – Example of dimensions for vented nickel-cadmium prismatic cells in steel containers.....	17
Table 2 – Example of dimensions for vented nickel-cadmium prismatic cells in plastic containers.....	18
Table 3 – Measurement tolerances in millimetres (valid for widths and lengths).....	18
Table 4 – Preferred values for rapid charge current R	19
Table 5 – Discharge performance at 20 °C.....	20
Table 6 – Discharge performance at +5 °C.....	21
Table 7 – Discharge performance at -18 °C.....	21
Table 8 – Discharge performance at low temperature.....	22
Table 9 – Discharge performance at high temperature.....	23
Table 10 – High currents values.....	24
Table 11 – Discharge current and pulse current applied during the measurement of the internal DC resistance.....	25
Table 12 – Endurance in cycles.....	28
Table 13 – Constant voltage charging conditions.....	31
Table 14 – Charge time.....	32
Table 15 – Parameters and responsibility for battery capacity sizing.....	38
Table 16 – Sequence of tests for type approval.....	40

Table 17 – Recommended test sequence for batch acceptance..... 41

Table A.1 – Ni-Cd batteries charging characteristics 43

Table C.1 – Battery structure information - Examples 48

Sample Document

get full document from standards.iteh.ai

INTERNATIONAL ELECTROTECHNICAL COMMISSION

Secondary cells and batteries containing alkaline or other non-acid electrolytes - Vented nickel-cadmium prismatic rechargeable cells and batteries for use in industrial applications

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 60623 has been prepared by subcommittee 21A: Secondary cells and batteries containing alkaline or other non-acid electrolytes, of IEC technical committee 21: Secondary cells and batteries. It is an International Standard.

This sixth edition cancels and replaces the fifth edition published in 2017. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) added a test for internal DC resistance;
- b) added a subclause for pulse power calculation;
- c) added a test for constant power measurement;
- d) added a subclause on the determination of durability parameters.

The text of this International Standard is based on the following documents:

Draft	Report on voting
21A/935/CDV	21A/959/RVC

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at http://www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at <http://www.iec.ch/publications>.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under <http://webstore.iec.ch> in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

Sample Document

get full document from standards.iteh.ai

1 Scope

This document specifies marking, designation, dimensions, tests and requirements for vented nickel-cadmium prismatic secondary single cells and battery systems made of them for use in industrial applications.

NOTE In this context, "prismatic" refers to cells having rectangular sides and base.

When there exists an IEC standard specifying test conditions and requirements for cells used in special applications and which is in conflict with this document, the former takes precedence.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050-482:2004, *International Electrotechnical Vocabulary (IEV) - Part 482: Primary and secondary cells and batteries*

IEC 60050-482:2004/AMD2:2020, *International Electrotechnical Vocabulary (IEV) - Part 482: Primary and secondary cells and batteries*

IEC 61434, *Secondary cells and batteries containing alkaline or other non-acid electrolytes - Guide to designation of current in alkaline secondary cell and battery standards*

IEC 60417, Graphical symbols for use on equipment, available at <http://www.graphical-symbols.info/equipment>

3 Terms, definitions, symbols and abbreviated terms

3.1 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 60050-482:2004 and the following apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- IEC Electropedia: available at <https://www.electropedia.org/>
- ISO Online browsing platform: available at <https://www.iso.org/obp>

3.1.1

vented cell

secondary cell having a cover provided with an opening through which products of electrolysis and evaporation are allowed to escape freely from the cell to the atmosphere

Note 1 to entry: The opening can be fitted with a venting system.

Note 2 to entry: The vented cell is the smallest unit manufactured in series, and the primary vehicle for electrical characterization.

3.1.2

monobloc battery

battery with multiple separate but electrically connected cell compartments each of which is designed to house an assembly of electrodes, electrolyte, terminals or interconnections and possible separators

Note 1 to entry: The cells in a monobloc battery can be connected in series or in parallel.

Note 2 to entry: See 5.4.2.

[SOURCE: IEC 60050-482:2004 [1], 482-02-17, modified – Note 2 to entry has been added.]

3.1.3

crate

container with frame walls for holding several cells or batteries

Note 1 to entry: See 5.4.2.

[SOURCE: IEC 60050-482:2004 [1], 482-05-10, modified – The word "battery" has been removed from the term, and Note 1 to entry has been added.]

3.1.4

tray

container with a base and walls for holding several cells or batteries

Note 1 to entry: See 5.4.2.

[SOURCE: IEC 60050-482:2004 [1], 482-02-35, modified – The word "battery" has been removed from the term, and Note 1 to entry has been added.]

3.1.5

ageing factor

quantitative factor expressing the degradation in the ability of the battery, due to usage, to deliver electrical energy under specified operating conditions such as, but not limited to, operating ambient temperature, cycling considering depth of discharge (DOD), and maintenance practices (applied according to manufacturer's instructions)

3.1.6

battery module

module

group of cells connected together either in a series or parallel, or both configuration, without protective devices

Note 1 to entry: NiCd battery module does not include any hardware (e.g. fuse or electronic board).

Note 2 to entry: Protective devices (e.g. temperature sensor) are part of the battery system.

3.1.7

battery system

battery

system that can include battery tray(s), battery crate(s), monobloc(s), battery module(s), electronic components/equipment and associated electromechanical connections

Note 1 to entry: Any component necessary to obtain the safety and durability of the battery system is included (e.g. battery thermal management system, BTMS)

Note 2 to entry: See 5.4.2 and 10.1.

Note 3 to entry: The battery system manufacturer can be the end user or the equipment manufacturer, in case they install for example heating/cooling systems, ventilation common to the global equipment but necessary for the battery.

Note 4 to entry: The battery system performances are derived from cell electrical characterization.

3.1.8**battery information system**

electronic system collecting and analyzing battery data to provide additional information, i.e. information not necessary for battery operation

Note 1 to entry: Additional information, for example, can be parameters necessary for condition-based maintenance.

3.1.9**end user**

organization which operates the battery system

Note 1 to entry: The end user is normally an organization which operates the device equipped with the battery system, unless the responsibility is delegated to a main contractor or consultant.

3.1.10**system integrator**

organization which has the technical responsibility of the complete battery system and charging system

Note 1 to entry: The system integrator can be the end user or the equipment manufacturer, or none of them.

3.1.11**manufacturer**

organization which has the technical responsibility for its scope of supply

Note 1 to entry: The manufacturer can be the equipment manufacturer or the system integrator of a battery system, a cell manufacturer, etc. If necessary to explicitly distinguish, "equipment manufacturer", "battery system manufacturer" or "cell manufacturer" is expressed.

3.1.12**cumulated requested service**

CRS

total amount of service requested by the buyer or the end user, expressed in duration (months or years) or delivered energy in kWh, under for example representative ambient and operating conditions as expressed

Note 1 to entry: Refer to [Clause 10](#) and [Clause 11](#).

3.1.13**nominal voltage**

suitable approximate value of the voltage used to designate or identify a cell or a battery

Note 1 to entry: The nominal voltage of a vented nickel-cadmium rechargeable single cell is 1,2 V.

Note 2 to entry: The nominal voltage of a battery of n series connected cells is equal to n times the nominal voltage of a single cell.

[SOURCE: [IEC 60050-482:2004 \[1\]](#), 482-03-31, modified – Replacement of the words "a battery or an electrochemical system" by "or a battery" and addition of Notes 1 and 2 to entry.]

3.1.14**discharge voltage**

<cell or battery> voltage between the terminals of a cell or battery when being discharged

[SOURCE: [IEC 60050-482:2004 \[1\]](#), 482-03-28, modified – The admitted and deprecated terms have been removed.]

3.1.15**rated capacity**

capacity value of a cell or battery determined under specified conditions and declared by the manufacturer

Note 1 to entry: The rated capacity is the quantity of electricity C_5 Ah (ampere-hours) declared by the manufacturer which a single cell can deliver during a 5 h period when charging, storing and discharging under the conditions specified in 7.3.2.

[SOURCE: IEC 60050-482:2004 [1], 482-03-15, modified – Addition of the words "cell or" in the definition, and of Note 1 to entry.]

3.1.16**state of charge**

SOC

remaining capacity to be discharged, normally expressed as a percentage of the cell rated capacity according to 7.3.2.2

3.1.17**state of charge at end of life**

SOC at end of life

remaining capacity to be discharged at end of life, normally expressed as 70 % of the cell rated capacity (3 h 30 min discharge with 7.3.2.2 conditions)

3.1.18**CCCV charge**

CCCV

method of charge consisting in a charge at constant current followed by a charge at constant voltage

3.2 Symbols and abbreviated terms

BOL	beginning of life
BTMS	battery thermal management system
CCCV	constant current constant voltage
CRS	cumulated requested service
DOD	depth of discharge
EOL	end of life
NiCd	nickel-cadmium
P_c	constant power for cycling evolution
RTE	round-trip efficiency
SOC	state of charge
REP	applications with frequent and repetitive charge and discharge cycles
OND	applications with sporadic on-demand energy delivery
MOB	mobile equipment
STA	stationary equipment

4 Parameter measurement tolerances

The overall accuracy of controlled or measured values, relative to the specified or actual values, shall be within the following tolerances:

- a) ± 1 % for voltage;
- b) ± 1 % for current;
- c) ± 2 °C for temperature;
- d) $\pm 0,1$ % for time;
- e) ± 1 % for capacity.

These tolerances comprise the combined accuracy of the measuring instruments, the measurement techniques used, and all other sources of error in the test procedure.

The details of the instrumentation used shall be provided in any report of results.

5 Designation and marking

5.1 Cell designation (mandatory)

Vented nickel-cadmium prismatic secondary single cells shall be designated by the letter "K" followed by a letter "L", "M", "H" or "X" which signifies

- low rate of discharge (L),
- medium rate of discharge (M),
- high rate of discharge (H), and
- very high rate of discharge (X).

NOTE 1 These types of cells are typically but not exclusively used for the following discharge rates:

- a) L up to $0,5 I_t$ A;
- b) M up to $3,5 I_t$ A;
- c) H up to $7,0 I_t$ A;
- d) X up to and above $7,0 I_t$ A.

NOTE 2 These currents are expressed as multiples of I_t A, where $I_t A = C_5 Ah / 1 h$ (see IEC 61434:1996 [2]).

NOTE 3 In case the cells have internal separations but a common electrolyte, they are still considered as a single cell.

This group of two letters shall be followed by a group of figures indicative of the rated capacity of the cell in ampere-hours. Cells that have been tested at 20 °C and 5 °C but not at –18 °C shall carry an additional marking of T5.

EXAMPLE KH 185 or KH 185 T5

Cells tested with CCCV charges shall carry the marking of CCCV followed by the current used: for example, KH 185 P CCCV R1.

5.2 Cell designation (optional)

The additional marking can be added to the mandatory marking. When the marking would exceed the available space on the cell, this information may be omitted on the cell but shall be provided in the documentation corresponding to the cell and in the type test report, or in a shared IT system accessible to the end user based on information on the cell label (e.g. data matrix).

As an option, cells in cases of plastic material can be designated by the letter "P" after the figures (for example: KH 185 P), or in case of steel material with a letter "S".

If there is no mention concerning the marking for temperature, the cells shall have been tested at $-18\text{ }^{\circ}\text{C}$, $5\text{ }^{\circ}\text{C}$ and $20\text{ }^{\circ}\text{C}$. Cells tested at other temperatures shall carry an additional marking of "T" followed by tested temperatures. In case the cell is characterized with both low and high temperature, they shall be indicated in increasing order with a solidus separating them: for example: KH 185 P T-35/+45.

Cells tested at rapid charge shall carry the marking "R" and the value of the tested rapid charge current, expressed in multiple of I_r A: for example, KH 185 P R1.

High grade cycling cells shall carry an additional marking "C" followed by the number of cycles: for example, KH 185 P C1500.

Cells having been tested with multiple types of tests shall carry the marking for the various tests performed: for example, KH 185 P T-35/+45 CCCV R1 C1500.

5.3 Cell termination

This document does not specify cell termination.

5.4 Battery designation

5.4.1 Battery structure formulation

In case of batteries where there are cells in series with crates or modules with a different number of the same capacity cells, the detailed information is not necessary in the designation; it is a constructive information already provided in the drawing.

Cells designation according to 5.1 or 5.2 followed by the battery structure formulation describes

- the number of cells in the minimum constitutive(s) entity(ies), and on the right side of the number, it describes their connection mode in series (S) or in parallel (P) - see Annex C, and
- in the event that the minimum constitutive entities are connected in series or in parallel, the number of minimum constitutive entities, and on the right side of the number, it describes their connection mode in series (S) or in parallel (P) - see Annex C including some examples.

The battery designation shall include the breakdown structure of the battery. The descriptive path followed to formulate the battery is from the smallest entity to the largest one.


EXAMPLE 1 "KM130(80S)" designates a prismatic vented nickel-cadmium battery. Its rated capacity is 130 Ah with 80 cells. It is designed for a medium discharge rate.

EXAMPLE 2 "KH100((2P)84S)" designates a prismatic vented nickel-cadmium battery system. Its rated capacity is 100 Ah. It is designed for a high discharge rate.

5.4.2 Definitions of components of a battery system

In order to clarify the definitions, 5.4.2 presents practical examples.

See Figure 1 (images are examples) for the case of mobile applications.



IEC

Figure 1 – Definition of cell(s), monobloc battery, crate, tray, and box - Example of mobile application

It is possible that some batteries do not include all the components showed in [Figure 1](#), for example single cells can be installed in a tray without crates. Some battery technologies can include further components (e.g. module) if necessary.

For the case of stationary applications, see [Figure 2](#) and [Figure 3](#) as examples, also illustrating the structure described in [Annex C](#).