

INTERNATIONAL STANDARD

EXTENDED VERSION

This full version of IEC 60730-2-10:2026 includes the content of the references made to IEC 60730-1:2022

**Automatic electrical controls -
Part 2-10: Particular requirements for motor-starting relays**

Sample Document

get full document from standards.iteh.ai



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2026 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Secretariat
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search -

webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews, graphical symbols and the glossary. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 500 terminological entries in English and French, with equivalent terms in 25 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD	9
1 Scope	12
2 Normative references	13
3 Terms and definitions	17
3.1 Definitions relating to ratings, voltages, currents, frequencies, and wattages	17
3.2 Definitions of types of control according to purpose	20
3.3 Definitions relating to the function of controls	22
3.4 Definitions relating to disconnection and interruption	25
3.5 Definitions of types of control according to construction	26
3.6 Definitions of type of automatic action of a control	28
3.7 Definitions relating to protection against electric shock and type of insulation	28
3.8 Definitions relating to component parts of controls	32
3.9 Definitions of types of terminals and terminations of controls	33
3.10 Definitions relating to the connections to controls	35
3.11 Definitions relating to the performance of type 2 actions	36
3.12 Definitions relating to the requirements for creepage distances and clearances	37
3.13 Miscellaneous definitions	37
3.14 Definitions relating to manufacturer and user	39
3.15 Definitions pertaining to thermistors	39
3.16 Definitions relating to the structure of controls using software	39
3.17 Definitions relating to error avoidance in controls using software	39
3.18 Definitions relating to fault/error control techniques for controls using software	39
3.19 Definitions relating to memory tests for controls using software	40
3.20 Definitions of software terminology – General	40
3.21 Definitions relating to classes of control functions	40
3.22 Definitions relating to functional safety	40
3.23 Definitions related to access to data exchange	40
3.24 Definitions related to EMC performance	40
4 General	42
4.1 General structure of the document	42
4.2 General requirements	43
4.3 General notes on tests	44
5 Required technical information	47
5.1 General requirements	47
5.2 Methods of providing technical information	47
5.3 Class II symbol	55
5.4 Additional requirements for marking	55
5.5 Warning or cautionary markings	57
6 Protection against electric shock	57
6.1 General requirements	57
6.2 Actuating members and actuating means	59
6.3 Capacitors	60
6.4 Covers and uninsulated live or hazardous parts	60

6.5	Battery operated controls provided with a user accessible mains supply input connector	61
7	Provision for protective earthing	61
7.1	Class 0I and Class I controls	61
7.2	Class II and class III controls	61
7.3	Adequacy of earth connections	61
7.4	Corrosion resistance	62
7.5	Other requirements	63
7.6	Protective equipotential bonding	63
8	Terminals and terminations	63
8.1	Terminals and terminations for external copper conductors	63
8.2	Terminals and terminations for internal conductors	68
8.3	Terminals and terminations for integrated conductors	70
9	Constructional requirements	70
9.1	Materials	70
9.2	Protection against electric shock	71
9.3	Actuation and operation	73
9.4	Actions	76
9.5	Openings in enclosures	79
9.6	Mounting of controls	79
9.7	Attachment of cords	80
9.8	Size of cords – non-detachable	81
9.9	Inlet openings	82
9.10	Equipment inlets and socket-outlets	82
9.11	Requirements during mounting, use, maintenance and servicing	83
9.12	Controls using software	85
9.13	Protective controls and components of protective control systems	88
10	Threaded parts and connections	91
10.1	Threaded parts moved during mounting or servicing	91
10.2	Current-carrying connections and connections providing protective earthing continuity	92
11	Creepage distances, clearances and distances through solid insulation	93
11.1	General	93
11.2	Clearances	94
11.3	Creepage distances	98
11.4	Solid insulation	102
12	Components	103
12.1	Transformers	103
12.2	Switch mode power supplies and converters	103
12.3	Capacitors	104
12.4	Fuses	104
12.5	Varistors	104
12.6	Thermistors	104
12.7	Relays	105
12.8	Other components	105
13	Fault assessment on electronic circuits	105
13.1	Fault assessment for inherent safety	105
13.2	Fault assessment to ensure functional safety	111

14	Moisture and dust resistance	111
14.1	Protection against ingress of water and dust	111
14.2	Protection against humid conditions	112
14.3	Touch current test for in-line cord controls and free-standing controls	113
15	Electric strength and insulation resistance	114
15.1	Insulation resistance	114
15.2	Electric strength	114
15.3	Additional tests for in-line cord and free-standing controls	116
16	Heating	117
17	Manufacturing deviation and drift	121
18	Environmental stress	121
18.1	Transportation and storage	121
18.2	Environmental stress of temperature	121
19	Endurance	122
19.1	General requirements	122
19.2	Electrical conditions for the tests	123
19.3	Thermal conditions for the tests	129
19.4	Manual and mechanical conditions for the tests	129
19.5	Dielectric strength requirements	130
19.6	Ageing test	130
19.7	Overvoltage test or overload test in all countries using an overload test of automatic action at accelerated rate	130
19.8	Test of automatic action at accelerated rate	131
19.9	Test of automatic action at slow rate	131
19.10	Overvoltage test or overload test in all countries that use the overload test of manual action at accelerated speed	131
19.11	Test of manual action at slow speed	131
19.12	Test of manual action at high speed which has multiple poles, and where polarity reversal occurs during the action	131
19.13	Test of manual action at accelerated speed	131
19.14	Evaluation of compliance	131
19.15	Test for particular purpose controls	132
20	Mechanical strength	132
20.1	General requirements	132
20.2	Impact resistance	133
20.3	Free-standing controls	133
20.4	In-line cord controls	134
20.5	Pull-cord actuated controls	134
20.6	Foot actuated controls	135
20.7	Actuating member and actuating means	135
20.8	Flexing – test	135
20.9	Cord anchorages – test	136
21	Resistance to heat, fire and tracking	137
21.1	General requirements	137
21.2	Integrated, incorporated and in-line cord controls	137
21.3	Independently mounted, free-standing controls	138
22	Resistance to corrosion	138
22.1	Resistance to rusting	138

23	Electromagnetic compatibility (EMC) requirements – Emission	139
23.1	General requirement	139
23.2	High frequency emission	139
23.3	Low frequency emission	143
24	Normal operation	143
25	Electromagnetic compatibility (EMC) requirements – Immunity	143
25.1	General	143
25.2	EMC test plan and report	144
25.3	Immunity requirements	146
25.4	Performance criteria	149
25.5	Surge immunity test	150
25.6	Electrical fast transient immunity test	150
25.7	Radio-frequency electromagnetic field immunity	151
25.8	Electrostatic discharge	151
25.9	Immunity to power-frequency magnetic fields	151
25.10	Test of the influence of voltage dips and voltage interruption in the power supply network	151
26	Abnormal operation tests	152
26.1	Abnormal temperature test	152
26.2	Overload tests	152
26.3	Battery short-circuit test	153
Annex A (normative)	Indelibility of markings	171
Annex B (normative)	Measurement of creepage distances and clearances in air	173
Annex C (informative)	Nominal voltages of supply systems for different modes of overvoltage control	177
Annex D (normative)	Overvoltage categories	179
Annex E (informative)	Typical usage of controls and related overvoltage categories	180
Annex F (normative)	Pollution degrees	181
F.1	Pollution	181
F.2	Degrees of pollution in the micro-environment	181
Annex G (normative)	Resistance to heat, fire and tracking tests	182
G.1	Glow-wire test	182
G.2	Proof tracking test	182
G.3	Ball pressure test	182
Annex H (normative)	Requirements related to functional safety	184
H.3	Terms and definitions	184
H.5	Information	195
H.9	Constructional requirements	197
H.13	Fault assessment on electronic circuits	213
H.17	Manufacturing deviation and drift	218
H.19	Endurance	219
H.25	Electromagnetic compatibility (EMC) requirements – Immunity	220
Annex I (normative)	Requirements for certain types of DC supplied controls	234
I.1	Scope	234
Annex J (normative)	Requirements for thermistor elements and controls using thermistors	236
J.1	Scope	236

Annex K (normative) Circuit for measuring touch current	253
Annex L (normative) Printed circuit board coating performance test	254
Annex M (normative) Printed circuit board protection	256
Annex N (informative) Explanatory notes for surge immunity test	259
N.1 Different source impedances	259
N.2 Application of the tests	259
N.3 Installation classification	260
Annex O (informative) Guidance for applying Clause 11	263
Annex P (normative) Requirements for SELV and PELV	266
P.1 Overview of the requirements for SELV and PELV	266
P.2 Protection against electric shock by SELV system or PELV system	266
P.3 Protective measures for SELV system and PELV system	267
Annex Q (informative) Regional differences relevant for the member countries of Cenelec	269
Annex R (informative) National differences relevant in the United States of America	274
R.2 Normative references	274
Annex S (informative) National differences relevant in Japan	275
S.2 Normative references	275
Annex T (informative) National differences relevant in Canada	276
T.2 Normative references	276
Bibliography	277
Figure 1 – Example of ports	40
Figure 2 – Structure of the document with respect to inherent safety and functional safety	43
Figure 3 – Example of an electronic circuit with low power points	106
Figure 4 – Test pin probe 13 of IEC 61032:1997	153
Figure 5 – Test finger probe B of IEC 61032:1997	154
Figure 6 – Test fingernail	155
Figure 7 – Impact test for free-standing controls	156
Figure 8 – Tumbling barrel	156
Figure 9 – Apparatus for testing durability of markings on rating labels	157
Figure 10 – Apparatus for flexing test	158
Figure 11 – Screw terminals and stud terminals	159
Figure 12 – Pillar terminals	160
Figure 13 – Mantle terminals	161
Figure 14 – Saddle and lug terminals	162
Figure 15 – Tabs	163
Figure 16 – Tabs for non-reversible connectors	164
Figure 17 – Receptacles	165
Figure 18 – Measurement of creepage distance and clearance	166
Figure 19 – Diagram for touch current measurement at operating temperature for single-phase connection of class II controls	167
Figure 20 – Diagram for touch current measurement at operating temperature for single-phase connection of controls other than class II	167

Figure 21 – Diagram for touch current measurement at operating temperature for three-phase connection of class II controls	168
Figure 22 – Diagram for touch current measurement at operating temperature for three-phase connection of controls other than class II	169
Figure 23 – Diagram for touch current measurement at operating temperature for single-phase connection of controls to three-wire, ground neutral supply other than class II	169
Figure 24 – Diagram for touch current measurement at operating temperature for two-phase connection of controls to three-wire, ground neutral supply other than class II	170
Figure B.1 – Narrow groove	174
Figure B.2 – Wide groove	174
Figure B.3 – V-shaped groove	174
Figure B.4 – Rib.....	174
Figure B.5 – Uncemented joint with narrow groove	175
Figure B.6 – Uncemented joint with wide groove	175
Figure B.7 – Uncemented joint with narrow and wide grooves	175
Figure B.8 – Diverging side walls	176
Figure B.9 – Narrow recess	176
Figure B.10 – Wide recess	176
Figure B.11 – Conductive floating part	176
Figure H.1 – V-Model for the software life cycle	205
Figure H.2 – Voltage variation test	223
Figure J.1 – Generic test circuit for inrush-current limiting thermistor endurance test	252
Figure K.1 – Circuit for measuring touch currents	253
Figure L.1 – Test sample	255
Figure M.1 – Example of type 1 protection	257
Figure M.2 – Example of type 2 protection	258
Figure N.1 – Example of surge protection by shielding in buildings with common earth reference systems	261
Figure N.2 – Example of secondary surge protection in buildings with separate common earth reference systems	262
Figure N.3 – Example of primary and secondary surge protection of indoor/outdoor equipment	262
Figure O.1 – Guidance flowchart for application of requirements of Clause 11	264
Table 1 – Required technical information and methods of providing these information	50
Table 2 – Cross-sectional area of conductors	64
Table 3 – Terminal conductors	66
Table 4 – Conductor pull test values	67
Table 5 – Nominal cross-sectional areas of conductors	68
Table 6 – Axial force values for tab insertion and withdrawal	70
Table 7 – Minimum cord conductor sizes	81
Table 8 – Data exchange	87
Table 9 – Threaded parts torque test values	92

Table 10 – Rated impulse voltage for equipment energized directly from the supply mains (from IEC 60664-1:2007, Table F.1)	95
Table 11 – Clearances for insulation co-ordination (from IEC 60664-1:2007, Table F.2).....	96
Table 12 – Minimum creepage distances for basic insulation	100
Table 13 – Minimum creepage distances for functional insulation	101
Table 14 – Electrical/electronic component fault modes	107
Table 15 – Minimum insulation resistance.....	114
Table 16 – Insulation or disconnection test voltages	115
Table 17 – Maximum heating temperatures.....	119
Table 18 – Electrical conditions for the overvoltage and endurance tests	125
Table 19 – Electrical conditions for the overload tests of 19.7 and 19.10	127
Table 20 – Electrical conditions for the endurance tests of 19.8, 19.9, 19.11, 19.12 and 19.13	128
Table 21 – Pull-cord force test values	134
Table 22 – Pull and torque values.....	136
Table 23 – Emission limit for residential electromagnetic environment	141
Table 24 – Emission limit for industrial electromagnetic environment	142
Table 25 – The applicable EMC test in relation to the class of control function and type of Action	144
Table 26 – Immunity test requirements for residential electromagnetic environments.....	146
Table 27 – Immunity test requirements for industrial electromagnetic environment	148
Table 28 – Performance criteria.....	150
Table B.1 – Value of X	173
Table C.1 – Inherent control or equivalent protective control.....	177
Table C.2 – Cases where protective control is necessary and control is provided by surge arresters having a ratio of clamping voltage to rated voltage not smaller than that specified by IEC 60099-1	178
Table E.1 – Typical usage.....	180
Table H.1 – Additional items to Table 1.....	195
Table H.2 – Acceptable measures to address fault/errors ^a	198
Table H.3 – Examples of techniques/measures for semi-formal methods	205
Table H.4 – Examples of techniques/measures for software architecture specification.....	206
Table H.5 – Examples of techniques/measures for module design specification	207
Table H.6 – Examples of techniques/measures for design and coding standards	207
Table H.7 – Examples of techniques/measures for software module testing	208
Table H.8 – Examples of techniques/measures for software integration testing.....	209
Table H.9 – Examples of techniques/measures for software safety validation	209
Table H.10 – Combinations of analytical measures during hardware development	210
Table H.11 – Examples of defences against unauthorised access and transmission failure modes.....	212
Table H.12 – Applicable test levels in addition to Clause 25.....	221
Table H.13 – Voltage dips, short interruptions and voltage variations.....	222
Table H.14 – Test values for voltage variations.....	223
Table H.15 – Test voltages for test level 2 (depending on the installation class conditions).....	226

Table H.16 – Test level for electrical fast transient burst test	227
Table H.17 – Test levels for conducted disturbances on mains and I/O lines.....	229
Table H.18 – Test level for immunity to radiated electromagnetic fields	230
Table H.19 – Increased test level for radiated immunity	230
Table H.20 – Test level for supply frequency variations	231
Table H.21 – Test level for continuous fields.....	232
Table I.1 – Electrical transient conduction immunity in accordance with ISO 7637-2	234
Table I.2 – Electrical transient conduction immunity in accordance with ISO 7637-3	235
Table J.1 – Maximum current.....	238
Table J.2 – Normal operating conditions	239
Table J.3 – Samples for the test (clause reference)	240
Table J.4 – Electrical and thermal ratings of a thermistor	241
Table J.5 – Additional items to Table 1	242
Table J.6 – Sequence of calibration and conditioning tests for PTC thermistors	244
Table J.7 – Classes for PTC sensing thermistors	245
Table J.8 – Sequence of calibration and conditioning tests for NTC thermistors.....	246
Table J.9 – Classes for NTC sensing thermistors	247
Table J.10 – Number of cycles for endurance test.....	250
Table J.11 – Ageing test temperature	250
Table J.12 – Number of cycles for endurance test.....	251
Table L.1 – Environmental cycling conditions.....	254
Table M.1 – IEC 60664-3 test levels or conditions	256
Table O.1 – Example A – Using Annex O guidance for applying Clause 11	265
Table O.2 – Example B – Using Annex O guidance for applying Clause 11	265
Table Q.1 – Additional aging parameters for windings.....	270

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**Automatic electrical controls -
Part 2-10 Particular requirements for motor-starting relays**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

This extended version (EXV) of the official IEC Standard provides the user with the full content of the Standard.

IEC 60730-2-10:2026 EXV includes the content of IEC 60730-2-10:2026 and the references made to IEC 60730-1:2022.

The specific content of IEC 60730-2-10:2026 is displayed on a blue background.

IEC 60730-2-10 has been prepared by IEC technical committee 72: Automatic electrical controls. It is an International Standard.

This third edition cancels and replaces the second edition published in 2006. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) adoption of IEC 60730-1:2022 with all of its significant changes.

The text of this International Standard is based on the following documents:

Draft	Report on voting
72/1522/CDV	72/1543/RVC

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

This part 2-10 is intended to be used in conjunction with IEC 60730-1. It was established on the basis of the sixth edition of that standard (2022). Consideration may be given to future editions of, or amendments to, IEC 60730-1.

This part 2-10 supplements or modifies the corresponding clauses in IEC 60730-1, so as to convert that publication into the IEC standard: Particular requirements for motor-starting relays.

Where this part 2-10 states "addition", "modification" or "replacement", the relevant requirement, test specification or explanatory matter in Part 1 should be adapted accordingly.

When a particular subclause of Part 1 is not mentioned in this part 2, that subclause applies.

In the development of a fully international standard it has been necessary to take into consideration the differing requirements resulting from practical experience in various parts of the world and to recognize the variation in national electrical systems and wiring rules.

In this publication:

- requirements proper: in roman type;
- *test specifications: in italic type;*
- explanatory matter: in smaller roman type.
- defined terms: **bold type**.

Subclauses, notes or items which are additional to those in Part 1 are numbered starting from 101, additional annexes are lettered AA, BB, etc.

The reader's attention is drawn to the fact that Annex Q, Annex R, Annex S, and Annex T list all of the "in-some-country" clauses on differing practices of a less permanent nature relating to the subject of this document.

A list of all parts of the IEC 60730 series, under the general title: *Automatic electrical controls*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

Sample Document

get full document from standards.iteh.ai

1 Scope

This part of IEC 60730 applies to automatic electrical **motor-starting relays**

- intended to control the start windings of single phase motors;
- for use in, on, or in association with equipment for household appliance and similar use;

NOTE 1 Throughout this document, the word "equipment" means "appliance and equipment" and "control" means "**motor-starting relays**".

- intended for appliances within the scope of IEC 60335;
- for equipment that is used in building automation within the scope of ISO 16484 series and IEC 63044 series (HBES/BACS);
- for equipment that is used by the public, such as equipment intended to be used in shops, offices, hospitals, farms and commercial and industrial applications;

EXAMPLE 1 Controls for commercial catering, heating and air-conditioning equipment.

- used in, on, or in association with equipment that are smart enabled;

EXAMPLE 2 Smart grid control, remote interfaces/control of energy-consuming equipment.

- that are AC or DC powered with a rated voltage not exceeding 690 V AC or 600 V DC;
- used in, on, or in association with equipment that use electricity, gas, oil, solid fuel, solar thermal energy, etc., or a combination thereof;
- utilized as part of a control system or controls which are mechanically integral with multifunctional controls having non-electrical outputs;
- using NTC or **PTC thermistors**, requirements for which are contained in Annex J;
- that are mechanically or electrically operated, responsive to or controlling such characteristics as current and voltage, or combinations thereof;

EXAMPLE 3 Centrifugal motor-starting devices.

- as well as manual controls when such are electrically and/or mechanically integral with automatic controls.

NOTE 2 Requirements for manually actuated mechanical switches not forming part of an automatic control are contained in IEC 61058-1-1.

This document applies to

- the inherent safety of motor-starting control, and
- functional safety of motor-starting control and safety related systems (when required),
- controls where the performance (for example the effect of EMC phenomena) of the product can impair the overall safety and performance of the controlled system,
- the operating values, operating times, and operating sequences where such are associated with equipment safety,
- motor-starting controls incorporating electronic devices, thermistor elements, thermal elements or magnetic elements.

This document specifies the requirements for construction, operation and testing of automatic electrical **motor-starting relays** used in, on, or in association with an equipment.

This document does not

- apply to **motor-starting relays** designed exclusively for industrial process applications unless explicitly mentioned in the relevant equipment standard. However, this document can be applied to motor-start relays for equipment intended specifically for industrial applications in cases where no relevant safety standard exists;
- take into account the response value of an automatic action of a control, if such a response value is dependent upon the method of mounting the control in the equipment. Where a response value is of significant purpose for the protection of the user, or surroundings, the value defined in the appropriate equipment standard or as determined by the manufacturer will apply;
- apply to general purpose relays or to contactors and motor starters of the type covered by IEC 60947 series;
- apply to mechanically operated motor-starting devices.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60038, *IEC standard voltages*

IEC 60065:2014, *Audio, video and similar electronic apparatus – Safety requirements*

IEC 60068-2-75, *Environmental testing – Part 2-75: Tests – Test Eh: Hammer tests*

IEC 60085, *Electrical insulation – Thermal evaluation and designation*

IEC 60099-1:1991, *Surge arresters – Part 1: Non-linear resistor type gapped surge arresters for a.c. systems*¹

IEC 60112:2020, *Method for the determination of the proof and the comparative tracking indices of solid insulating materials*

IEC 60127 (all parts), *Miniature fuses*

IEC 60227-1, *Polyvinyl chloride insulated cables of rated voltages up to and including 450/750 V – Part 1: General requirements*

IEC 60245-1, *Rubber insulated cables – Rated voltages up to and including 450/750 V – Part 1: General requirements*

IEC 60269 (all parts), *Low-voltage fuses*

IEC 60335-1:2020, *Household and similar electrical appliances – Safety – Part 1: General requirements*

¹ Withdrawn.