

INTERNATIONAL STANDARD

EXTENDED VERSION

This full version of IEC 60730-2-9:2026 includes the content of the references made to IEC 60730-1:2022

**Automatic electrical controls -
Part 2-9: Particular requirements for temperature sensing controls**

Sample Document

get full document from standards.iteh.ai



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2026 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Secretariat
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search -

webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews, graphical symbols and the glossary. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 500 terminological entries in English and French, with equivalent terms in 25 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD	9
1 Scope	12
2 Normative references	13
3 Terms and definitions	17
3.1 Definitions relating to ratings, voltages, currents, frequencies, and wattages	17
3.2 Definitions of types of control according to purpose	19
3.3 Definitions relating to the function of controls	23
3.4 Definitions relating to disconnection and interruption	26
3.5 Definitions of types of control according to construction	27
3.6 Definitions of type of automatic action of a control	29
3.7 Definitions relating to protection against electric shock and type of insulation	29
3.8 Definitions relating to component parts of controls	33
3.9 Definitions of types of terminals and terminations of controls	34
3.10 Definitions relating to the connections to controls	36
3.11 Definitions relating to the performance of type 2 actions	37
3.12 Definitions relating to the requirements for creepage distances and clearances	38
3.13 Miscellaneous definitions	38
3.14 Definitions relating to manufacturer and user	40
3.15 Definitions pertaining to thermistors	40
3.16 Definitions relating to the structure of controls using software	40
3.17 Definitions relating to error avoidance in controls using software	40
3.18 Definitions relating to fault/error control techniques for controls using software	40
3.19 Definitions relating to memory tests for controls using software	41
3.20 Definitions of software terminology – General	41
3.21 Definitions relating to classes of control functions	41
3.22 Definitions relating to functional safety	41
3.23 Definitions related to access to data exchange	41
3.24 Definitions related to EMC performance	41
4 General	43
4.1 General structure of the document	43
4.2 General requirements	45
4.3 General notes on tests	45
5 Required technical information	49
5.1 General requirements	49
5.2 Methods of providing technical information	49
5.3 Class II symbol	58
5.4 Additional requirements for marking	58
5.5 Warning or cautionary markings	60
6 Protection against electric shock	60
6.1 General requirements	60
6.2 Actuating members and actuating means	63
6.3 Capacitors	63
6.4 Covers and uninsulated live or hazardous parts	64

6.5	Battery operated controls provided with a user accessible mains supply input connector	64
7	Provision for protective earthing	64
7.1	Class 0I and Class I controls	64
7.2	Class II and class III controls	64
7.3	Adequacy of earth connections	64
7.4	Corrosion resistance	66
7.5	Other requirements	66
7.6	Protective equipotential bonding	66
8	Terminals and terminations	67
8.1	Terminals and terminations for external copper conductors	67
8.2	Terminals and terminations for internal conductors	71
8.3	Terminals and terminations for integrated conductors	73
9	Constructional requirements	74
9.1	Materials	74
9.2	Protection against electric shock	75
9.3	Actuation and operation	77
9.4	Actions	80
9.5	Openings in enclosures	86
9.6	Mounting of controls	86
9.7	Attachment of cords	87
9.8	Size of cords – non-detachable	88
9.9	Inlet openings	89
9.10	Equipment inlets and socket-outlets	90
9.11	Requirements during mounting, use, maintenance and servicing	90
9.12	Controls using software	93
9.13	Protective controls and components of protective control systems	95
9.101	Time factor	98
10	Threaded parts and connections	98
10.1	Threaded parts moved during mounting or servicing	98
10.2	Current-carrying connections and connections providing protective earthing continuity	100
11	Creepage distances, clearances and distances through solid insulation	101
11.1	General	101
11.2	Clearances	102
11.3	Creepage distances	106
11.4	Solid insulation	110
12	Components	111
12.1	Transformers	111
12.2	Switch mode power supplies and converters	111
12.3	Capacitors	112
12.4	Fuses	112
12.5	Varistors	112
12.6	Thermistors	112
12.7	Relays	113
12.8	Other components	113
13	Fault assessment on electronic circuits	113
13.1	Fault assessment for inherent safety	113

13.2	Fault assessment to ensure functional safety	119
14	Moisture and dust resistance	119
14.1	Protection against ingress of water and dust	119
14.2	Protection against humid conditions	120
14.3	Touch current test for in-line cord controls and free-standing controls	121
14.101	Refrigeration controls	122
15	Electric strength and insulation resistance	123
15.1	Insulation resistance	123
15.2	Electric strength	123
15.3	Additional tests for in-line cord and free-standing controls	125
16	Heating	126
17	Manufacturing deviation and drift	131
18	Environmental stress	131
18.1	Transportation and storage	131
18.2	Environmental stress of temperature	131
19	Endurance	131
19.1	General requirements	131
19.2	Electrical conditions for the tests	133
19.3	Thermal conditions for the tests	138
19.4	Manual and mechanical conditions for the tests	138
19.5	Dielectric strength requirements	139
19.6	Ageing test	139
19.7	Overvoltage test or overload test in all countries using an overload test of automatic action at accelerated rate	139
19.8	Test of automatic action at accelerated rate	140
19.9	Test of automatic action at slow rate	140
19.10	Overvoltage test or overload test in all countries that use the overload test of manual action at accelerated speed	141
19.11	Test of manual action at slow speed	141
19.12	Test of manual action at high speed which has multiple poles, and where polarity reversal occurs during the action	141
19.13	Test of manual action at accelerated speed	141
19.14	Evaluation of compliance	142
19.15	Test for particular purpose controls	142
19.101	Type 2.P cycling test	145
20	Mechanical strength	147
20.1	General requirements	147
20.2	Impact resistance	147
20.3	Free-standing controls	148
20.4	In-line cord controls	148
20.5	Pull-cord actuated controls	149
20.6	Foot actuated controls	149
20.7	Actuating member and actuating means	149
20.8	Flexing – test	150
20.9	Cord anchorages – test	150
20.101	Push-and-turn or pull-and-turn actuation	151
20.102	Parts containing liquid metal	152
21	Resistance to heat, fire and tracking	152

21.1	General requirements	152
21.2	Integrated, incorporated and in-line cord controls.....	152
21.3	Independently mounted, free-standing controls	154
22	Resistance to corrosion	154
22.1	Resistance to rusting	154
23	Electromagnetic compatibility (EMC) requirements – Emission	155
23.1	General requirement	155
23.2	High frequency emission	155
23.3	Low frequency emission.....	159
24	Normal operation	159
25	Electromagnetic compatibility (EMC) requirements – Immunity	159
25.1	General.....	159
25.2	EMC test plan and report	160
25.3	Immunity requirements.....	162
25.4	Performance criteria	165
25.5	Surge immunity test.....	166
25.6	Electrical fast transient immunity test.....	166
25.7	Radio-frequency electromagnetic field immunity	167
25.8	Electrostatic discharge.....	167
25.9	Immunity to power-frequency magnetic fields.....	167
25.10	Test of the influence of voltage dips and voltage interruption in the power supply network.....	167
26	Abnormal operation tests.....	168
26.1	Abnormal temperature test.....	168
26.2	Overload tests	169
26.3	Battery short-circuit test.....	170
Annex A	(normative) Indelibility of markings	188
Annex B	(normative) Measurement of creepage distances and clearances in air.....	190
Annex C	(informative) Nominal voltages of supply systems for different modes of overvoltage control	194
Annex D	(normative) Overvoltage categories	196
Annex E	(informative) Typical usage of controls and related overvoltage categories	197
Annex F	(normative) Pollution degrees	198
Annex G	(normative) Resistance to heat, fire and tracking tests	199
Annex H	(normative) Requirements related to functional safety	201
Annex I	(normative) Requirements for certain types of DC supplied controls.....	254
Annex J	(normative) Requirements for thermistor elements and controls using thermistors.....	256
Annex K	(normative) Circuit for measuring touch current	273
Annex L	(normative) Printed circuit board coating performance test.....	274
Annex M	(normative) Printed circuit board protection	276
Annex N	(informative) Explanatory notes for surge immunity test.....	279
Annex O	(informative) Guidance for applying Clause 11	283
Annex P	(normative) Requirements for SELV and PELV	286
Annex Q	(informative) Regional differences relevant for the member countries of Cenelec	289

Annex R (informative) National differences relevant in the United States of America.....	294
Annex S (informative) National differences relevant in Japan	295
Annex T (informative) National differences relevant in Canada	296
Annex AA (informative) Maximum manufacturing deviation and drift ^{a, b}	297
Annex BB (normative) Time factor	298
Annex CC (normative) Number of cycles.....	302
Annex DD (normative) Controls for use in agricultural confinement buildings	303
Annex EE (informative) Guide to the application of temperature sensing controls within the scope of IEC 60730-2-9	306
Bibliography.....	328
Figure 1 – Example of ports	41
Figure 2 – Structure of the document with respect to inherent safety and functional safety	45
Figure 101 – Impact tool	84
Figure 3 – Example of an electronic circuit with low power points	114
Figure 102 – Aluminium cylinder for temperature change method	146
Figure 4 – Test pin probe 13 of IEC 61032:1997	170
Figure 5 – Test finger probe B of IEC 61032:1997	171
Figure 6 – Test fingernail	172
Figure 7 – Impact test for free-standing controls	173
Figure 8 – Tumbling barrel.....	173
Figure 9 – Apparatus for testing durability of markings on rating labels.....	174
Figure 10 – Apparatus for flexing test	175
Figure 11 – Screw terminals and stud terminals	176
Figure 12 – Pillar terminals	177
Figure 13 – Mantle terminals.....	178
Figure 14 – Saddle and lug terminals	179
Figure 15 – Tabs.....	180
Figure 16 – Tabs for non-reversible connectors	181
Figure 17 – Receptacles	182
Figure 18 – Measurement of creepage distance and clearance	183
Figure 19 – Diagram for touch current measurement at operating temperature for single-phase connection of class II controls	184
Figure 20 – Diagram for touch current measurement at operating temperature for single-phase connection of controls other than class II	184
Figure 21 – Diagram for touch current measurement at operating temperature for three-phase connection of class II controls	185
Figure 22 – Diagram for touch current measurement at operating temperature for three-phase connection of controls other than class II	186
Figure 23 – Diagram for touch current measurement at operating temperature for single-phase connection of controls to three-wire, ground neutral supply other than class II.....	186

Figure 24 – Diagram for touch current measurement at operating temperature for two-phase connection of controls to three-wire, ground neutral supply other than class II	187
Figure B.1 – Narrow groove	191
Figure B.2 – Wide groove	191
Figure B.3 – V-shaped groove	191
Figure B.4 – Rib.....	191
Figure B.5 – Uncemented joint with narrow groove	192
Figure B.6 – Uncemented joint with wide groove	192
Figure B.7 – Uncemented joint with narrow and wide grooves	192
Figure B.8 – Diverging side walls	193
Figure B.9 – Narrow recess	193
Figure B.10 – Wide recess	193
Figure B.11 – Conductive floating part	193
Figure H.1 – V-Model for the software life cycle	222
Figure H.2 – Voltage variation test	241
Figure J.1 – Generic test circuit for inrush-current limiting thermistor endurance test	272
Figure K.1 – Circuit for measuring touch currents	273
Figure L.1 – Test sample	275
Figure M.1 – Example of type 1 protection	277
Figure M.2 – Example of type 2 protection	278
Figure N.1 – Example of surge protection by shielding in buildings with common earth reference systems	281
Figure N.2 – Example of secondary surge protection in buildings with separate common earth reference systems	282
Figure N.3 – Example of primary and secondary surge protection of indoor/outdoor equipment.....	282
Figure O.1 – Guidance flowchart for application of requirements of Clause 11	284
Figure BB.1 – Determination of time factor in the case of a sudden temperature change	299
Figure BB.2 – Determination of time factor in the case of a linear rise of test-bath temperature	300
Figure EE.1 – Thermostat	316
Figure EE.2 – Self-resetting temperature limiter.....	317
Figure EE.3 – Non-self-resetting temperature limiter	317
Figure EE.4 – Self-resetting thermal cut-out	319
Figure EE.5 – Manual reset thermal cut-out	319
Figure EE.6 – Single-operation device	321
Figure EE.7 – Three-stage control system	322
Figure EE.8 – Schematic diagram showing usage of various controls approved to IEC 60730-2-9	324
Table 1 – Required technical information and methods of providing these information	52
Table 2 – Cross-sectional area of conductors	68
Table 3 – Terminal conductors.....	69
Table 4 – Conductor pull test values	70

Table 5 – Nominal cross-sectional areas of conductors.....	72
Table 6 – Axial force values for tab insertion and withdrawal	73
Table 7 – Minimum cord conductor sizes	89
Table 8 – Data exchange	94
Table 9 – Threaded parts torque test values	100
Table 10 – Rated impulse voltage for equipment energized directly from the supply mains (from IEC 60664-1:2007, Table F.1)	103
Table 11 – Clearances for insulation co-ordination (from IEC 60664-1:2007, Table F.2).....	104
Table 12 – Minimum creepage distances for basic insulation	108
Table 13 – Minimum creepage distances for functional insulation	109
Table 14 – Electrical/electronic component fault modes	115
Table 15 – Minimum insulation resistance.....	123
Table 16 – Insulation or disconnection test voltages	124
Table 17 – Maximum heating temperatures.....	128
Table 18 – Electrical conditions for the overvoltage and endurance tests.....	134
Table 19 – Electrical conditions for the overload tests of 19.7 and 19.10	136
Table 20 – Electrical conditions for the endurance tests of 19.8, 19.9, 19.11, 19.12 and 19.13	137
Table 21 – Pull-cord force test values	149
Table 22 – Pull and torque values	151
Table 23 – Emission limit for residential electromagnetic environment.....	157
Table 24 – Emission limit for industrial electromagnetic environment.....	158
Table 25 – The applicable EMC test in relation to the class of control function and type of Action	160
Table 26 – Immunity test requirements for residential electromagnetic environments.....	162
Table 27 – Immunity test requirements for industrial electromagnetic environment	164
Table 28 – Performance criteria	166
Table 29 – Maximum winding temperature (for test of mechanical blocked output conditions).....	169
Table B.1 – Value of X	190
Table C.1 – Inherent control or equivalent protective control.....	194
Table C.2 – Cases where protective control is necessary and control is provided by surge arresters having a ratio of clamping voltage to rated voltage not smaller than that specified by IEC 60099-1	195
Table E.1 – Typical usage.....	197
Table H.1 – Additional items to Table 1.....	212
Table H.2 – Acceptable measures to address fault/errors ^a	216
Table H.3 – Examples of techniques/measures for semi-formal methods	223
Table H.4 – Examples of techniques/measures for software architecture specification	223
Table H.5 – Examples of techniques/measures for module design specification	224
Table H.6 – Examples of techniques/measures for design and coding standards	224
Table H.7 – Examples of techniques/measures for software module testing	225
Table H.8 – Examples of techniques/measures for software integration testing.....	226
Table H.9 – Examples of techniques/measures for software safety validation	226

Table H.10 – Combinations of analytical measures during hardware development	228
Table H.11 – Examples of defences against unauthorised access and transmission failure modes	229
Table H.12 – Applicable test levels in addition to Clause 25.....	238
Table H.13 – Voltage dips, short interruptions and voltage variations.....	239
Table H.14 – Test values for voltage variations.....	240
Table H.15 – Test voltages for test level 2 (depending on the installation class conditions).....	243
Table H.16 – Test level for electrical fast transient burst test	245
Table H.17 – Test levels for conducted disturbances on mains and I/O lines.....	247
Table H.18 – Test level for immunity to radiated electromagnetic fields	248
Table H.19 – Increased test level for radiated immunity	249
Table H.20 – Test level for supply frequency variations	250
Table H.21 – Test level for continuous fields.....	252
Table I.1 – Electrical transient conduction immunity in accordance with ISO 7637-2	254
Table I.2 – Electrical transient conduction immunity in accordance with ISO 7637-3	255
Table J.1 – Maximum current.....	258
Table J.2 – Normal operating conditions	259
Table J.3 – Samples for the test (clause reference)	260
Table J.4 – Electrical and thermal ratings of a thermistor	261
Table J.5 – Additional items to Table 1	262
Table J.6 – Sequence of calibration and conditioning tests for PTC thermistors	264
Table J.7 – Classes for PTC sensing thermistors	265
Table J.8 – Sequence of calibration and conditioning tests for NTC thermistors.....	266
Table J.9 – Classes for NTC sensing thermistors	267
Table J.10 – Number of cycles for endurance test.....	270
Table J.11 – Ageing test temperature	270
Table J.12 – Number of cycles for endurance test.....	271
Table L.1 – Environmental cycling conditions.....	274
Table M.1 – IEC 60664-3 test levels or conditions	276
Table O.1 – Example A – Using Annex O guidance for applying Clause 11	285
Table O.2 – Example B – Using Annex O guidance for applying Clause 11	285
Table Q.1 – Additional aging parameters for windings.....	290
Table AA.1 – Recommended values of manufacturing deviation and drift.....	297
Table BB.1 – Method to determine and verify time factor values (see 9.101).....	301
Table CC.1 – Number of cycles for independently mounted and in-line cord controls	302
Table EE.1 – Typical examples of the classification of temperature sensing controls in accordance with IEC 60730-2-9	322
Table EE.2 – Examples of controls expected to operate during IEC 60335 series, Clause 11 and Clause 19.....	325
Table EE.3 – Guidance on the common usage of types of control	326

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**Automatic electrical controls -
Part 2-9: Particular requirements for temperature sensing controls**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

This extended version (EXV) of the official IEC Standard provides the user with the full content of the Standard.

IEC 60730-2-9:2026 EXV includes the content of IEC 60730-2-9:2026 and the references made to IEC 60730-1:2022.

The specific content of IEC 60730-2-9:2026 is displayed on a blue background.

IEC 60730-2-9 has been prepared by IEC technical committee 72: Automatic electrical controls. It is an International Standard.

This fifth edition cancels and replaces the fourth edition published in 2015, Amendment 1:2018 and Amendment 2:2020. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) adoption of IEC 60730-1:2022 with all of its significant changes to IEC 60730-1:2013, IEC 60730-1:2013/AMD1:2015 and IEC 60730-1:2013/AMD2:2020.

The text of this International Standard is based on the following documents:

Draft	Report on voting
72/1534/FDIS	72/1540/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

This part 2-9 is intended to be used in conjunction with IEC 60730-1. It was established on the basis of the sixth edition of that standard (2022). Consideration can be given to future editions of, or amendments to, IEC 60730-1.

This part 2-9 supplements or modifies the corresponding clauses in IEC 60730-1, so as to convert that publication into the IEC standard: Particular requirements for temperature sensing controls.

Where this part 2-9 states "addition", "modification" or "replacement", the relevant requirement, test specification or explanatory matter in part 1 should be adapted accordingly.

When a particular subclause of Part 1 is not mentioned in this Part 2, that subclause applies.

In the development of a fully international standard it has been necessary to take into consideration the differing requirements resulting from practical experience in various parts of the world and to recognize the variation in national electrical systems and wiring rules.

The reader's attention is drawn to the fact that Annex R, Annex S and Annex T list all of the "in-some-country" clauses on differing practices of a less permanent nature relating to the subject of this document.

In this publication:

The following print types are used:

- requirements proper: in roman type;
- *test specifications: in italic type;*
- explanatory matter: in smaller roman type;
- Defined terms: **bold type**.

Subclauses, notes or items which are additional to those in Part 1 are numbered starting from 101, additional annexes are lettered AA, BB, etc.

A list of all parts of the IEC 60730 series, under the general title: *Automatic electrical controls*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

Sample Document

get full document from standards.iteh.ai

1 Scope

This document applies to temperature sensing controls

- for use in, on, or in association with equipment for household appliance and similar use, including equipment for heating, air-conditioning and similar applications. The equipment can use electricity, gas, oil, solid fuel, solar thermal energy, etc., or a combination thereof.

NOTE 1 Throughout this document, the word "equipment" means "appliance and equipment" and "controls" means "temperature sensing controls".

- for building automation within the scope of ISO 16484 series and IEC 63044 series (HBES/BACS);

EXAMPLE 1 Independently mounted temperature sensing controls, controls in smart grid systems and controls for building automation systems within the scope of ISO 16484-2.

- for equipment that is used by the public, such as equipment intended to be used in shops, offices, hospitals, farms and commercial and industrial applications;

EXAMPLE 2 Controls for commercial catering, heating and air-conditioning equipment.

- that are **smart enabled controls**;

EXAMPLE 3 Smart grid control, remote interfaces/control of energy-consuming equipment including computer or smart phone.

- that are AC or DC powered controls with a rated voltage not exceeding 690 V AC or 600 V DC;
- used in, on, or in association with equipment that use electricity, gas, oil, solid fuel, solar thermal energy, etc., or a combination thereof;
- utilized as part of a control system or controls which are mechanically integral with multifunctional controls having non-electrical outputs;
- using NTC or **PTC thermistors** and to discrete **thermistors**, requirements for which are contained in Annex J;
- that have electrical circuits and **control** circuits which are, for example, operated by bimetals, magnet coils, memory metals, pressure elements, temperature-sensitive expansion elements or electronic elements.
- as well as manual controls when such are electrically and/or mechanically integral with automatic controls.

NOTE 2 Requirements for manually actuated mechanical switches not forming part of an automatic control are contained in IEC 61058-1-1.

This document applies to

- the inherent safety of automatic electrical controls, and
- functional safety of temperature **sensing controls** and safety related systems,
- controls where the performance (for example the effect of EMC phenomena) of the product can impair the overall safety and performance of the controlled system,
- the operating values, operating times, and operating sequences where such are associated with equipment safety and to the testing of automatic electrical temperature **sensing control** devices used in, or in association with, equipment,

EXAMPLE 4 **Boiler thermostats, fan controls, temperature limiters and thermal cut-outs.**

- electrical safety of temperature sensing controls with non-electrical outputs such as refrigerant flow and gas **controls**,
- **single-operation devices** as defined in this document.

This document specifies the requirements for construction, operation and testing of automatic electrical controls used in, on, or in association with an equipment.

This document does not

- apply to automatic electrical temperature **sensing controls** intended exclusively for industrial process applications unless explicitly mentioned in the relevant part 2 or the equipment standard. However, this document can be applied to evaluate automatic electrical controls intended specifically for industrial applications in cases where no relevant safety standard exists.
- take into account the response value of an automatic action of a control, if such a response value is dependent upon the method of mounting the control in the equipment. Where a response value is of significant purpose for the protection of the user, or surroundings, the value defined in the appropriate equipment standard or as determined by the manufacturer will apply.
- address the integrity of the output signal to the network devices, such as interoperability with other devices unless it has been evaluated as part of the control system.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60038, *IEC standard voltages*

IEC 60065:2014, *Audio, video and similar electronic apparatus – Safety requirements*

IEC 60068-2-75, *Environmental testing – Part 2-75: Tests – Test Eh: Hammer tests*

IEC 60085, *Electrical insulation – Thermal evaluation and designation*

IEC 60099-1:1991, *Surge arresters – Part 1: Non-linear resistor type gapped surge arresters for a.c. systems*¹

IEC 60112:2020, *Method for the determination of the proof and the comparative tracking indices of solid insulating materials*

IEC 60127 (all parts), *Miniature fuses*

IEC 60216-1, *Electrical insulating materials - Thermal endurance properties - Part 1: Ageing procedures and evaluation of test results*

IEC 60227-1, *Polyvinyl chloride insulated cables of rated voltages up to and including 450/750 V – Part 1: General requirements*

IEC 60245-1, *Rubber insulated cables – Rated voltages up to and including 450/750 V – Part 1: General requirements*

IEC 60269 (all parts), *Low-voltage fuses*

IEC 60335-1:2020, *Household and similar electrical appliances – Safety – Part 1: General requirements*

¹ Withdrawn.