



IEC 60800

Edition 4.1 2026-06

INTERNATIONAL STANDARD

CONSOLIDATED VERSION

Heating cables with a rated voltage up to and including 300/500 V for comfort heating and prevention of ice formation

Sample Document

get full document from standards.iteh.ai



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2026 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Secretariat
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search -

webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews, graphical symbols and the glossary. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 500 terminological entries in English and French, with equivalent terms in 25 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	3
INTRODUCTION.....	5
1 Scope.....	6
2 Normative references	6
3 Terms and definitions	8
4 Mechanical classification	10
5 Requirements for marking.....	10
6 Requirements for installation instructions	11
7 General requirements for construction of heating cables.....	12
7.1 General.....	12
7.2 Conductors	12
7.3 Insulation	13
7.4 Electrically conducting screen.....	13
7.5 Armouring	13
7.6 Sheath.....	13
7.7 Moisture resistance.....	13
8 Testing	14
8.1 Type tests – General requirements	14
8.2 Type tests – Detailed test requirements	14
8.2.1 Electrical resistance of heating conductors and screen.....	14
8.2.2 Water immersion and temperature cycling test.....	15
8.2.3 Verification of rated output for parallel heating cables.....	16
8.2.4 Verification of start-up current for parallel heating cables	16
8.2.5 Penetration test for electrically conductive screen	16
8.2.6 Flammability test	17
8.2.7 Deformation test for installation classification	18
8.2.8 Cold impact test.....	19
8.2.9 Cold bend test	20
8.2.10 Ageing test for insulation	21
8.2.11 Ageing test for non-metallic sheath.....	21
8.2.12 Compatibility test.....	21
8.2.13 Weathering and UV resistance test.....	22
8.2.14 Tensile test.....	23
8.2.15 Reverse winding test	23
8.2.16 Heat shock test.....	24
8.2.17 Shrinkage test for insulation and sheath	24
8.2.18 Hot set test.....	25
8.2.19 Cyclic ageing test for the heating cable	25
8.2.20 Cyclic ageing test for splices and end seals.....	25
8.2.21 Checking of the durability of markings	26
8.2.22 Pressure test at high temperature for insulation and sheath.....	26
8.3 Routine and sample tests.....	26
8.3.1 General remarks.....	26
8.3.2 Voltage test	27
8.3.3 Heating cable resistance and output verification	27
8.3.4 Insulation thickness	27

8.3.5	Sheath thickness	27
8.3.6	Hot set test.....	27
Annex A (normative) Weathering and UV resistance test		28
Bibliography.....		29
Figure 1 – Typical arrangement for splice testing		17
Figure 2 – Typical arrangement for end seal testing.....		18
Figure 3 – Cold bend test.....		20
Figure 4 – Jaws for tensile machine		23

Sample Document

get full document from standards.iteh.ai

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**Heating cables with a rated voltage up to and including 300/500 V
for comfort heating and prevention of ice formation**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of the official IEC Standard and its amendment has been prepared for user convenience.

IEC 60800 edition 4.1 contains the fourth edition (2021-11) [documents 20/1972/FDIS and 20/1991/RVD] and its amendment 1 (2026-06) [documents 20/2288/FDIS and 20/2294/RVD].

In this Redline version, a vertical line in the margin shows where the technical content is modified by amendment 1. Additions are in green text, deletions are in strikethrough red text. A separate Final version with all changes accepted is available in this publication.

IEC 60800 has been prepared by IEC technical committee 20: Electric cables. It is an International Standard.

This fourth edition cancels and replaces the third edition published in 2009. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) modification of the title: "up to and including", has been introduced;
- b) update of IEC 60811 references;
- c) introduction of a test for mechanical properties of sheaths after the water immersion and temperature cycling test;
- d) introduction of a weathering and UV resistance test according to ISO 4892-2:2013, Annex A.

The text of this International Standard is based on the following documents:

Draft	Report on voting
20/1972/FDIS	20/1991/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/standardsdev/publications.

The committee has decided that the contents of this document and its amendment will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

INTRODUCTION

This document is intended to provide a comprehensive overview of the essential requirements and testing appropriate to electrical resistance heating cables used for comfort heating and prevention of ice formation. While some of this work already exists in national standards or international standards, this document has collated much of this existing work.

This document provides a means to verify the electrical, thermal and mechanical durability of resistive heating cables, so that in normal use their performance is without danger to the user or surroundings. Compliance is checked by carrying out all the tests specified in this document.

Sample Document

get full document from standards.iteh.ai

1 Scope

This document is applicable to, and specifies requirements for resistive heating cables for low temperature applications such as comfort heating and the prevention of ice formation. These heating cables and heating cable sets can comprise either factory assembled or field (work-site) assembled units, and are heating cables assembled in accordance with manufacturer's instructions.

Bare conductors and protected conductors to be supplied at voltages equal to, or less than, 50 V are excluded from the scope of this document.

Typical applications include, but are not limited to:

- surface heating installed in or under surfaces;
- direct and storage heating;
- snow melting and frost protection of roofs, gutters, pipes, etc.

Electrical resistance trace heating systems for industrial and commercial applications are specified in the IEC 62395 series [1]¹ and for explosive atmospheres applications in the IEC/IEEE 60079-30 series [2], as are mineral insulated heating cables.

Applications in which the sheath temperature exceeds 100 °C are outside the scope of this document.

The object of this document is to ensure that electrical resistance heating cables operate safely under their normal defined conditions of use. This is achieved by:

- employing heating cables of the appropriate construction that meet the test criteria detailed in this document;
- including, for heating cables with an electrical protective component, a metallic braid, concentric wires or sheath, or other suitable electrically conductive material for protective purposes in case of fault;
- ensuring that the heating cables operate at safe temperatures with respect to the materials used in the construction of the cables and their installations according to national regulations.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050-461, *International Electrotechnical Vocabulary (IEV) – Part 461: Electric cables* (available at <http://www.electropedia.org>)

IEC 60228, *Conductors of insulated cables*

IEC 60332-1-1, *Tests on electric and optical fibre cables under fire conditions – Part 1-1: Test for vertical flame propagation for a single insulated wire or cable – Apparatus*

¹ Numbers in square brackets refer to the bibliography.

IEC 60332-1-2, *Tests on electric and optical fibre cables under fire conditions – Part 1-2: Test for vertical flame propagation for a single insulated wire or cable – Procedure for 1 kW pre-mixed flame*

IEC 60364-7-701, *Low-voltage electrical installations – Part 7-701: Requirements for special installations or locations – Locations containing a bath or shower*

IEC 60364-7-753, *Low-voltage electrical installations – Part 7-753: Requirements for special installations or locations – Heating cables and embedded heating systems*

IEC 62230, *Electric cables – Spark test method*

IEC 60811-201, *Electric and optical fibre cables – Test methods for non-metallic materials – Part 201: General tests – Measurement of insulation thickness*

IEC 60811-202, *Electric and optical fibre cables – Test methods for non-metallic materials – Part 202: General tests – Measurement of thickness of non-metallic sheath*

IEC 60811-401, *Electric and optical fibre cables – Test methods for non-metallic materials – Part 401: Miscellaneous tests – Thermal ageing methods – Ageing in air oven*

IEC 60811-404, *Electric and optical fibre cables - Test methods for non-metallic materials - Part 404: Miscellaneous tests - Mineral oil immersion tests for sheaths*

IEC 60811-501, *Electric and optical fibre cables – Test methods for non-metallic materials – Part 501: Mechanical tests – Tests for determining the mechanical properties of insulating and sheathing compounds*

IEC 60811-502, *Electric and optical fibre cables – Test methods for non-metallic materials- Part 502: Mechanical tests – Shrinkage test for insulations*

IEC 60811-503, *Electric and optical fibre cables – Test methods for non-metallic materials – Part 503: Mechanical tests – Shrinkage test for sheaths*

IEC 60811-506, *Electric and optical fibre cables – Test methods for non-metallic materials – Part 506: Mechanical tests – Impact test at low temperature for insulations and sheaths*

IEC 60811-507, *Electric and optical fibre cables – Test methods for non-metallic materials – Part 507: Mechanical tests – Hot set test for cross-linked materials*

IEC 60811-508, *Electric and optical fibre cables – Test methods for non-metallic materials – Part 508: Mechanical tests – Pressure test at high temperature for insulation and sheaths*

IEC 60811-509, *Electric and optical fibre cables – Test methods for non-metallic materials – Part 509: Mechanical tests – Test for resistance of insulations and sheaths to cracking (heat shock test)*

IEC 62395-1:2013, *Electrical resistance trace heating systems for industrial and commercial applications – Part 1: General and testing requirements*

ISO 4892-3:2016, *Plastics – Methods of exposure to laboratory light sources – Part 3: Fluorescent UV lamps*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 60050-461 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

3.1

armouring

mechanical reinforcement of the heating cable

Note 1 to entry: The reinforcement can be made of one or more layers of steel wires or braid, or of a metallic sheath or other suitable material.

3.2

cold lead

electrically insulated conductor or conductors used to connect a heating cable to the branch circuit and designed so that it does not produce significant heat

3.3

connection splice

sealed splice, connecting the heating cable to the cold lead, or an identical heating cable

3.4

earthing conductor

uninsulated conductor (drain wire) which is in good electric contact with the electrical screen along the length

3.5

electrically conductive screen

metallic braid, concentric wires, metallic sheath, or alternative covering with sufficient conductivity so that, when bonded to ground, will cause a residual current device (RCD) to operate under fault conditions

3.6

end termination

sealed termination, which may be heat producing, connected to the heating cable at the end opposite to that where the power is supplied

3.7

factory assembled heating cable set

heating cable set (unit) supplied with components, which are assembled by the manufacturer

3.8

field assembled heating cable

heating cable supplied in bulk with components to be assembled during installation

3.9

heating cable

cable, with or without an electrically conductive screen, metallic or equivalent, sheath or armour intended for emitting heat for heating purposes

3.10

heating cable set

heating cable with suitable power connection and end termination included

3.11

heating conductor

part of a serial heating cable in which the electrical energy is transformed into heat

3.12

insulation

material which insulates each conductor from other conductors or from conducting parts at earth potential

3.13

integral components

factory-assembled or field-assembled electrical terminations and connections, such as heat shrink terminations, moulded end seals or splices, which conform to the general shape of the heating cable and are exposed to the same environments as the heating cable

3.14

maximum sheath temperature

maximum temperature of the outermost covering of a heating cable

3.15

nominal voltage

actual voltage applied to the heating cable when in service

3.16

parallel heating cable

heating elements electrically connected in parallel, with the heating element either continuous or in discrete units or zones, such that the watt density per unit length is not significantly changed with any change in circuit length

3.17

rated resistance

resistance at 20 °C of 1 m of conductor

Note 1 to entry: Most heating cables contain more than one conductor and the resistance is measured for all conductors.

3.18

rated voltage

reference voltage for which the heating cable is designed

Note 1 to entry: The rated voltage is expressed by the combination of two values U_0/U , expressed in volts:

U_0 being the RMS value between any insulated conductor and "earth" (metal covering of the cable or the surrounding medium);

U being the RMS value between any two-phase conductors of a multicore cable or of a system of single-core cables.

Note 2 to entry: See IEC 62440:2008, 5.2 [3].

3.19

routine test

test made by the manufacturer on each manufactured length of cable to check that each length meets the specified requirements

3.20**sample test**

test made by the manufacturer on samples of completed cable or components taken from a complete cable, at specified frequency, so as to verify that the finished product meets the specified requirements

3.21**sheath**

uniform and continuous covering, metallic or non-metallic, enclosing the insulated conductor(s), used for mechanical protection and to protect the cable against influences from the surroundings

3.22**type test**

test made before supplying, on a general commercial basis, a type of cable covered by this document, in order to demonstrate satisfactory performance characteristics to meet the intended application

Note 1 to entry: Type tests are of such a nature that, after they have been made, they need not be repeated, unless changes are made in the cable materials or design or manufacturing process which might change the performance characteristics.

4 Mechanical classification

The heating cables in this document have been divided into two classes which indicate their ability to withstand mechanical forces during and after installation. These classes are as follows:

- mechanical class M1: for heating cables intended for installation with low risk of mechanical damage;
- mechanical class M2: for heating cables intended for installation with higher risk of mechanical damage.

The class of any heating cable is determined by its performance as measured against the requirements in 8.2.7, 8.2.8 and 8.2.14.

NOTE 1 Mechanical class M1: for heating cables intended for use in applications with low risk of mechanical damage, for example the installation on even surfaces like flat, smooth sub-floors of concrete or wooden materials or thermal insulations, embedded in screeds with no sharp objects.

NOTE 2 Mechanical class M2: for heating cables intended for use in applications with higher risk of mechanical damage, such as the installation on steel reinforcing grids, direct embedding in soil, in concrete with sharp objects, on roofs and gutters.

5 Requirements for marking

The product shall be identified by printing, embossing or indenting on the sheath or on a label attached to the product or on a component inside the heating cable.

Embossing shall not be used on the insulation.

A label shall be attached to the product in a permanent way and be clearly detectable to the electrical installer.

The label shall be attached to the part of the product which is clearly visible when unpacking the product ready for installation.

The marking shall at least contain:

- the identification of the manufacturer by name and/or a symbol;
- the type reference;
- the resistance per metre of heating cable at 20°C in ohms per metre for single or twin conductor series resistive heating cables and for a parallel heating cable, the power output in watts per metre at a reference temperature. This is not required for heating cable sets;
- the mechanical classification;
- the rated voltage for parallel heating cables or maximum nominal voltage for series heating cables;
- if applicable, the indication "not flame-retardant".

The distance between the end of one complete set of marks and the beginning of the next shall not exceed:

- 550 mm, if the marking is on the sheath;
- 275 mm, if the marking is on a component inside the heating cable.

If the units are factory assembled, the following additional information shall be provided:

For series resistive sets:

- nominal voltage;
- total wattage and wattage per metre;
- total resistance.

For parallel resistive sets:

- nominal voltage;
- power output in watts per metre at a reference temperature or total wattage.

Printed marking shall be durable. Compliance with this requirement shall be checked by the test given in 8.2.21.

The above are the minimum requirements and suppliers are free to add any additional information which may be useful, such as the following:

Traceability identification shall be added such as week and year of manufacture, or batch number.

NOTE National or regional regulations can give other requirements.

6 Requirements for installation instructions

The manufacturer shall provide product-specific installation instructions for heating cables, heating cable sets and components. The instructions shall be clearly identified as to the products and locations that apply, and shall include the following information:

- a) the intended use(s), either by general application type or by specific listed application;
- b) a means of isolating all line conductors from the supply;
- c) the indication that over-current protection is provided;
- d) the statement "Residual current device (RCD) having a residual current not exceeding 30 mA is required";

- e) for mechanical classification M1 heating cables, intended for reduced levels of mechanical forces, the statement "Caution: Do not use in areas subject to high mechanical loads or impact";
- f) an applicable statement to indicate that any metal sheath, braid, screen or equivalent electrically conductive covering of the heating cable shall be connected to an earth terminal;
- g) if unscreened heating cables are installed, the indication that they shall be covered by an electrically earthed mesh or equivalent and protected by a 30 mA RCD according to the installation standard. See also IEC 60364-7-701 and IEC 60364-7-753;
- h) minimum installation temperature;
- i) minimum bending radius;
- j) maximum sheath temperature, ~~if applicable~~;
- k) a statement such as: "The presence of the heating cable shall be made evident by the posting of caution signs or markings, at appropriate locations, such as at the power connection fittings and/or at frequent intervals along the circuit and be part of any electrical documentation following the installation";
- l) if applicable, the statement "The heating cable shall only be installed in concrete or other non-combustible materials";
- m) for series resistive heating cables with more than two conductors, the indication that the resistance of each conductor shall be given.

The above are the minimum requirements and suppliers are free to add any additional information which may be useful.

NOTE National regulations, or in their absence, the IEC 60364 series [4], can give additional requirements.

7 General requirements for construction of heating cables

7.1 General

The heating cables shall be designed and constructed so as to give electrical, thermal and mechanical durability, and so that, in normal use, their performance is without danger to the user or surroundings.

Tapes, fillers, filler strings, etc. may be used in the heating cable.

All integral components shall comply with this document.

Compliance is checked by all the requirements and tests specified in this document.

It is presupposed that all exposed parts of a heating cable and heating cable set intended for use in contact with tap water are constructed of materials that meet relevant national or local requirements.

7.2 Conductors

Conductors shall consist of one or more wires of pure or alloyed metal, or other suitable material.

The resistance of the heating conductors at 20 °C shall be in accordance with the values given by the manufacturer with a maximum tolerance of $\pm 10\%$.

The heating conductor-material used shall not have a negative temperature coefficient of resistance. Compliance shall be checked according to the test in 8.2.1.

7.3 Insulation

The insulating materials used in heating cables shall be suitable for the intended use. This shall be verified by meeting the tests and the requirements given in this document.

The minimum mean value of the insulation thickness shall be stated by the manufacturer and measured in accordance with IEC 60811-201, and meet the minimum requirements specified in 8.3.4.

7.4 Electrically conducting screen

When applicable and required, heating cables shall be provided with an evenly distributed electrically conductive metallic screen, or electrically conductive metallic sheath, tape or laminate or other suitable electrically conductive material. The metallic screen or electrically conductive material shall enable protection device(s) to operate as intended.

NOTE 1 For heating cables without an electrically conducting screen, additional national requirements can apply.

The resistance of the conductive sheath or screen, inclusive of a separate earthing conductor which shall be in contact with the sheath or screen, shall be not higher than the resistance of each conductor in the heating cable or higher than the resistance of a plain copper conductor having a 0,5 mm² cross-sectional area as given for a class 1 conductor according to IEC 60228, whichever is the lesser. A number of copper wires may be included in order to comply with the requirements.

NOTE 2 In some countries, national regulations require the resistance to be less than that of 0,5 mm² copper conductors.

Compliance shall be checked as described in 8.2.1.

If a conductive sheath or screen alone is used as the earthing conductor, the resistance measured shall be the total resistance including the earthing connection wire (drain wire).

Electrically conductive screens shall be so constructed as to prevent the penetration of foreign substances greater than 1 mm in diameter into the insulation without touching the screen. Compliance shall be checked by the test specified in 8.2.5.

7.5 Armouring

Separate armouring, if any, may consist of metallic or non-metallic wires, sheath, tape or laminate. Electrically conductive armouring shall be so constructed as to prevent the penetration of foreign substances greater than 1 mm in diameter into the insulation without touching the armouring. Compliance shall be checked by the test specified in 8.2.5.

NOTE National regulations can give other requirements.

7.6 Sheath

The sheathing materials used in heating cables shall be suitable for the intended use. This shall be verified by meeting the tests and the requirements given in this document. A non-metallic outer sheath shall give mechanical and/or corrosion protection dependent on the type of heating cable.

The minimum mean value of the sheath thickness shall be stated by the manufacturer and measured in accordance with IEC 60811-202, and meet the minimum requirements specified in 8.3.5.

7.7 Moisture resistance

Heating cables shall comply with the requirements as stated in 8.2.2.