

INTERNATIONAL ELECTROTECHNICAL COMMISSION

IEC 60840
Edition 5.0 2020-05

AMENDMENT 1 –
POWER CABLES WITH EXTRUDED INSULATION AND THEIR ACCESSORIES FOR RATED VOLTAGES ABOVE
30 kV (UM = 36 kV) UP TO 150 kV (UM = 170 kV) – TEST METHODS AND REQUIREMENTS

CORRIGENDUM 1

Figure E.1 – Schematic diagram of apparatus for water penetration test

Replace:

“length = (8 000 ± 50) mm”

with:

“length = (6 000 ± 50) mm”

IEC 60840:2020/AMD1:2023/COR1:2025

Figure F.1 – Schematic diagram of apparatus for water penetration test in the conductor

Replace:

“length = (4 000 ± 50) mm”

with:

“length = (3 000 ± 50) mm”