

INTERNATIONAL STANDARD

**Nuclear power plants - Instrumentation, control and electrical power systems -
Requirements for static uninterruptible DC and AC power supply systems**

get full document from standards.iteh.ai



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2025 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Secretariat
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search -

webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews, graphical symbols and the glossary. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 500 terminological entries in English and French, with equivalent terms in 25 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD	3
INTRODUCTION	5
1 Scope	7
2 Normative references	7
3 Terms and definitions	8
4 Abbreviated terms	10
5 System requirements	10
5.1 General	10
5.2 Function and description	11
5.2.1 Preamble	11
5.2.2 Designations	13
5.2.3 Direct current systems	13
5.2.4 Alternating current systems	13
5.3 System divisions	14
5.4 System boundaries	14
6 Functional requirements for static uninterruptible power supplies	15
6.1 Static uninterruptible power supplies for systems important to safety	15
6.2 Batteries and battery chargers	15
6.3 Inverters and bypass switches	16
6.4 UPS	17
6.5 Converters used for voltage stabilization	18
6.6 I&C power supply using DC/DC converters and AC/DC converters	18
7 Requirements for distribution systems	18
7.1 System aspects	18
7.2 Load allocation	19
7.3 Electrical aspects	21
7.4 Earthing	22
8 Effects of loads on supply quality	22
8.1 General	22
8.2 Electromagnetic interference	22
8.3 Transients	23
8.4 Load current	23
8.5 Power supplies to loads of lower safety classification	23
9 Monitoring and protection	24
9.1 General	24
9.2 Monitoring	24
9.3 Electrical protection	24
10 Qualification of equipment	25
11 Design to cope with ageing	25
12 Testing	26
13 Maintenance	26
Annex A (informative) Examples of voltage input variations	27
Annex B (informative) Examples of specifications	29
B.1 Example 1: Specification for a DC power supply for equipment requiring a non-interruptible supply	29

B.2	Example 2: Specification for AC power supply for equipment requiring a non-interruptible supply	30
B.3	Example 3: Specification for DC power supply with DC/DC converter for equipment.....	31
B.4	Human factor engineering programme	32
Annex C (normative) Uninterruptible power supplies and distribution systems for power plants with passive design and SMRs.....		33
C.1	General.....	33
C.2	Recommendations and requirements	34
C.3	Safety assessment.....	34
Bibliography.....		35
Figure 1 – Boundary of a SUPS		12
Figure 2 – Example of one division of a SUPS system		20
Figure 3 – Example of I&C uninterruptible AC power supply system.....		21
Figure A.1 – Example of voltage variations on the on-site AC power system during clearing of a transmission system fault		27
Figure A.2 – Example of on-site voltage profile after loss of load (transfer to house load operation)		27
Figure A.3 – Example of simulated safety bus voltages, double open phase condition in the 400 kV line to the unit transformer		28
Table B.1 – Example 1: Specification for a DC power supply for equipment requiring a non-interruptible supply		29
Table B.2 – Example 2: Specification for AC power supply for equipment requiring a non-interruptible supply		30
Table B.3 – Example 3: Specification for DC power supply with DC/DC converter for equipment.....		31
Table C.1 – Features of electrical power systems that support the different levels of defence in depth as stated in IAEA Safety Standard Series SSR-2/1 (Rev. 1).....		33

INTERNATIONAL ELECTROTECHNICAL COMMISSION

Nuclear power plants - Instrumentation, control and electrical power systems - Requirements for static uninterruptible DC and AC power supply systems

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 61225 has been prepared by subcommittee 45A: Instrumentation, control and electrical power systems of nuclear facilities, of IEC technical committee 45: Nuclear instrumentation. It is an International Standard.

This fourth edition cancels and replaces the third edition published in 2019. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) expansion and clarification of the requirements for static uninterruptible DC and AC power supply systems to ease the application in SMRs and passive designs.

This International Standard is to be used in conjunction with IEC 61513:2011, IEC 60709:2018, IEC 60880:2006, IEC 62138:2018, IEC 62855:2016 and IEC 63046:2020.

The text of this International Standard is based on the following documents:

Draft	Report on voting
45A/1591/FDIS	45A/1610/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

Sample Document

get full document from standards.iteh.ai

INTRODUCTION

a) Technical background, main issues and organization of the standard

The 1993 issue of IEC 61225 was developed for specifying the requirements relevant to the design of electrical supplies for I&C systems in nuclear power plants. Considering the experience gathered worldwide on this subject, in 2003 working group A2 recommended a revision to this document to allow a new revision, IEC 61225 Ed. 2 (2005), to be consistently integrated into the SC 45A standard series. In 2015, working group A11 recommended a revision to this document following the publication of the revision of IAEA SSG-34 and that the scope of the standard should cover static uninterruptible power supplies for all types of connected equipment. In 2022, working group A11 recommended a revision to this document to ease the application to SMRs and passive designs.

International operating experience with electrical supply systems in nuclear power plants has highlighted a number of supply voltage variations and malfunctions, such as:

- voltage perturbations due to disturbances on the internal AC distribution system (with origin off-site or on-site).
- voltage overshoot on loss of grid.
- open phase conditions (one or two phases).
- asymmetrical faults.

These types of perturbations can degrade the performance of static uninterruptible power supplies and ultimately result in failure of connected equipment.

One of the objectives of the uninterruptible power supplies is to protect connected equipment from voltage variations on the on-site AC interruptible distribution system (the immunity concept). The power supplies also guarantee an output voltage with specified magnitude and waveform (in case of AC) to connected loads. The power supplies have the capacity to supply the relevant loads during a specified time regardless of any voltage variations on the on-site AC interruptible distribution system.

Examples of voltage and frequency variations in the incoming feeder to the supplies can be found in informative Annex A. Examples of specifications for static uninterruptible power supplies can be found in informative Annex B. Requirements for SMRs and passive designs are given in Annex C.

This document is applicable to the design of static uninterruptible electrical power supplies in new nuclear power plants (including SMRs and passive designs) when design work is initiated after the publication of this document and in general for nuclear facilities. It also serves as a reference for upgrading and modernizing existing nuclear power plants and facilities.

b) Situation of the current standard in the structure of the SC 45A standard series

IEC 61225 is a second level document specifically addressing the particular topic of requirements for electrical supplies.

For more details on the structure of the SC 45A standard series, see item d) of this introduction.

c) Recommendations and limitations regarding the application of this document

It is important to note that this document establishes no additional functional requirements for safety systems.

To ensure that the standard will continue to be relevant in future years, the emphasis has been placed on issues of principle, rather than specific technologies.

d) Description of the structure of the IEC SC 45A standard series and relationships with other IEC documents and other bodies documents (IAEA, ISO)

The top-level documents of the IEC SC 45A standard series are IEC 61513 and IEC 63046. IEC 61513 provides general requirements for I&C systems and equipment that are used to perform functions important to safety in NPPs. IEC 63046 provides general requirements for electrical power systems of NPPs; it covers power supply systems including the supply systems of the I&C systems. IEC 61513 and IEC 63046 are to be considered in conjunction and at the same level. IEC 61513 and IEC 63046 structure the IEC SC 45A standard series and shape a complete framework establishing general requirements for instrumentation, control and electrical systems for nuclear power plants.

IEC 61513 and IEC 63046 refer directly to other IEC SC 45A standards for general topics related to the categorization of functions and the classification of systems, qualification, separation, defence against common cause failure, control room design, electromagnetic compatibility, cybersecurity, software and hardware aspects for programmable digital systems, coordination of safety and security requirements and management of ageing. The standards referenced directly at this second level should be considered together with IEC 61513 and IEC 63046 as a consistent document set.

At a third level, IEC SC 45A standards not directly referenced by IEC 61513 or by IEC 63046 are standards related to specific equipment, technical methods, or specific activities. Usually these documents, which make reference to second-level documents for general topics, can be used on their own.

A fourth level extending the IEC SC 45 standard series, corresponds to the Technical Reports which are not normative.

The IEC SC 45A standards series consistently implements and details the safety and security principles and basic aspects provided in the relevant IAEA safety standards and in the relevant documents of the IAEA nuclear security series (NSS). In particular this includes the IAEA requirements SSR-2/1, establishing safety requirements related to the design of nuclear power plants (NPPs), the IAEA safety guide SSG-30 dealing with the safety classification of structures, systems and components in NPPs, the IAEA safety guide SSG-39 dealing with the design of instrumentation and control systems for NPPs, the IAEA safety guide SSG-34 dealing with the design of electrical power systems for NPPs and the implementing guide NSS17 for computer security at nuclear facilities. The safety and security terminology and definitions used by SC 45A standards are consistent with those used by the IAEA.

IEC 61513 and IEC 63046 have adopted a presentation format similar to the basic safety publication IEC 61508 with an overall life-cycle framework and a system life-cycle framework. Regarding nuclear safety, IEC 61513 and IEC 63046 provide the interpretation of the general requirements of IEC 61508-1, IEC 61508-2 and IEC 61508-4, for the nuclear application sector. In this framework IEC 60880, IEC 62138 and IEC 62566 correspond to IEC 61508-3 for the nuclear application sector. IEC 61513 and IEC 63046 refer to ISO as well as to IAEA GS-R part 2 and IAEA GS-G-3.1 and IAEA GS-G-3.5 for topics related to quality assurance (QA). At level 2, regarding nuclear security, IEC 62645 is the entry document for the IEC/SC 45A security standards. It builds upon the valid high-level principles and main concepts of the generic security standards, in particular ISO/IEC 27001 and ISO/IEC 27002; it adapts them and completes them to fit the nuclear context and coordinates with the IEC 62443 series. At level 2, IEC 60964 is the entry document for the IEC/SC 45A control rooms standards and IEC 62342 is the entry document for the ageing management standards.

NOTE It is assumed that for the design of I&C systems in NPPs that implement conventional safety functions (e.g. to address worker safety, asset protection, chemical hazards, and process energy hazards) international or national standards are applied.

1 Scope

This document specifies the performance and the functional characteristics of the low voltage static uninterruptible power supply (SUPS) systems in a nuclear power plant (NPP) and, when applicable, in nuclear facilities in general. An uninterruptible power supply (UPS) is an electrical equipment which draws electrical energy from a source, stores it, and maintains the supply in a specified form by means inside the equipment to output terminals. A SUPS has no rotating parts to perform its functions.

The specific design requirements for the components of the power supply system are covered by IEC standards and other standards listed in the normative references. Otherwise, specific component-level design requirements are outside the scope of this document.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60038, *IEC standard voltages*

IEC 60146-1-1, *Semiconductor converters – General requirements and line commutated converters – Part 1-1: Specification of basic requirements*

IEC 60146-2, *Semiconductor converters – Part 2: Self-commutated semiconductor converters including direct d.c. converters*

IEC 60364-4-41, *Low voltage electrical installations – Part 4-41: Protection for safety – Protection against electric shock*

IEC 60709, *Nuclear power plants – Instrumentation, control and electrical power systems important to safety – Separation*

IEC 61000 (all parts), *Electromagnetic compatibility (EMC)*

IEC 61513, *Nuclear power plants – Instrumentation and control important to safety – General requirements for systems*

IEC 62003, *Nuclear power plants – Instrumentation, control and electrical power systems – Requirements for electromagnetic compatibility testing*

IEC 62040 (all parts), *Uninterruptible power systems (UPS)*

IEC/IEEE 60780-323, *Nuclear facilities – Electrical equipment important to safety – Qualification*

IEC/IEEE 60980-344, *Nuclear facilities – Equipment important to safety – Seismic qualification*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

NOTE Other terms not defined below are defined in IAEA Safety Guides SSG-34 and SSG-39.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

3.1

anticipated operational occurrence

AOO

deviation of an operational process from normal operation that is expected to occur at least once during the operating lifetime of a facility but which, in view of appropriate design provisions, does not cause any significant damage to items important to safety or lead to accident conditions

[SOURCE: IAEA Nuclear Safety and Security Glossary, 2022 (Interim) Edition]

3.2

battery charger

electrical item used to convert AC into DC to charge batteries and to supply power to DC loads during normal operation

Note 1 to entry: The battery charger provides transformer isolation of the DC output from the AC input and is equipped with regulation and monitoring.

[SOURCE: IEEE 946, 2004]

3.3

common cause failure

CCF

failure of two or more structures, systems or components due to a single specific event or cause

[SOURCE: IAEA Nuclear Safety and Security Glossary, 2022 (Interim) Edition]

3.4

common mode failure

CMF

failure of two or more structures, systems or components in the same manner or mode due to a single specific event or cause

[SOURCE: IAEA Nuclear Safety and Security Glossary, 2022 (Interim) Edition]

3.5

diversity

presence of two or more independent (redundant) systems or components to perform an identified function, where the different systems or components have different attributes so as to reduce the possibility of common cause failure, including common mode failure

[SOURCE: IAEA Nuclear Safety and Security Glossary, 2022 (Interim) Edition]

3.6**division**

collection of items, including their interconnections, that form one redundancy of a redundant system or safety group

Note 1 to entry: Divisions can include multiple channels.

Note 2 to entry: Designation that enables the establishment and maintenance of physical, electrical, and functional independence from other redundant sets of items.

[SOURCE: IAEA SSG-39, 2016]

3.7**item important to safety**

item that is part of a safety group and/or whose malfunction or failure could lead to radiation exposure of the site personnel or members of the public

Note 1 to entry: Items important to safety include those structures, systems and components whose malfunction or failure could lead to undue radiation exposure of site personnel or members of the public;

[SOURCE: IAEA Nuclear Safety and Security Glossary, 2022 (Interim) Edition]

3.8**plant states**

Operational states		Accident conditions		
Normal operation	Anticipated operational occurrences	Design basis accidents	Design extension conditions	
			Without significant fuel degradation	With core melting

[SOURCE: IAEA Nuclear Safety and Security Glossary, 2022 (Interim) Edition]

3.9**redundancy**

provision of alternative (identical or diverse) structures, systems and components, so that any single structure, system or component can perform the required function regardless of the state of operation or failure of any other

[SOURCE: IAEA Nuclear Safety and Security Glossary, 2022 (Interim) Edition]

3.10**single failure**

failure which results in the loss of capability of a single system or component to perform its intended safety function(s), and any consequential failure(s) which result from it

[SOURCE: IAEA Nuclear Safety and Security Glossary, 2022 (Interim) Edition]

3.11**single failure criterion**

criterion (or requirement) applied to a system such that it must be capable of performing its task in the presence of any single failure

[SOURCE: IAEA Nuclear Safety and Security Glossary, 2022 (Interim) Edition]

4 Abbreviated terms

AC	alternating current
CCF	common cause failure
CMF	common mode failure
DC	direct current
EMC	electromagnetic compatibility
EMP	electromagnetic pulse
I&C	instrumentation and control
IGBT	insulated-gate bipolar transistor
NPP	nuclear power plant
SMR	small modular reactor
SUPS	static uninterruptible power supply
UPS	uninterruptible power supply

5 System requirements

5.1 General

This document defines requirements for reliable and robust SUPS systems in nuclear facilities including NPPs. In general, more stringent criteria are applied to items important to safety, such as power supplies, requiring additional verifications. However, the entire on-site and off-site power systems contribute to the reliability and robustness of the nuclear facilities power system. The same requirements should be applied to SUPS systems regardless of their importance to safety with a graded approach to verification and validation.

For SMRs and power plants with passive designs, the term "(highly) reliable power supply" is often used instead of "power supply important to safety". Provisions for power supplies important to safety apply in general for a reliable power system. These supplies are required for monitoring and actuation (if necessary) of systems important to safety.

Robust power supply systems shall have sufficient margins and built-in conservatism to ensure that:

- equipment ratings, capabilities and capacities required to meet intended goals are not exceeded during all postulated conditions considered in the safety case;
- equipment protection set points are selected to accommodate anticipated perturbations in the nuclear facility's electrical distribution system during all modes of operation and plant states;
- the equipment has the capacity and capability to support emergency operations.

The design of the power supplies shall include analysis of:

- transient, dynamic, and quasi-stationary variations in voltage and frequency (in case of AC power source);
- power interruptions on the incoming feeder (see 5.2.2) (or voltage or frequency dips exceeding the allowed dynamic variation range) lasting from milliseconds up to extended loss of all AC interruptible power supplies;
- asymmetrical conditions;
- independence of redundant parts of the power supply system and resilience against common cause failures (CCFs).