

CORRIGENDUM 1

11 Routine verification

Replace the existing sentence after the title by the following new text and new subclause:

This clause of Part 1 applies except as follows.

11.9 Dielectric properties

Addition after the first paragraph:

A dielectric test is not required on a DBO containing busbars and/or prefabricated main circuit wiring only, nor on simple constructions where inspection of the conductors and cables, including proper laying is sufficient.

11 Vérification individuelle de série

Remplacer la phrase existante après le titre par le nouveau texte suivant et le nouveau paragraphe suivant:

L'article de la Partie 1 s'applique avec les exceptions suivantes.

11.9 Propriétés diélectriques

Addition après le premier alinéa:

Un essai diélectrique n'est pas exigé pour un DBO comportant des jeux de barres et/ou un câblage préfabriqué du circuit d'alimentation, ni pour des constructions simples où l'inspection des conducteurs et des câbles, y compris le cheminement approprié est suffisant.