

INTERNATIONAL ELECTROTECHNICAL COMMISSION  
COMMISSION ÉLECTROTECHNIQUE INTERNATIONALE

---

IEC 61558-1  
Edition 3.0 2017-09

Safety of transformers, reactors, power supply  
units and combinations thereof -

Part 1: General requirements and tests

IEC 61558-1  
Édition 3.0 2017-09

Sécurité des transformateurs, bobines  
d'inductance, blocs d'alimentation et des  
combinaisons de ces éléments -

Partie 1: Exigences générales et essais

## CORRIGENDUM 1

Corrections to the French version appear after the English text.

Les corrections à la version française sont données après le texte anglais.

### 19.12 Winding construction

*Replace the existing fourth paragraph of 19.12.3 starting with "For spirally wrapped insulation..." with the following new text and new Figure 15:*

For spirally wrapped insulation, the measured **creepage distances and clearances** between layers, shall be those given in Clause 26.

If the measured **creepage distances and clearances** along the path between layers are higher than those for P2 in accordance with Table 21 and Table 22 no additional test according to 26.2.4 – Test A, and 26.2.5.1 – Test B is required. The test voltages of the type tests in Clause K.2 shall be applied with the conditions of K.2.5.

If the measured **creepage distances and clearances** are higher or equal than those for P1 and smaller than those for P2 in accordance with Table 21 and Table 22 the path between layers shall be sealed against ingress of dust and moisture, as described in 26.2.5.1 – Test B. The test voltages of the type tests in Clause K.2 shall be applied with the conditions of K.2.5.

If the measured **creepage distances and clearances** are less than those for P1 in accordance with Table 21, the path between layers shall be sealed as for a cemented joint in 26.2.4. This shall be tested in accordance with 26.2.4 – Test A with wires in usual delivery conditions. The test voltages of the type tests in Clause K.2 shall be applied with the conditions of K.2.5.

The principle for insulated spirally wrapped winding wires for 1 000 V AC for reinforced insulation is shown in Figure 15.