

INTERNATIONAL STANDARD

AMENDMENT 1

**Communication networks and systems for power utility automation -
Part 10: Conformance testing**

Sample Document

get full document from standards.iteh.ai



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2025 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Secretariat
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search -

webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews, graphical symbols and the glossary. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 500 terminological entries in English and French, with equivalent terms in 25 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

Warning! Make sure that you obtained this publication from an authorized distributor.

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**Communication networks and systems for power utility automation -
Part 10: Conformance testing**

AMENDMENT 1

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch> [and/or] www.iso.org/patents. IEC shall not be held responsible for identifying any or all such patent rights.

Amendment 1 to IEC 61850-10 has been prepared by IEC technical committee 57: Power systems management and associated information exchange.

The major changes in this amendment are as follows:

- server device conformance test procedures have been updated; new test cases are: sAss4, sAss5, sAssN7, sSrv14, sSrv15, sDs15, sSg11..sSg14, sRp15, sRp16, sRp17, sRp23, sRpN9, sBr29, sBrN9, sBrN10, sGop12, sGos8..15, sGos20..23, sGosN7, sSBOs8, sTm6, sTm7, sTmP1, sTmP2, sTmP5, sTmPN1;
- client device conformance test procedures have been updated; new test cases are: cAss10, cAssN8, cAssN9, cSrv10, cSrvN7..cSrvN9, cSg46, cRp14..22, cRp40..46, cBr14..22, cBr30..32, cBr46, cLog9, cLog46, cLogN4, cGcb46, cSBOs10, cFt16, cMsvcb1, cMsvcb2, cMsvcb46;

- sampled values test procedures have been merged into server;
- server IED configuration tool related conformance test procedures have been updated; the ICD export and SCD import test cases have been merged into server, new test cases are: tTf4, tTf5;
- System Configuration Tool related conformance test procedures have been updated; new test cases are: tSieN2, tSce8..10, tSceN2, tDfeN3, tSmo7..9, tSse4..7, tSsi5..6, tSeh7..11;
- GOOSE performance test procedures have been updated; the performance classes have been updated to align with the performance class definition updates.

The text of this Amendment is based on the following documents:

Draft	Report on voting
57/2769/FDIS	57/2797/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this Amendment is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications/.

A list of all parts of IEC 61850 series, under the general title *Communication networks and systems for power utility automation*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

1 Scope

Add the following new text after the first paragraph of the Scope (before the NOTE):

Cyber security extensions provided by IEC 62351 are conformance tested against the IEC 62351-100-4 and IEC 62351-100-6.

2 Normative references

Insert the following new normative references:

IEC/IEEE 61850-9-3:2016, *Communication networks and systems for power utility automation – Part 9-3: Precision time protocol profile for power utility*

IEC 61869-9:2016, *Instrument transformers – Part 9: Digital interface for instrument transformers*

Remove the following existing normative reference:

IEC 62439-3:2012, *Industrial communication networks – High availability automation networks – Part 3: Parallel Redundancy Protocol (PRP) and High Availability Seamless Redundancy (HSR)*

4 Abbreviated terms

Insert the following new abbreviated term:

PTP Precision Time Protocol

6 Device related conformance testing

Replace the existing text, figures (Figures 2 to 6) and tables (Tables 1 to 71) of Clause 6 with the following new text, figures and tables:

6.1 Test methodology

Communication testing needs at least two devices to communicate with each other. Comprehensive interoperability testing of all possible products is not feasible. Therefore, the test concept shall include test devices, test configurations, and test scenarios. The dynamic behaviour should be tested properly by using well-defined test cases.

Messages are generated to test the communication capabilities. Hardwired stimuli (contacts, voltages, currents, etc.) and stimuli coming over a serial link if applicable should be used if applicable.

Special attention shall be given to communication equipment such as star-couplers, switches, etc. which shall support all requested features of the standard but not introduce additional contingencies and limitations. The impact of the communication method (client-server, GOOSE, SV, etc.) used by the DUT shall be considered properly in the test procedures. Verification of functional applications (use of GOOSE messages) is not part of a conformance test even if advanced tools may offer such analysis.

6.2 Conformance test procedures

6.2.1 General

This subclause describes the test procedure requirements, test structure, the abstract test cases (what is to be tested). The format and a few examples of detailed test procedures (how to perform the test) are given in Annex A.


6.2.2 Test procedure requirements

The test procedure requirements are:

- The abstract test cases describe what shall be tested, the detailed test procedures describe how a test engineer, or a test system shall perform the test.
- Test cases include a reference to the applicable paragraph(s) in the referenced document(s).
- The test results shall be reproducible in the same test lab and in other test labs.
- Support automated testing with minimal human intervention, as far as reasonably possible.

- The tests shall focus on situations that cannot easily be tested during, for example, a factory or site acceptance test, and prevent inter-operability risks, for example:
 - check behaviour of the device on delayed, lost, double and out of order packets,
 - configuration, implementation, operation risks,
 - mismatching names, parameters, settings, or data types,
 - exceeding certain limits, ranges or timeouts,
 - force situations to test negative responses,
 - check all (control) state machine paths, and
 - force simultaneous control operations from multiple clients.
- The ACSI tests focus on the application layer (mapping).
- The device under test (DUT) is considered as a black box. The I/O and the communication interface are used for testing.
- The test includes testing the versions, data model and configuration file, and the use of applicable ISO/IEC 9646 series terminology.

The test procedures shall be formatted as outlined in Figure 2. With this format, the test procedures document can also be used as test report. A few test procedure examples are depicted in Annex A.



IEC

Figure 2 – Test procedure format

6.2.3 Test structure

The test cases are structured as follows:

- documentation and version control (IEC 61850-4);
- configuration file (IEC 61850-6);
- data model (IEC 61850-7-3 and IEC 61850-7-4);
- mapping of ACSI models and services (IEC 61850-7-2 and applicable SCSM).

6.2.4 Test cases to test a server device

6.2.4.1 General

This part of the IEC 61850 series specifies the test system architecture and abstract test cases for server devices. The abstract test cases shall be used for the definition of test procedures to run in tests.

NOTE The SCSM specific test procedures are provided by test facilities agreed upon by the market participants.

6.2.4.2 Test system architecture to test a server device

In order to be able to perform a server device test, a minimum test set-up is necessary. The test architecture contains (see Figure 3):

- DUT;
- client simulator to initiate and generate TPAA messages;
- GOOSE simulator to send correct and incorrect GOOSE messages;
- SV simulator to send correct and incorrect SV messages;
- test master to start/stop test cases, start/stop the analyzer and archive test results;
- time master;
- engineering tool to configure the DUT;
- protocol analyzer to store all the network traffic for each test case;
- signal generator to force binary and analogue events, controlled by the test master or test engineer.




Figure 3 – Test system architecture to test a server device

The test system shall include documentation regarding test system hardware and test system software.

6.2.4.3 Documentation and version control test procedure overview

The test cases listed in Table 1 shall apply.

Table 1 – Server documentation test cases

Test case	Test case description
sDoc1	Check if the major/minor software version in the PICS documentation and the DUT do match (IEC 61850-4). PICS shall contain: <ul style="list-style-type: none"> ACSI conformance statement according to IEC 61850-7-2:2010, Annex A IEC 61850-9-3 PICS (when supported) IEC 61869-9 conformance class a, b, c or d (when supported)
sDoc2	Check if the major/minor software version in the PIXIT documentation and software version of the DUT does match (IEC 61850-4). PIXIT shall indicate the required information as requested in the test cases
sDoc3	Check if the major/minor software version in the MICS documentation and software version of the DUT does match (IEC 61850-4). MICS shall indicate the semantics of all non-standard Logical Nodes, Data Objects, Data Attributes and enumeration. MICS may contain other items in additional sections of the MICS.
sDoc4	Check if the major/minor software version in the TICS documentation and software version of the DUT does match (IEC 61850-4). TICS shall indicate that the mandatory and applicable technical issues are implemented.
sDoc5	Check the ICD if the server capabilities in the IED "services" section(s) do correspond with the ACSI services specified in the PICS

6.2.4.4 Configuration file test cases

The test cases listed in Table 2 shall apply.

Table 2 – Server configuration file test cases

Test case	Test case description
sCnf1	Verify the SCL version = "2007", revision = "B", release = "4"
sCnf2	Verify the XML encoding is UTF-8 or utf-8; <?xml version="1.0" encoding="UTF-8"?>
sCnf3	Verify that the ICD validates according to SCL schema: version 2007, revision B, release 4
sCnf4	Use the ICT tool to export an ICD file. When ICD is not supported export IID file. Use this file for the remaining tests. It is not allowed to change this SCL file with general purpose tools such as an XML editor. Condition: when the ICD is not fixed
sCnf5	Import the ICD or IID file from sCnf4 into SCT SIMULATOR and generate SCD file as follows: <ul style="list-style-type: none"> update IED name change IP/MAC address change SubNetwork name add DataSet's (when supported) add ReportControl's (when supported) add GSEControl's (when supported) add SampledValueControl's (when supported) add data flows (ExtRef's) from other IED's (when nolctBinding=F) Import the SCD file into the ICT tool and select the IED to be handled from IED's named in the SCD file by IED name

Test case	Test case description
sCnf6	<p>Complete the GOOSE and SV subscribe from sCnf5 and export the IID file. Verify that the ExtRef intAddr does not change when the external binding changes. The intAddr should not contain external data.</p> <p>Condition: when GOOSE and/or SV subscribe is supported</p>
sCnf10	<p>Verify the ICD has at most one Substation or Line or Process exists at SCL level and the attribute "name" is "TEMPLATE".</p> <p>Condition: when Substation or Line or Process section is present</p>
sCnf11	<p>Verify the ICD has none of the LNode bound to an IED different from "TEMPLATE" or "none"</p> <p>Condition: when Substation section is present</p>
sCnf20	<p>Verify that the "Communication" element exists:</p> <ul style="list-style-type: none"> • IED/Services/DynAssociation or IED/AccessPoint/Services/DynAssociation is declared) and IED/AccessPoint/ Server is declared or • LN0/GSEControl element exist or • LN0/SampledValueControl element exist
sCnf21	<p>For each ConnectedAP/Address element:</p> <p>Verify that exactly one "P" element with attribute type="OSI-PSEL" with a valid value (non-empty, even number of characters, maximum 16 characters 0-9,A-F)</p> <p>Verify that exactly one "P" element with attribute type="OSI-SSEL" with a valid value (non-empty, even number of characters, maximum 16 characters 0-9,A-F)</p> <p>Verify that exactly one "P" element with attribute type="OSI-TSEL" with a valid value (non-empty, even number of characters, maximum 8 characters 0-9,A-F)</p> <p>(Note that if xsi:type mechanism is used then schema validator can automatically verify the type)</p> <p>Condition: IED/Services/DynAssociation is declared</p>
sCnf22	<p>Verify that for each accesspoint no more than one "P" element with attribute type="OSI-AP-Title" and "OSI-AE-Qualifier and "IP" and "IP-SUBNET", "IP-GATEWAY", OSI-NSAP, OSI-AP-Invoke, OSI-AE-Invoke and DNSName exists. For each of these that exist:</p> <p>Verify OSI-AP-Title value contains only decimal digits and non-repeating commas</p> <p>Verify OSI-AE-Qualifier value is decimal representation from 0-65535</p> <p>Verify IP and IP-SUBNET and IP-GATEWAY contain a "standard dotted-decimal" for Ipv4</p> <p>Verify Ipv6 and Ipv6-SUBNET and Ipv6-GATEWAY contain a RFC 4291 address with leading zeros for Ipv6</p> <p>Verify OSI-AP-Invoke and OSI-AE-Invoke values are between 0 and 65535.</p>
sCnf23	<p>For each GSE element:</p> <p>Address/P[type=MAC-Address] right digit of first octet is odd (1,3,5,7,9,B,D,F) (multicast).</p> <p>Address/P[type=VLAN-ID] present</p> <p>Address/P[type=PRIORITY] present</p> <p>Address/P[type=APPID] = 0000-3FFF or 8000-BFFF</p> <p>Condition: when GSE element is present</p>
sCnf24	<p>For each SMV element referencing a SampledValueControl whose attribute multicast=true or missing, verify Address/P[type=MAC-Address] right digit of first octet is odd (1,3,5,7,9,B,D,F) (multicast)</p> <p>For each SMV element referencing a SampledValueControl whose attribute multicast=false, verify Address/P[type=MAC-Address] right digit of first octet is even (0,2,4,6,8,A,C,E) (unicast)</p> <p>For each SMV element in the ICD:</p> <ul style="list-style-type: none"> • Address/P[type=VLAN-ID] present • Address/P[type=PRIORITY] = present • Address/P[type=APPID] = 4000-7FFF <p>Condition: when SMV element is present</p>
sCnf25	<p>Verify the ICD that each Subnetwork/ConnectedAP@iedName is "TEMPLATE"</p>
sCnf26	<p>Verify each Subnetwork/ConnectedAP@apName matches one of IED/AccessPoint@name</p>

Test case	Test case description
sCnf27	Verify for each GSE element, the GSE@cbName points to a GSEControl within the AccessPoint pointed to by GSE//@apName and GSE@IdInst. Condition: when GSE element is present
sCnf28	Verify for each SMV element, the SMV@cbName points to a SampledValueControl within the AccessPoint pointed to by SMV//@apName and SMV@IdInst. Condition: when SMV element is present
sCnf29	Verify that at least one SubNetwork type has value "8-MMS" when type is present or type is absent
sCnf40	Verify the ICD has exactly one IED element and that the attribute "name" of the element is "TEMPLATE"
sCnf41	Verify all FCDA elements reference existing data and that doName and (optional) daName contain correct references. (ref 61850-6:2010, 9.3.,7 Table 22). <ul style="list-style-type: none"> Verify attributes IdInst, InClass, doName, and fc are declared. Verify attribute InInst is declared if InClass is not "LLN0". Verify first component of doName references a DO@name and second component (if any) references a SDO@name within DO referenced by first component Verify first component of daName (if present) references a DA@name and other component (if any) references a BDA@name within structure hierarchy of the DA referenced by first component Verify that at most one component of doName/daName contains an index and that ix attribute is identical to this index (see 61850-6:2010, Table 22). Valid example:<FCDA IdInst="LD0" InClass="MHAI" InInst="1" fc="MX" doName="HA.phsAHar(0)" daName="cVal.mag.f" ix="0" />
sCnf42	Verify DOI/SDI/DAI structures match DataTypeTemplates (DOI@name is valid DO in LD/LN and DAI@name is a leaf within that DO and SDI@name form hierarchy between DOI and DAI)
sCnf43	Verify that the ICD has none of the ExtRef references IEDs different from TEMPLATE or "@" Condition: when ExtRef iedName attribute is present
sCnf44	Verify that the ICD has no ClientLN elements exist within ReportControl and no IEDName elements within GSEControl and SampledValueControl
sCnf45	Verify all GSEControl/SampledValueControl/ReportControl have confRev>0 when datSet is not empty
sCnf46	Verify IED@originalSciVersion, IED@originalSciRevision and IED@originalSciRelease attributes match corresponding attributes of SCL element (SCL@version, SCL@revision and SCL@release)
sCnf47	Verify multiple identically named DOI/SDI/DAI elements at the same level differ by "ix" attribute (either different "ix" or "ix" attribute not present). Condition: when DOI/SDI/DAI ix attribute is present
sCnf48	Verify multiple LLN0.SGCB do not appear in the same logical device hierarchy (defined by LLN0.GrRef which references the parent logical device) Condition: when multiple SGCB are present
sCnf49	Verify element "Log" exists only in LLN0 Condition: when Log is present
sCnf50	Verify that the name length of IED, Logical Devices, Logical Nodes, data objects, data attributes, data sets and control blocks do not exceed the maximum length as specified in IEC 61850-7-2:2010, 22.2 and SCSM
sCnf51	Verify that logical node LPHD is present in each root logical device (IEC 61850-7-1:2010, 8.2.5)
sCnf52	Verify that DUT/tool can import file with GSEControl in multiple LN0 Add one GSEControl to first and last LN0 in the configuration of the device Condition: Services/GSESettings attribute cbName is not "fix" or absent and multiple Logical Devices exist and GOOSE max > 1
sCnf60	Verify that the attribute nameLength="64" exists in the IED/Services element

Test case	Test case description
sCnf61	Verify that the Services section must not contradict existing control block and data sets; <ul style="list-style-type: none"> • Nr of DataSet elements <= ConfDataSet.max (if provided). • Nr of ReportControl instances <= ConfReportControl.max (if provided) • Nr of Buffered ReportControl instances <= ConfReportControl.maxBuf (if provided) • Nr of GSEControl <= GOOSE.max (if provided) • Nr of SMVControl <= SMVsc.max (if provided) • Nr of LogControl <= ConfLogControl.max (if provided) • Nr of LGOS instances <= SupSubscription.maxGo (if provided) • Nr of LSVS instances <= SupSubscription.maxSv (if provided)
sCnf62	Verify the AccessPoint/Services element does not contain the attribute nameLength Condition: when AccessPoint Services element is present
sCnf63	Verify AccessPoint/Services element does not contain any of the elements ConfLNs, and ConfLdName Condition: when AccessPoint Services element is present
sCnf64	Verify that in case SupSubscription is claimed to be supported at least one instance of LGOS or LSVS must be in the ICD. Condition: when SupSubscription element is present
sCnf65	Verify that if serviceType=GOOSE is specified for ExtRef the ClientServices.goose=true or ClientServices.rGOOSE=true. For serviceType=SMV the ClientServices.sv=true or ClientServices.rSV=true Condition: when serviceType=GOOSE or serviceType=SMV is present
sCnf70	Verify for each DAType/BDA or DOType/DA with attribute "bType"=Struct has attribute "type" whose value matches DAType@id; does not declare valKind and does not contain a <Val> element
sCnf71	Verify for each DAType/BDA or DOType/DA with attribute "bType"=Enum has attribute "type" whose value matches EnumType@id
sCnf72	Verify type names do not exceed 255 characters, contain no "whitespace" characters and contain only characters from Basic-Latin and Latin-1-Supplement
sCnf73	Verify that each DOType element contains at least one SDO or DA element
sCnf74	Verify for each DA with FC="CO" (except "SBO") that the associated DAType contains the element <ProtNs type="8-MMS">IEC 61850-8-1:2003</ProtNs> Verify for each DA name="SBO" (FC="CO") contains the ProtNS element NOTE type default value is 8-MMS so it's optional
sCnf75	Verify for each (instance of) DOType/DA[name=ctlModel] whose associated EnumType contains direct-with-normal-security has in the DOType a DA named "Oper". If ctlModel has valKind=RO and valImport=missing/false then use the configured ctlModel value instead of EnumType. Similar for sbo-with-normal-security, Oper, Cancel and SBO Similar for direct-with-enhanced-security, Oper Similar for sbo-with-enhanced-security, Oper, Cancel and SBOw
sCnf76	Deprecated same as sMdl18
sCnf80	Verify that <Val> element values actually match a value in the corresponding EnumType, "ord" shall not be used, only EnumVal element values. Ref IEC 61850-6:2010, Table 45.
sCnf81	Verify that <Val> elements values match IEC 61850-6:2010, Table "Data type mapping" (if no table rows then Val element is not allowed at all)
sCnf82	Verify for each LLN0 that if LLN0.NamPit.InNs is present it shall have value IEC 61850-7-4:2007B (and IdNs is valid domain name space), otherwise LLN0.NamPit.IdNs shall have value IEC 61850-7-4:2007B.
sCnf83	Verify each ctlModel has an associated <Val> element
sCnf84	Verify CDC=ORG references use the ACS1 format (with ".", no "\$" and no functional constraint) and that the reference does exist Condition: when a data object with CDC=ORG is present

Test case	Test case description
sCnf85	<p>Verify for each Logical Device whose LLN0 does not contain GrRef, the existence of Data Object LLN0.NamPlt</p> <p>Verify for each LLN0 which contains the DO NamPlt, the existence and non-null value for Data Attribute LLN0.NamPlt.configRev</p>
IEC 61869-9 configuration file test cases	
sCnf100	<p>Check if the server "ClientServices" capabilities in the ICD "services" section do match with the IED capabilities:</p> <ul style="list-style-type: none"> • sv=true • maxSMV = supported number of SV streams <p>Condition: when IEC 61869 SV subscribe is supported</p>
sCnf120	Verify that all LDevice's with an IEC 61869 MSVCB have inst=MUnn where nn are digits.
sCnf121	<p>Verify the existence of LPHD extension Data Objects: NamVariant, NamHzRtg, NamAuxVRtg (optional), NamHoldRtg and NamMaxDIRtg (table 903) and MaxDI (part 7-4 Ed2 Amd1)</p> <p>Verify the existence of LPHD.PhyNam data attributes: vendor, model, serNum, hwRev, swRev and d and that these attributes have valKind read-only.</p> <p>The effective logical node namespace: InNs = IEC 61869-9:2016[A]</p>
sCnf122	<p>Verify the existence of TCTR extension Data Objects: NamAccRtg, NamARtg, NamClipRtg (table 905) and Clip, HoldTmms (part 7-4 Ed2 Amd1)</p> <p>The effective logical node namespace: InNs= IEC 61869-9:2016[A]</p>
sCnf123	<p>Verify the existence of TVTR extension Data Objects: NamAccRtg, NamVRtg, NamClipRtg (table 907) and Clip, HoldTmms (part 7-4 Ed2 Amd1)</p> <p>The effective logical node namespace: InNs= IEC 61869-9:2016[A]</p>
sCnf124	<p>Verify for the logical nodes TCTR and TVTR naming;</p> <p>For the backwards compatible configuration: InnATCTR1, InnBTCTR2, InnCTCTR3, InnNTCTR4, UnnATVTR1, UnnBTVTR2, UnnCTVTR3, UnnNTVTR4</p> <p>For the preferred rates: InnpTCTRn and UnnpTVTRn, where nn is a number and p is the phase (IEC 61869-9:2011, 6.903.7 and 6.903.8)</p>
sCnf125	<p>Verify the sampled value control block:</p> <p>For backward compatible configuration:</p> <ul style="list-style-type: none"> – If name is MSVCB01; smpMod=SmpPerPeriod or absent, smpRate=80, confRev=1, nofASDU=1, smvID=xxxxMUnn01 – If name is MSVCB02; smpMod=SmpPerPeriod or absent, smpRate=256, confRev=1, nofASDU=8, smvID=xxxxMUnn02 – Name = MSVCBxx smpMod=SmpPerPeriod or absent, smpRate = 96 (the Japanese variant) where xx is not 01 nor 02 <p>For preferred rates:</p> <ul style="list-style-type: none"> – Name = MSVCBxx, smpMod=SmpPerSec where xx is not 01 nor 02 <p>Verify the SmvOpts (IEC 61869:2011, 6.903.1 and IEC 61850-6: Table 31)</p> <ul style="list-style-type: none"> – SmvOpt: sampleSynchronized="true" or absent; refreshTime="false" or absent; sampleRate="false" or absent; dataSet="false" or absent; security="false" or absent
sCnf126	<p>Verify the SV dataset naming and elements</p> <p>For backward compatible configuration:</p> <p>PhsMeas1 Dataset elements as specified in clause 6.903.10</p> <p>For preferred rates:</p> <p>PhsMeas2..99 (IEC 61869 6.903.10)</p> <p>Dataset elements sequence shall be i/q/i/q... and current proceeds voltage if both are present. Where multiple current or multiple voltage members for a common measurement point exist, they shall be adjacent and in the sequence: A, AB, B, BC, C, CA, N.</p> <p>The number of current and voltage elements shall match the number in the variant code currently under test.</p>

Test case	Test case description
sCnf127	Verify the AmpSv units, offset and scaleFactor attribute values match 61869-9:2011, Table 904, read-only and not vallmport=T Verify the VolSv units, offset and scaleFactor attribute values match 61869-9:2011, Table 906, read-only and not vallmport=T
sCnf128	Verify that if the device does not supply all samples for the backwards compatible rate(s), 'dummy' SAV data attributes might be referenced in the data set. To detect the difference between dummy and real samples in the SCL, the ICD shall have all LN's included but the ones that are not supported have the LN Mode preconfigured to "Off". Condition: a not supported channel
sCnf129	Check if the server "SMVSettings" capabilities in the ICD "services" section does match: <ul style="list-style-type: none"> • SamplesPerSec is present • SmpRate is present • SecPerSamples is absent • kdaParticipant / McSecurity is false or absent • pdcTimeStamp is false or absent • synchSrcId is absent/false/true (IEC 61850-9-2:2011/AMD1:2020)

6.2.4.5 Data model test cases

The test cases listed in Table 3 shall apply.

Table 3 – Server data model test cases

Test case	Test case description
sMdl1	Verify presence of mandatory data objects for each LN type and data attributes for each DO type. Passed when all objects/attributes are present
sMdl2	Verify presence of conditional presence true data objects for each LN type and data attributes for each DO type. Passed when all objects/attributes are present
sMdl3	Verify non-presence of conditional presence false data objects for each LN type and data attributes for each DO type. Passed when these objects/attributes are not present
sMdl4	Verify data model mapping according to applicable SCSM concerning name length and object expansion. Passed when mapping is according to applicable SCSM
sMdl5	Verify data model mapping according to applicable SCSM concerning organisation of functional components.
sMdl6	Verify data model mapping according to applicable SCSM concerning naming of control blocks and logs. Passed when mapping is according to applicable SCSM.
sMdl7	Verify type of all data objects for each LN type and all data attributes for each DO type. Passed when type of all objects/attributes do match with the IEC 61850-7-3, IEC 61850-7-4 and the applicable SCSM
sMdl8	Verify that the enum types and values from the SCL and in the device are in specified range. Passed when all enum types and values match the 2007B.nsd.
sMdl9	Check if manufacturer specific data model extensions are implemented according to the extension rules in IEC 61850-7-1:2010, Clause 14.
sMdl10	Check if the order of the data attributes with the same functional constraint of the DO type match with IEC 61850-7-3. Passed when all attributes are in matching order
sMdl11	Moved to sCnf50
sMdl12	Check that the rules for multiple data object instantiation are kept (IEC 61850-7-1:2010,14.6, IEC 61850-7-4)
sMdl13	Moved to sCnf82
sMdl14	Check the correct use of name spaces for non-substation power utility applications like for example Hydro and DER; Condition: when non-substation name space is used

Test case	Test case description
sMdl15	Check if the SCL configuration file used to configure the DUT corresponds with the actual data object references, data types, data sets and pre-configured data values (settings) exposed by the DUT on the network.
sMdl16	<p>Change one parameter/setting with vallImport=True of each configurable data type and FC (FC can be DC, CF or SP) using the SCT SIMULATOR</p> <p>Change one parameter/setting when vallImport=False or absent of each configurable data type and FC (FC can be DC, CF or SP) using the supplied IED configuration tool</p> <p>Check the updated online parameter/setting values correspond with the configured values in the SCL.</p> <p>Document the tested parameters in the test report.</p> <p>Condition when a parameter/setting is configurable</p>
sMdl17	<p>Check the "IdName" naming structure when supported. All online object references (including data sets, control block references and object references – CDC ORG) shall start with the "LDevice IdName" value instead of the "IED name" + "LDevice inst"</p> <p>Condition when Services ConflDName is present</p>
sMdl18	Verify that the indicated trigger option: <DA dchg, qchg, dupd > is conformant with the IEC 61850-7-3 standardized Trigger Option.
sMdl19	Configure IED attribute name in server resulting in a 64-character MMS domain name for the longest IdInst and verify online domain name agrees with configuration.
sMdl20	If ICD/IID file contains any valKind=Conf: Verify that online data model does not contain empty data structures as a result of all contained attributes being valKind=Conf
sMdl21	<p>Modify some LN prefix / instance number in the SCD file, reconfigure the IED and load onto the IED. Browse the IED data model and check that changes are in,</p> <p>Condition: when Services ConflNs fixPrefix=false or fixLnInst=false</p>
sMdl22	<p>Verify that at least one Logical Device has LPHDx.Proxy=false.</p> <p>Verify each tracking Data Object in LTRK (example: SpcTrk) appears in at most one LTRK Logical Node in all Logical Devices which have LPHDx.Proxy=false.</p> <p>For Logical Device with LPHDx.Proxy=true, no tests are required</p>
sMdl23	<p>Modify valKind from Set to RO in the SCD file, reconfigure the IED and load onto the IED. Browse the IED data model and check that the attributes are readonly.</p> <p>Condition: when Services ValueHandling setToRO=true, SICS-I211</p>
sMdl24	<p>Import a master clock device in the SCD file, reconfigure the IED and load onto the IED. Check that the IED synch to the master clock.</p> <p>Condition: SICS-I24 out-of-scope need clarification</p>
sMdl25	<p>Instantiate 2 new LGOS in the SCD file (IEC 61850-6:2009, Annex G) one from a GOOSE control block from a logical device with IdName and one without. Reconfigure the IED and load onto the IED. Browse the IED data model and check that the LGOS is present.</p> <p>Condition: when Services SupSubscription maxGo>0</p>
sMdl26	<p>Instantiate a new LSVS in the SCD file (IEC TR 61850-6:2016, Annex G) one from a Sampled Value control block from a logical device with IdName and one without. Reconfigure the IED and load onto the IED. Browse the IED data model and check that the LSVS is present.</p> <p>Condition: when Services SupSubscription maxSv>0</p>
sMdl27	<p>Verify that the IED can subscribe to a GOOSE published at the connectedAP of ServerAt accesspoint of another IED</p> <p>Condition: when GOOSE subscribe is supported</p>

6.2.4.6 Mapping of ACSI models and services test cases

Test items shall be grouped together in tables. The tables shall reflect the applicable service models specified in Figure 3 of IEC 61850-7-2:2010:

- application association (sAss);
- server, Logical device, Logical node, Data, and Data Attribute model (sSrv);
- data set model (sDs);
- service tracking (sTrk);
- substitution model (sSub);
- setting group model (sSg);
- unbuffered report control model (sRp);
- buffered report control model (sBr);
- log control model (sLog);
- generic object oriented substation events (sGop and sGos);
- control model (sCtl);
- time and time synchronisation model (sTm);
- file transfer model (sFt);
- Samples Values publishing (sSvp);
- Samples Values subscribing (sSvs).

Test cases are defined for each ACSI model and services in the following categories:

- positive = verification of normal conditions, typically resulting in response+
- negative = verification of abnormal conditions, typically resulting in response–

A test case is mandatory when the applicable ACSI model and ACSI service is supported by the DUT. This is specified in the PICS according to IEC 61850-7-2:2010, Annex A. The test result interpretation (passed/failed) depends on the declared IED capabilities e.g. in the ICD file as well as on the test result.

6.2.4.7 Application association model

6.2.4.7.1 Positive test cases

The test cases listed in Table 4 shall apply.

Table 4 – Association positive test cases

Test case	Test case description
sAss1	Associate and client-release a TPAA association (IEC 61850-7-2:2010, 8.3.2)
sAss2	Associate and client-abort TPAA association (IEC 61850-7-2:2010, 8.3.2)
sAss3	Associate with maximum number of clients simultaneously (PIXIT)
sAss4	Verify the negotiation of MMS initiate parameters
sAss5	Verify the server initiates the Associate