

INTERNATIONAL STANDARD

**High-voltage switchgear and controlgear -
Part 201: AC solid-insulation enclosed switchgear and controlgear for rated
voltages above 1 kV and up to and including 52 kV**

get full document from standards.iteh.ai



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2026 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Secretariat
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search -

webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews, graphical symbols and the glossary. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 500 terminological entries in English and French, with equivalent terms in 25 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD	8
INTRODUCTION	11
1 Scope	12
2 Normative references	12
3 Terms and definitions	13
3.1 General terms and definitions	13
3.2 Assemblies of switchgear and controlgear	15
3.3 Parts of assemblies	15
3.4 Switching devices	15
3.5 Parts of switchgear and controlgear	15
3.6 Operational characteristics of switchgear and controlgear	19
3.7 Characteristic quantities	21
3.8 Index of definitions	22
4 Normal and special service conditions	23
5 Ratings	24
5.1 General	24
5.2 Rated voltage (U_r)	24
5.3 Rated insulation level (U_d , U_p , U_s)	24
5.4 Rated frequency (f_r)	24
5.5 Rated continuous current (I_r)	24
5.6 Rated short-time withstand current (I_k , I_{ke})	25
5.6.101 Rated short-time withstand current (I_k)	25
5.6.102 Rated short-time phase to earth withstand current (I_{ke})	25
5.7 Rated peak withstand current (I_p , I_{pe})	25
5.7.101 Rated peak withstand current (I_p)	25
5.7.102 Rated peak phase-to-earth withstand current (I_{pe})	25
5.8 Rated durations of short-circuit (t_k , t_{ke})	26
5.8.101 Rated duration of short-circuit (t_k)	26
5.8.102 Rated duration of phase-to-earth short-circuit (t_{ke})	26
5.9 Rated supply voltage of auxiliary and control circuits (U_a)	26
5.10 Rated supply frequency of auxiliary circuits	26
5.11 Rated pressure of compressed gas supply for controlled pressure systems	26
5.101 Classification of earthing function through main switching device	26
5.102 Rated cable test voltages (U_{ct} (AC), U_{ct} (DC))	26
5.102.1 General	26
5.102.2 Rated power-frequency cable test voltage U_{ct} (AC)	27
5.102.3 Rated DC cable test voltage U_{ct} (DC) with rated duration t_{ct} (DC)	27
5.103 Ratings of the internal arc classification (IAC)	27
5.103.1 General	27
5.103.2 Types of accessibility	27
5.103.3 Classified sides	27
5.103.4 Rated arc fault currents (I_A , I_{Ae})	28

5.103.5	Rated arc fault duration (t_A , t_{Ae})	28
6	Design and construction	28
6.1	Requirements for liquids in switchgear and controlgear	28
6.2	Requirements for gases in switchgear and controlgear	28
6.3	Earthing of switchgear and controlgear	28
6.3.101	Earthing of the high-voltage conductive parts	28
6.3.102	Earthing of enclosure(s)	29
6.3.103	Earthing of withdrawable and removable parts	29
6.3.104	Earthing circuit	29
6.4	Auxiliary and control equipment	30
6.5	Dependent power operation	30
6.6	Stored energy operation	30
6.7	Independent unlatched operation (independent manual or power operation)	30
6.8	Manually operated actuators	30
6.9	Operation of releases	30
6.10	Pressure/level indication	30
6.11	Nameplates	31
6.12	Locking devices	33
6.13	Position indication	34
6.14	Degrees of protection provided by enclosures	34
6.14.1	General	34
6.14.2	Protection of persons against access to hazardous parts and protection of the equipment against ingress of solid foreign objects (IP coding)	34
6.14.3	Protection against ingress of water (IP coding)	34
6.14.4	Protection of equipment against mechanical impact under normal service conditions (IK coding)	34
6.15	Creepage distances for outdoor insulators	34
6.16	Gas and vacuum tightness	34
6.17	Tightness for liquid systems	34
6.18	Fire hazard (flammability)	34
6.19	Electromagnetic compatibility (EMC)	34
6.20	X-ray emission	34
6.21	Corrosion	35
6.22	Filling levels for insulation, switching and/or operation	35
6.101	General requirements for assemblies	35
6.102	Solid insulating enclosure	36
6.102.1	General	36
6.102.2	Covers and doors	36
6.102.3	Partition or shutter being part of the enclosure	37
6.102.4	Inspection windows	37
6.102.5	Ventilating openings, vent outlets	37
6.102.6	Protection category of the solid insulating enclosure against electric shock	38
6.102.7	Requirements for protection categories	38
6.103	High-voltage compartments	39
6.103.1	General	39
6.103.2	Fluid-filled compartments (gas or liquid)	40
6.103.3	Partitions and shutters	41
6.104	Removable parts	42

6.105	Provisions for dielectric tests on cables	43
6.106	Internal arc fault.....	43
7	Type tests	43
7.1	General.....	43
7.1.1	Basics	43
7.1.2	Information for identification of specimens	44
7.1.3	Information to be included in type-test reports	44
7.2	Dielectric tests	44
7.2.1	General	44
7.2.2	Ambient air conditions during tests	45
7.2.3	Wet test procedure	45
7.2.4	Conditions of switchgear and controlgear during dielectric tests	45
7.2.5	Criteria to pass the test	45
7.2.6	Application of the test voltage and test conditions.....	45
7.2.7	Tests of switchgear and controlgear of $U_r \leq 245$ kV	46
7.2.8	Tests of switchgear and controlgear of $U_r > 245$ kV	47
7.2.9	Artificial pollution tests for outdoor insulators.....	48
7.2.10	Partial discharge tests	48
7.2.11	Dielectric tests on auxiliary and control circuits.....	48
7.2.12	Voltage test as condition check	48
7.2.101	Dielectric tests on cable testing circuits	49
7.3	Radio interference voltage (RIV) test	49
7.4	Resistance measurement.....	49
7.4.1	Measurement of the resistance of auxiliary contacts class 1 and class 2	49
7.4.2	Measurement of the resistance of auxiliary contacts class 3	49
7.4.3	Electrical continuity of earthed metallic parts test	49
7.4.4	Resistance measurement of contacts and connections in the main circuit as a condition check.....	49
7.4.101	Requirement for protection category PB2.....	49
7.5	Continuous current tests	50
7.5.1	Condition of the test object	50
7.5.2	Arrangement of the equipment.....	50
7.5.3	Test current and duration.....	50
7.5.4	Temperature measurement during test	50
7.5.5	Resistance of the main circuit	51
7.5.6	Criteria to pass the test	51
7.5.101	Test report.....	51
7.6	Short-time withstand current and peak withstand current tests	51
7.6.1	General	51
7.6.2	Arrangement of the equipment and of the test circuit	52
7.6.3	Test current and duration.....	53
7.6.4	Condition of test object after test	53
7.7	Verification of the protection	54
7.7.1	Verification of the IP coding.....	54
7.7.2	Verification of the IK coding.....	54
7.8	Tightness tests	54
7.9	Electromagnetic compatibility tests (EMC)	54
7.10	Additional tests on auxiliary and control circuits	54
7.10.1	General	54

7.10.2	Functional tests	55
7.10.3	Verification of the operational characteristics of auxiliary contacts	55
7.10.4	Environmental tests	55
7.10.5	Dielectric test	55
7.11	X-radiation test procedures for vacuum interrupters	55
7.101	Verification of making and breaking capacities	55
7.101.1	General	55
7.101.2	Test requirements for main switching devices	56
7.101.3	Test requirements for earthing function	56
7.102	Mechanical operation tests	56
7.102.1	Switching devices and removable parts	56
7.102.2	Mechanical and electromechanical interlocks and locking devices	57
7.103	Pressure withstand test for gas-filled compartments	59
7.103.1	Pressure withstand test for gas-filled compartments with pressure relief devices	59
7.103.2	Pressure withstand test for gas-filled compartments without pressure relief devices	60
7.104	Tests to verify the protection of persons against dangerous electrical effects	60
7.104.1	General	60
7.104.2	Dielectric tests	60
7.104.3	Measurements of leakage currents	61
7.105	Internal arc test	61
7.105.1	General	61
7.105.2	Test conditions	62
7.105.3	Arrangement of the equipment	63
7.105.4	Test procedure	63
7.105.5	Criteria to pass the test	63
7.105.6	Test report	64
7.105.7	Extension of validity of test results	65
7.106	Thermal stability test	65
7.107	Humidity test	66
8	Routine tests	66
8.1	General	66
8.2	Dielectric test on the main circuit	66
8.3	Tests on auxiliary and control circuits	66
8.3.1	Inspection of auxiliary and control circuits, and verification of conformity to the circuit diagrams and wiring diagrams	66
8.3.2	Functional tests	67
8.3.3	Verification of protection against electrical shock	67
8.3.4	Dielectric tests	67
8.4	Measurement of the resistance of the main circuit	67
8.5	Tightness test	67
8.6	Design and visual checks	67
8.101	Partial discharge measurement	67
8.102	Mechanical operation tests	68
8.103	Pressure tests of gas-filled compartments	68
8.104	Tests after erection on site	68
8.105	Measurement of fluid condition after filling on site	69
9	Guide to the selection of switchgear and controlgear (informative)	69

9.1	General.....	69
9.2	Selection of rated values.....	69
9.3	Cable-interface considerations.....	70
9.4	Continuous or temporary overload due to changed service conditions.....	70
9.5	Environmental aspects.....	70
9.101	Selection of design and construction.....	70
9.101.1	General	70
9.101.2	Architecture and accessibility to high-voltage compartments.....	71
9.101.3	Service continuity of the switchgear and controlgear	72
9.102	Ratings related to earthing circuits.....	74
9.103	Internal arc fault.....	74
9.103.1	General	74
9.103.2	Causes and preventive measures	75
9.103.3	Supplementary protective measures	75
9.103.4	Considerations for the selection and installation	76
9.103.5	Internal arc test	77
9.103.6	IAC classification	78
9.104	Summary of technical requirements, ratings and optional tests	79
10	Information to be given with enquiries, tenders and orders (informative).....	81
10.1	General.....	81
10.2	Information with enquiries and orders	81
10.3	Information with tenders.....	82
11	Transport, storage, installation, operating instructions and maintenance	83
11.1	General.....	83
11.2	Conditions during transport, storage and installation	83
11.3	Installation	83
11.4	Operating instructions	83
11.5	Maintenance	84
12	Safety.....	84
12.101	Procedures	84
12.102	Internal arc aspects	84
13	Influence of the product on the environment	84
Annex A (normative)	Internal arc fault – Method to verify the internal arc classification (IAC).....	85
A.1	Room simulation	85
A.2	Indicators (for assessing the thermal effects of the gases).....	87
A.2.1	General	87
A.2.2	Arrangement of indicators.....	87
A.3	Tolerances for geometrical dimensions of test arrangements	88
A.4	Test parameters.....	88
A.4.1	General	88
A.4.2	Voltage	88
A.4.3	Current	88
A.4.4	Frequency	89
A.5	Test procedure.....	89
A.5.1	Supply circuit.....	89
A.5.2	Arc initiation	90
Annex B (normative)	Partial discharge measurement	99

B.1	General.....	99
B.2	Application.....	99
B.3	Test circuits and measuring instruments	100
B.4	Test procedure.....	100
Annex C (informative) Regional deviations.....		105
Annex D (normative) Humidity test.....		106
D.1	General.....	106
D.2	Test procedure and test conditions	106
D.2.1	Test cycle and its duration	106
D.2.2	Generation of fog.....	107
D.2.3	High air temperature period	107
D.2.4	Test chamber	107
D.2.5	Test object.....	107
D.2.6	Test voltage and voltage supply.....	108
D.2.7	Total test duration.....	108
D.3	Test criteria and evaluation.....	108
D.3.1	Criterion during the test	108
D.3.2	Criterion after the test.....	108
D.3.3	Evaluation of the test.....	108
Annex E (informative) Protection categories		110
E.1	Protection category PA	110
E.2	Protection categories PB.....	111
Annex F (informative) List of symbols and abbreviations used in IEC 62271-201		112
Annex G (normative) Flowchart categorisation procedure LSC for a given functional unit FU1 with connection compartment		113
Annex H (informative) Pressure coordination chart for gas-filled compartments		114
Bibliography.....		115
Figure 1 – LSC1.....		73
Figure 2 – LSC2.....		73
Figure 3 – LSC2.....		73
Figure 4 – LSC2.....		74
Figure 5 – LSC2A		74
Figure 6 – LSC2B		74
Figure 7 – LSC2B		74
Figure 8 – No LSC assigned		74
Figure 9 – No LSC assigned		74
Figure A.1 – Mounting frame for vertical indicators		92
Figure A.2 – Horizontal indicator.....		92
Figure A.3 – Position of the indicators.....		93
Figure A.4 – Room simulation and indicator positioning for accessibility A, classified rear side, ceiling above 2 000 mm, functional unit of any height.....		94
Figure A.5 – Ceiling height stated from the floor or false floor level where the switchgear is actually placed		96
Figure A.6 – Indicator positioning in case of protrusion at < 2 000 mm height, at classified side		97

Figure A.7 – Indicator positioning in case a bottom exhaust duct belonging to the assembly is defined as a walkable integrated part of the false floor	97
Figure A.8 – Room simulation and indicator positioning for accessibility type A, non-accessible rear side, ceiling at 2 000 mm, so functional unit $\leq$ 1 800 mm high	98
Figure B.1 – Partial discharge test circuit (three-phase arrangement)	103
Figure B.2 – Partial discharge test circuit (system without earthed neutral)	104
Figure D.1 – Test cycle	109
Figure D.2 – Test chamber	109
Figure E.1 – Possible designs for protection category PA	110
Figure E.2 – Possible designs for protection category PB	111
Figure G.1 – Flowchart categorisation procedure LSC for a given functional unit FU1 with connection compartment.....	113
Figure H.1 – Example of pressure coordination chart	114
Table 1 – Nameplate information	31
Table 2 – Locations, causes and examples of measures to decrease the probability of internal arc faults	76
Table 3 – Single-phase-to-earth arc fault current depending on the network neutral earthing	78
Table 4 – Summary of technical requirements, ratings and optional tests for assemblies	79
Table A.1 – Parameters for internal arc test according to compartment construction	91
Table B.1 – Test circuits and procedures	102

get full document from standards.iteh.ai

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**High-voltage switchgear and controlgear -
Part 201: AC solid-insulation enclosed switchgear
and controlgear for rated voltages above 1 kV
and up to and including 52 kV**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 62271-201 has been prepared by subcommittee 17C: Assemblies, of IEC technical committee 17: High-voltage switchgear and controlgear. It is an International Standard.

This third edition cancels and replaces the second edition published in 2014. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) aligned with the third edition of IEC 62271-200 published in 2021 and its Amendment 1 published in 2024, for structure, definitions, classifications, ratings and testing procedures, where appropriate;
- b) clause numbering aligned with IEC 62271-1:2017, including the adoption of the subclause names of Clause 3;

- c) in Clause 3 specific terms and definitions are added for "in service", "normal operating condition" and "normal use";
- d) earthing circuit is more precisely described, including ratings and test requirements;
- e) number of mechanical tests on interlocks is reduced for type testing;
- f) forces to apply during type testing are better prescribed (refer to 7.102);
- g) resistance measuring on main circuit is only needed before continuous current tests (as reference for routine tests) and not anymore needed after this continuous current test. Rationale for this deletion is that this measured resistance does not mean anything; as the temperature rise test was just finished, a new temperature rise test will not give new information;
- h) IEC 62271-100:2021 has been taken into account in 7.101.2;
- i) IEC 62271-107:2019 and IEC IEEE 62271-37-013:2021 are also considered in 7.101.2;
- j) LSC category is more precisely described, including an explaining flowchart (Annex G);
- k) examples not covered by the IAC test are transferred from Clause 6 to 9.103;
- l) the term "assembly" is defined in Clause 3 and used as synonym for "solid-insulation enclosed switchgear and controlgear" in this document;
- m) "metallic" is replaced by "metal" where applicable;
- n) a 1 s rule was introduced for Criterion 4 during IAC tests regarding hot gases versus glowing particles as cause of ignition;
- o) internal arc tests for switchgear with protrusions are more precisely described in Annex A;
- p) partitions accessible in normal use are now PA, PB1 or PB2 instead of PI which has been removed (refer to 6.103.3)

The text of this International Standard is based on the following documents:

Draft	Report on voting
17C/980/FDIS	17C/995/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

This document should be read in conjunction with IEC 62271-1:2017 and its Amendment 1:2021, to which it refers and which is applicable, unless otherwise specified. In order to simplify the indication of corresponding requirements, the same numbering of clauses and subclauses is used as in IEC 62271-1. Amendments to these clauses and subclauses are given under the same numbering, whilst additional subclauses are numbered from 101.

The reader's attention is drawn to the fact that Annex C lists all of the "in-some-country" clauses on differing practices of a less permanent nature relating to the subject of this document.

A list of all parts in the IEC 62271 series, published under the general title *High-voltage switchgear and controlgear*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

Sample Document

get full document from standards.iteh.ai

INTRODUCTION

High-voltage (IEC 60050-601:1985 [1],¹ 601-01-27) switchgear refers to rated voltages above 1 kV. However, medium-voltage is commonly used for distribution systems with rated voltages above 1 kV and generally applied up to and including 52 kV; refer to IEC 60050-601:1985 [1], 601-01-28.

Although primarily dedicated to three-phase systems, this document can also be applied to single-phase and two-phase systems.

Switchgear and controlgear assemblies having a metal enclosure are covered by IEC 62271-200 [2].

Gas-filled medium-voltage designs use to have design pressures below 500 kPa, as mentioned for example in the introduction of EN 50187 [3].

Sample Document

get full document from standards.iteh.ai

¹ Numbers in square brackets refer to the Bibliography.

1 Scope

This part of IEC 62271 is applicable to prefabricated solid-insulation enclosed switchgear and controlgear assemblies designed for:

- alternating current;
- rated voltages above 1 kV and up to and including 52 kV;
- service frequencies up to and including 60 Hz;
- indoor installation;
- areas limited to authorized personnel.

The assembly can include either air-insulated or fluid-filled compartments, or both.

For components installed in a solid-insulation enclosed switchgear and controlgear, this document supplements or even replaces in some cases, the requirements as stated by the individual product standards.

The list of components which can be inside the solid-insulation enclosed switchgear and controlgear is not limited to the ones explicitly cited in this document.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050-151, *International Electrotechnical Vocabulary (IEV) - Part 151: Electrical and magnetic devices*

IEC 60050-441, *International Electrotechnical Vocabulary (IEV) - Part 441: Switchgear, controlgear and fuses*

IEC 60060-1:2025, *High-voltage test techniques - Part 1: General terminology and test requirements*

IEC 60270, *High-voltage test techniques - Partial discharge measurements*

IEC 60529:1989, *Degrees of protection provided by enclosures (IP Code)*

IEC 60529:1989/AMD 1:1999

IEC 60529:1989/AMD 2:2013

IEC 62262:2002, *Degrees of protection provided by enclosures for electrical equipment against external mechanical impacts (IK code)*

IEC 62271-1:2017, *High-voltage switchgear and controlgear - Part 1: Common specifications for alternating current switchgear and controlgear*

IEC 62271-1:2017/AMD1:2021

IEC 62271-100:2021, *High-voltage switchgear and controlgear – Part 100: Alternating-current circuit-breakers*

IEC 62271-100:2021/AMD1:2024

IEC 62271-102:2018, *High-voltage switchgear and controlgear – Part 102: Alternating current disconnectors and earthing switches*
IEC 62271-102:2018/AMD1:2022

IEC 62271-103:2021, *High-voltage switchgear and controlgear - Part 103: Alternating current switches for rated voltages above 1 kV up to and including 52 kV*

IEC 62271-105:2021, *High-voltage switchgear and controlgear - Part 105: Alternating current switch-fuse combinations for rated voltages above 1 kV up to and including 52 kV*

IEC 62271-106:2021, *High-voltage switchgear and controlgear - Part 106: Alternating current contactors, contactor-based controllers and motor-starters*

IEC 62271-107:2019, *High-voltage switchgear and controlgear - Part 107: Alternating current fused circuit-switchers for rated voltages above 1 kV up to and including 52 kV*

IEC/IEEE 62271-37-013:2021, *High-voltage switchgear and controlgear - Part 37-013: Alternating current generator circuit-breakers*

ISO 4126-2, *Safety devices for protection against excessive pressure - Part 2: Bursting disc safety devices*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 62271-1, IEC 60050-151, IEC 60050-441 and the following apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- IEC Electropedia: available at <https://www.electropedia.org/>
- ISO Online browsing platform: available at <https://www.iso.org/obp>

NOTE The classification system for definitions of IEC 62271-1:2017 is followed. Terms and definitions are referenced and prioritized in the following order:

- Clause 3 of this document;
- IEC 62271-1:2017;
- IEC 60050-441;
- IEC 60050-151.

3.1 General terms and definitions

The definitions in 3.1 of IEC 62271-1:2017 are applicable, with the following additions:

3.1.101

ambient air temperature

<of an assembly> temperature, determined under specified conditions, of the air surrounding the enclosure of an assembly

[SOURCE: IEC 60050-441:1984, 441-11-13, modified – "prescribed" has been replaced by "specified", "complete switching device or fuse" by "enclosure of an assembly" and the note has been removed.]