

INTERNATIONAL STANDARD

**Lightning protection system components (LPSC) -
Part 2: Requirements for conductors and earth electrodes**

Sample Document

get full document from standards.iteh.ai



THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2025 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Secretariat
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search -

webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews, graphical symbols and the glossary. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 500 terminological entries in English and French, with equivalent terms in 25 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD	4
INTRODUCTION	6
1 Scope	7
2 Normative references	7
3 Terms and definitions	7
4 Requirements	10
4.1 General	10
4.2 Documentation and installation instructions	10
4.3 Air-termination conductors, air-termination rods, catenary wires and down conductors	10
4.4 Earth electrodes	13
4.4.1 General	13
4.4.2 Earth conductors	15
4.4.3 Earth rods	15
4.4.4 Earth plates and equipotential earth grids	15
4.4.5 Couplers for earth rods	15
4.5 Earth lead-in conductors	16
4.6 Marking	16
4.6.1 Content of marking	16
4.6.2 Durability and legibility	17
5 Tests	17
5.1 General test conditions	17
5.2 Air-termination conductors, air-termination rods, catenary wires, down conductors, earth lead-in conductors, earth conductors, earth plates and equipotential earth grids	17
5.2.1 General	17
5.2.2 Test for thickness of coating	18
5.2.3 Resistance test for coated conductors	20
5.2.4 Bending test for coated conductors	20
5.2.5 Environmental test for coated conductors	20
5.2.6 Electrical resistivity test	21
5.2.7 Tensile strength test	22
5.2.8 Material, configuration and cross-sectional area test	22
5.3 Earth rods	22
5.3.1 General	22
5.3.2 Test for thickness of coating on earth rods	22
5.3.3 Adhesion test for copper coated earth rods	22
5.3.4 Electrical resistance test for coated earth rods	23
5.3.5 Bending test for copper coated steel earth rods	24
5.3.6 Environmental test for coated earth rods	24
5.3.7 Electrical resistivity test for earth rods	24
5.3.8 Tensile strength test for earth rods	25
5.3.9 Test for yield/tensile ratio for copper coated steel earth rods	25
5.3.10 Material, configuration and cross-sectional area test for earth rods	26
5.4 Couplers for earth rods	26
5.4.1 General	26

5.4.2	Compression test by mechanical means	26
5.4.3	Environmental test.....	28
5.4.4	Lightning current test.....	28
5.4.5	Tensile strength test for couplers of earth rods	28
5.5	Marking test.....	29
5.5.1	General test conditions	29
5.5.2	Acceptance criteria	29
5.6	Documentation and installation instructions	29
5.6.1	General test conditions	29
5.6.2	Acceptance criteria	29
6	Electromagnetic compatibility (EMC)	29
7	Structure and content of the test report.....	29
7.1	General.....	29
7.2	Report identification	30
7.3	Specimen description.....	30
7.4	Conductor	30
7.5	Standards and references	30
7.6	Test procedure.....	30
7.7	Testing equipment description	30
7.8	Measuring instruments description	31
7.9	Results and parameters recorded	31
7.10	Statement of pass or fail	31
Annex A (normative)	Environmental test	32
A.1	General.....	32
A.2	Salt mist treatment.....	32
A.3	Humid sulphurous atmosphere treatment	32
A.4	Ammonia atmosphere treatment	32
Annex B (normative)	Lightning current test	33
B.1	General.....	33
B.2	Acceptance criteria	33
Annex C (normative)	Requirements and tests for air-termination conductors, air-termination rods, catenary wires and down conductors	34
Annex D (normative)	Requirements and tests for earth lead-in conductors, earth electrodes, equipotential earth grids and couplers for earth rods	35
Annex E (normative)	Sequence of tests for air-termination conductors, air-termination rods, catenary wires, earth lead-in conductors, down-conductors, earth conductors, earth plates and equipotential earth grids	36
Annex F (normative)	Sequence of tests for earth rods.....	38
Annex G (normative)	Sequence of tests of couplers for earth rods	39
Annex H (normative)	Material, configuration and cross-sectional area test.....	40
H.1	General.....	40
H.2	Acceptance criteria for air-termination conductors, air-termination rods, catenary wires and down conductors	40
H.3	Acceptance criteria for earth lead-in conductors, earth electrodes, equipotential earth grids	40
Annex I (normative)	Applicability of previous tests	41
Bibliography		42

Figure 1 – Coating measurements around the circumference of a round conductor	18
Figure 2 – Coating measurements of a plate conductor.....	18
Figure 3 – Typical test arrangement for adhesion test.....	23
Figure 4 – Definitions of upper yield strength R_{eH} and tensile strength R_m	25
Figure 5 – Typical test arrangement for the compression test by mechanical means	27
Figure E.1 – Flow chart of tests for air-termination conductors, air-termination rods, catenary wires, earth lead-in conductors, down-conductors, earth electrodes and equipotential earth grids	37
Figure F.1 – Flow chart of tests for earth rods.....	38
Figure G.1 – Flow chart of tests of couplers for earth rods	39
Table 1 – Material, configuration and cross-sectional area of air-termination conductors, air-termination rods, catenary wires and down-conductors	11
Table 2 – Material properties	12
Table 3 – Material, configuration and cross-sectional area of earth lead-in conductors, earth electrodes and equipotential earth grids.....	13
Table B.1 – Lightning impulse current (I_{imp}) parameters	33
Table C.1 – Summary of requirements and tests for various elements tested according to Table 1 and Table 2.....	34
Table D.1 – Summary of requirements and tests for various elements tested according to Table 2 and Table 3	35
Table I.1 – Differences in the requirements for conductors and earth electrodes complying with IEC 62561-2:2012 or IEC 62561-2:2018.....	41

get full document from standards.iteh.ai

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**Lightning protection system components (LPSC) -
Part 2: Requirements for conductors and earth electrodes**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 62561-2 has been prepared by IEC technical committee 81: Lightning protection. It is an International Standard.

This third edition cancels and replaces the second edition published in 2018. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) definitions of new conductor types mentioned in this document have been added;
- b) the document has been updated in line with IEC 60068-2-52:2017 on salt mist treatment;
- c) the document has been updated in line with ISO 22479:2019 on humid sulphurous atmosphere treatment;
- d) a new normative Annex H for material, configuration and cross-sectional area test has been introduced;

- e) a new normative Annex I for applicability of previous tests has been introduced.
- f) equipotential earth grid has been introduced.

The text of this International Standard is based on the following documents:

Draft	Report on voting
81/794/FDIS	81/800/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts in the IEC 62561 series, published under the general title *Lightning protection system components (LPSC)*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

INTRODUCTION

This part of IEC 62561 deals with the requirements and tests for lightning protection system components (LPSC), specifically conductors and earth electrodes, used for the installation of a lightning protection system (LPS) designed and implemented according to the IEC 62305 series.

Sample Document

get full document from standards.iteh.ai

1 Scope

This part of IEC 62561 specifies the requirements and tests for

- metallic conductors (other than "natural" conductors) that form part of the air-termination and down-conductor systems, and
- metallic earth electrodes that form part of the earth-termination system.

NOTE 1 Additional requirements can be necessary for conductors and earth electrodes intended for use in hazardous environments.

NOTE 2 In CENELEC member countries, testing requirements of components for explosive atmospheres are specified in CLC/TS 50703-2.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60068-2-52:2017, *Environmental testing – Part 2-52: Tests – Test Kb: Salt mist, cyclic (sodium, chloride solution)*

IEC 60228, *Conductors of insulated cables*

ISO 2178, *Non-magnetic coatings on magnetic substrates – Measurement of coating thickness – Magnetic method*

ISO 1460, *Metallic coatings – Hot dip galvanized coatings on ferrous materials – Gravimetric determination of the mass per unit area*

ISO 1461:2022, *Hot dip galvanized coatings on fabricated iron and steel articles – Specifications and test methods*

ISO 6892-1, *Metallic materials – Tensile testing – Part 1: Method of test at room temperature*

ISO 6957:1988, *Copper alloys – Ammonia test for stress corrosion resistance*

ISO 22479:2019, *Corrosion of metals and alloys – Sulphur dioxide test in a humid atmosphere (fixed gas method)*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- IEC Electropedia: available at <https://www.electropedia.org/>
- ISO Online browsing platform: available at <https://www.iso.org/obp>

3.1**air-termination system**

part of an external lightning protection system (LPS) intended to intercept lightning flashes

EXAMPLE Air-termination rods, air-termination conductors and catenary wires.

3.2**air-termination rod**

part of the air-termination system consisting of a metal rod for intercepting and conducting flashes to the down-conductor and earthing system of the lightning protection system (LPS)

3.3**air-termination conductor**

part of the air-termination system consisting of a conductor for intercepting and conducting flashes to the down-conductor and earthing system of the lightning protection system (LPS)

3.4**catenary wire**

part of the air-termination system consisting of an overhead wire for intercepting and conducting flashes to the down-conductor and earthing system of the lightning protection system (LPS)

3.5**copper coated steel**

steel that is manufactured through a continuous electro-plating process of copper over steel core, resulting in a permanent molecular bond between the two materials

3.6**down-conductor system**

part of an external LPS intended to conduct lightning current between the air-termination system and the earth-termination system

3.7**down-conductor**

part of the down-conductor system intended to conduct lightning current from the air-termination system to the earth-termination system of the LPS

3.8**earth lead-in conductor**

conductor installed between the down-conductor or test joint and the earth electrode intended to provide connection of the earth electrode with the test joint and can be partially buried in soil or partially embedded in concrete and partially placed in air

Note 1 to entry: An earth lead-in conductor can also provide mechanical protection against accidental stresses to the down conductor system.

3.9**earth-termination system**

part of an external lightning protection system, which is intended to conduct and disperse lightning current to the earth

3.10**earth electrode****ground electrode, USA**

part or group of parts of the earth-termination system which provides direct electrical contact with the earth and disperses lightning current into the earth

EXAMPLE Tape, wire, earth plate, lattice earth plate, meshed earth plate, solid earth rod, tubular earth rod.

3.11

earth conductor

ground conductor, USA

earth electrode consisting of a conductor buried in the ground

3.12

earth plate

metallic earth electrode consisting of a solid plate buried in the ground or a lattice plate buried in the ground

3.13

earth rod

earth electrode consisting of a solid or tubular metal rod driven into the ground

3.14

earth-rod-driving-head

tool used in those applications where it is necessary to drive the earth rod

3.15

couplers for earth rods

part of the earth-termination system that facilitates the coupling of one section of an earth rod to another for the purpose of deep driving

Note 1 to entry: Male and female or plug and socket connections of earth rods are also defined as couplers.

3.16

hot dipped galvanized steel

steel coated by a process which alloys with the surface of the base metal when immersing the metal in a bath of molten zinc at a temperature of around 450 °C (842 °F)

3.17

type test

test required to be made before supplying a type of material covered by IEC 62561-2 on a general commercial basis, in order to demonstrate satisfactory performance characteristics to meet the intended application

3.18

stranded conductor

conductor consisting of a number of individual wires or strands all or some of which generally have a helical form

Note 1 to entry: The cross-section of a stranded conductor can be circular or otherwise shaped.

Note 2 to entry: The term "strand" is also used to designate a single wire.

[SOURCE: IEC 60050-461:2008, 461-01-07]

3.19

rope lay conductor

conductor composed of a central core surrounded by one or more layers of helically laid groups of wires

3.20

smooth weave stranded conductor

conductor constructed of multi-strand soft drawn wire, interwoven in a basket weave configuration so as to avoid fraying in application

3.21

equipotential earth grid

mat consisting of an array of conductor intended for potential equalization

4 Requirements

4.1 General

Conductors and earth electrodes shall be designed in such a manner that, when they are installed in accordance with the manufacturer's instructions, their performance shall be reliable, stable and safe to persons and surrounding equipment.

The choice of a material depends on its ability to match the particular application requirements such as life cycle of the material, effects from galvanic corrosion and compatibility with other interconnected materials or services.

Summaries of the requirements for tests are given in Annex C and Annex D and the sequence of tests in Annex E, Annex F and Annex G.

4.2 Documentation and installation instructions

The manufacturer or supplier of the conductors and rods shall provide adequate information in their documentation or installation instructions, for example by drawings or photographs, to ensure that the installer of the conductors and rods can select and install the materials in accordance with IEC 62305-3 and IEC 62305-4.

To facilitate the installer, where it is necessary, the manufacturer or supplier may recommend the proper tools for their installation and instruments in order to perform specified measurements by IEC 62305 (all parts). In addition, where it is necessary to recommend a training for the safe selection and use of LPS components.

Documentation and installation instructions content shall not be in contradiction with the content of the relative testing report of each component.

Instructions are checked as per their completeness in accordance with 5.6.

4.3 Air-termination conductors, air-termination rods, catenary wires and down conductors

The material, configuration and cross-sectional area of the conductors and rods shall be in accordance with Table 1. Their mechanical and electrical characteristics shall be in accordance with Table 2.

Other materials may be used if they possess equivalent mechanical and electrical characteristics and corrosion resistance properties for the intended application.

Other configurations may be used if the relevant cross-sections are met.

If dimensions, materials or configurations other than those shown in Table 1 and Table 2 are applied, it is possible to use such after a successful electrical test with lightning current as per Table B.1, class H, as well as all the tests required by Clause 5.

Coated conductors and air-termination rods shall be corrosion-resistant and the coating shall exhibit good adherence to the base material.

Compliance is checked by inspection and by the tests as follows:

- a) for coated specimens, according to 5.2.2, 5.2.3, 5.2.4, 5.2.5, 5.2.6, 5.2.7, 5.2.8 and 5.5;
- b) for uncoated specimens, according to 5.2.6, 5.2.7, 5.2.8 and 5.5.