

TECHNICAL SPECIFICATION

SPECIFICATION TECHNIQUE

**High-voltage switchgear and controlgear –
Part 5: Common specifications for direct current switchgear and controlgear**

**Appareillage à haute tension –
Partie 5: Spécifications communes pour appareillage à courant continu**



THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2024 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Secretariat
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews, graphical symbols and the glossary. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 500 terminological entries in English and French, with equivalent terms in 25 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Recherche de publications IEC -

webstore.iec.ch/advsearchform

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études, ...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et une fois par mois par email.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Découvrez notre puissant moteur de recherche et consultez gratuitement tous les aperçus des publications, symboles graphiques et le glossaire. Avec un abonnement, vous aurez toujours accès à un contenu à jour adapté à vos besoins.

Electropedia - www.electropedia.org

Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 500 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 25 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

TECHNICAL SPECIFICATION

SPECIFICATION TECHNIQUE

**High-voltage switchgear and controlgear –
Part 5: Common specifications for direct current switchgear and controlgear**

**Appareillage à haute tension –
Partie 5: Spécifications communes pour appareillage à courant continu**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 29.130.10

ISBN 978-2-8327-0252-9

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	9
INTRODUCTION.....	11
1 Scope.....	12
2 Normative references.....	12
3 Terms and definitions	14
3.1 General terms and definitions	14
3.2 Assemblies of switchgear and controlgear	19
3.3 Parts of assemblies.....	19
3.4 Switching devices	19
3.5 Parts of switchgear and controlgear.....	21
3.6 Operational characteristics of switchgear and controlgear	25
3.6.5 Terms and definitions relative to pressure (or density)	26
3.6.6 Terms and definitions relating to gas and vacuum tightness	27
3.6.7 Terms and definitions relating to liquid tightness.....	29
3.7 Characteristic quantities	29
3.8 Index of definitions	30
4 Normal and special service conditions.....	33
4.1 Normal service conditions	33
4.1.1 General	33
4.1.2 Indoor switchgear and controlgear.....	33
4.1.3 Outdoor switchgear and controlgear	34
4.2 Special service conditions	34
4.2.1 General	34
4.2.2 Altitude	34
4.2.3 Exposure to pollution	35
4.2.4 Temperature and humidity.....	35
4.2.5 Exposure to abnormal vibrations, shock or tilting	35
4.2.6 Wind speed.....	35
4.2.7 Other parameters.....	35
5 Ratings.....	36
5.1 General.....	36
5.2 Rated direct voltage (U_{rd})	36
5.2.1 General	36
5.2.2 Rated voltages.....	37
5.3 Rated insulation level (U_{dd} , U_p , U_s)	37
5.4 Rated continuous current (I_{rd}).....	40
5.5 Rated values of short-time withstand current.....	40
5.5.1 Typical waveform of short-circuit current.....	40
5.5.2 Rated short-time withstand direct current (I_{kd}).....	43
5.5.3 Rated peak withstand current (I_{pd}).....	43
5.5.4 Rated duration of short-circuit (t_{kd})	43
5.6 Rated supply voltage of auxiliary and control circuits (U_a).....	43
5.6.1 General	43
5.6.2 Rated supply voltage (U_a).....	44
5.7 Rated supply frequency of auxiliary and control circuits.....	44

6	Design and construction	45
6.1	Requirements for liquids in switchgear and controlgear	45
6.2	Requirements for gases in switchgear and controlgear	45
6.3	Earthing of switchgear and controlgear	45
6.4	Auxiliary and control equipment and circuits	45
6.4.1	General	45
6.4.2	Protection against electric shock	46
6.4.3	Components installed in enclosures	47
6.5	Dependent power operation	50
6.6	Stored energy operation	50
6.6.1	General	50
6.6.2	Energy storage in gas receivers or hydraulic accumulators	50
6.6.3	Energy storage in springs (or weights)	50
6.6.4	Manual charging	50
6.6.5	Motor charging	51
6.6.6	Energy storage in capacitors	51
6.7	Independent unlatched operation (independent manual or power operation)	51
6.8	Manually operated actuators	51
6.9	Operation of releases	51
6.9.1	General	51
6.9.2	Shunt closing release	52
6.9.3	Shunt opening release	52
6.9.4	Capacitor operation of shunt releases	52
6.9.5	Under-voltage release	52
6.10	Pressure/level indication	52
6.10.1	Gas pressure	52
6.10.2	Liquid level	52
6.11	Nameplates	53
6.11.1	General	53
6.11.2	Application	53
6.12	Locking devices	54
6.13	Position indication	55
6.14	Degrees of protection provided by enclosures	55
6.14.1	General	55
6.14.2	Protection of persons against access to hazardous parts and protection of the equipment against ingress of solid foreign objects (IP coding)	55
6.14.3	Protection against ingress of water (IP coding)	55
6.14.4	Protection against mechanical impact under normal service conditions (IK coding)	55
6.15	Creepage distances for outdoor insulators	55
6.16	Gas and vacuum tightness	56
6.16.1	General	56
6.16.2	Controlled pressure systems for gas	56
6.16.3	Closed pressure systems for gas	56
6.16.4	Sealed pressure systems	56
6.17	Tightness for liquid systems	57
6.17.1	General	57
6.17.2	Leakage rates	57
6.18	Fire hazard (flammability)	57

6.19	Electromagnetic compatibility (EMC).....	57
6.20	X-ray emission	57
6.21	Corrosion	57
6.22	Filling levels for insulation, switching and/or operation	57
7	Type tests	58
7.1	General.....	58
7.1.1	Basics	58
7.1.2	Information for identification of test objects.....	58
7.1.3	Information to be included in type-test reports	58
7.2	Dielectric tests	59
7.2.1	General	59
7.2.2	Ambient air conditions during tests	59
7.2.3	Wet test procedure.....	60
7.2.4	Arrangement of the equipment	60
7.2.5	Criteria to pass the test.....	60
7.2.6	Application of the test voltage and test conditions.....	61
7.2.7	Tests of switchgear and controlgear	63
7.2.8	Artificial pollution tests for outdoor insulators.....	65
7.2.9	Partial discharge tests.....	65
7.2.10	Dielectric tests on auxiliary and control circuits.....	65
7.2.11	Voltage test as condition check	65
7.3	Resistance measurement	66
7.3.1	Measurement of the resistance of auxiliary contacts class 1 and class 2	66
7.3.2	Measurement of the resistance of auxiliary contacts class 3.....	66
7.3.3	Electrical continuity of earthed metallic parts test.....	66
7.3.4	Resistance measurement of contacts and connections in the main circuit as a condition check	66
7.4	Continuous current tests.....	67
7.4.1	Condition of the test object.....	67
7.4.2	Arrangement of the equipment	67
7.4.3	Test current and duration	68
7.4.4	Temperature measurement during test	69
7.4.5	Resistance of the main circuit.....	70
7.4.6	Criteria to pass test.....	70
7.5	Short-time withstand current and peak withstand current tests	74
7.5.1	General	74
7.5.2	Arrangement of the equipment and of the test circuit.....	74
7.5.3	Test current and duration	75
7.5.4	Conditions of the test object after test.....	76
7.6	Verification of the protection.....	76
7.6.1	Verification of the IP coding.....	76
7.6.2	Verification of the IK coding.....	76
7.7	Tightness tests.....	77
7.7.1	General	77
7.7.2	Controlled pressure systems for gas.....	78
7.7.3	Closed pressure systems for gas.....	78
7.7.4	Sealed pressure systems	79
7.7.5	Liquid tightness tests	79
7.8	Electromagnetic compatibility tests (EMC)	79

7.8.1	Emission tests	79
7.8.2	Immunity tests on auxiliary and control circuits	82
7.8.3	Additional EMC tests on auxiliary and control circuits	85
7.9	Additional tests on auxiliary and control circuits	86
7.9.1	General	86
7.9.2	Functional tests	86
7.9.3	Verification of the operational characteristics of auxiliary contacts	86
7.9.4	Environmental tests	87
7.9.5	Dielectric test	88
7.10	X-radiation test for vacuum interrupters	88
7.10.1	General requirements	88
7.10.2	Test voltage and measurement procedure	90
7.10.3	Acceptance criteria	90
8	Routine tests	91
8.1	General	91
8.2	Dielectric test on the main circuit	91
8.3	Tests on auxiliary and control circuits	91
8.3.1	Inspection of auxiliary and control circuits, and verification of conformity to the circuit diagrams and wiring diagrams	91
8.3.2	Functional tests	92
8.3.3	Verification of protection against electrical shock	92
8.3.4	Dielectric tests	92
8.4	Measurement of the resistance of the main circuit	92
8.5	Tightness test	93
8.5.1	General	93
8.5.2	Controlled pressure systems for gas	93
8.5.3	Closed pressure systems for gas	93
8.5.4	Sealed pressure systems	93
8.5.5	Liquid tightness tests	93
8.6	Design and visual checks	93
9	Guide to the selection of switchgear and controlgear (informative)	94
9.1	General	94
9.2	Selection of rated values	94
9.3	Cable-interface considerations	94
9.4	Continuous or temporary overload due to changed service conditions	94
9.5	Environmental aspects	94
9.5.1	Service conditions	94
9.5.2	Clearances affected by service conditions	94
9.5.3	High humidity	94
9.5.4	Solar radiation	95
10	Information to be given with enquiries, tenders and orders (informative)	95
10.1	General	95
10.2	Information with enquiries and orders	95
10.3	Information with tenders	96
11	Transport, storage, installation, operating instructions and maintenance	97
11.1	General	97
11.2	Conditions during transport, storage and installation	97
11.3	Installation	97
11.3.1	General	97

11.3.2	Unpacking and lifting.....	97
11.3.3	Assembly.....	98
11.3.4	Mounting.....	98
11.3.5	Connections.....	98
11.3.6	Information about gas and gas mixtures for controlled and closed pressure systems.....	98
11.3.7	Final installation inspection.....	99
11.3.8	Basic input data by the user.....	99
11.3.9	Basic input data by the manufacturer.....	99
11.4	Operating instructions.....	100
11.5	Maintenance.....	100
11.5.1	General.....	100
11.5.2	Information about fluids and gas to be included in maintenance manual.....	100
11.5.3	Recommendations for the manufacturer.....	100
11.5.4	Recommendations for the user.....	101
11.5.5	Failure report.....	102
12	Safety.....	103
12.1	General.....	103
12.2	Precautions by manufacturers.....	104
12.3	Precautions by users.....	104
13	Influence of the product on the environment.....	105
Annex A (informative)	Examples of HVDC side switchgear arrangement for one pole in an HVDC substation.....	106
Annex B (informative)	Exposure to pollution.....	108
B.1	General.....	108
B.2	Minimum requirements for switchgear in normal service condition.....	108
B.3	Minimum requirements for switchgear in special service condition.....	108
Annex C (informative)	Preferred insulation levels for rated voltages lower than 105 kV.....	109
Annex D (informative)	Short-circuit current in HVDC systems.....	110
D.1	VSC HVDC.....	110
D.2	LCC HVDC.....	111
D.3	Special case of LCC HVDC DC faults – LCC as diode bridge.....	111
D.4	HVDC systems with DC circuit-breakers.....	113
D.5	Calculation of the rated short-time withstand direct current.....	114
D.6	Calculation of Joule integral value (E_j).....	115
Annex E (informative)	References for auxiliary and control circuit components.....	116
Annex F (informative)	List of symbols.....	118
Annex G (normative)	Method for the weatherproofing test for outdoor switchgear and controlgear.....	120
Annex H (normative)	Tolerances on test quantities during tests.....	123
Annex I (informative)	Extension of validity of type tests.....	126
I.1	General.....	126
I.2	Dielectric tests.....	126
I.3	Short-time withstand current and peak withstand current tests.....	126
I.4	Electromagnetic immunity test on auxiliary and control circuits.....	126
I.5	Environmental tests on auxiliary and control circuits.....	126
Annex J (normative)	Identification of test objects.....	128
J.1	General.....	128

J.2	Data	128
J.3	Drawings.....	128
Annex K (informative)	Test circuit for superimposed impulse voltage tests	130
K.1	General.....	130
K.2	Test circuit using blocking capacitor	130
K.3	Test circuit using sphere gap.....	130
Annex L (informative)	Information and technical requirements to be given with enquiries, tenders and orders.....	132
L.1	General.....	132
L.2	Normal and special service conditions (refer to Clause 4)	132
L.3	Ratings (refer to Clause 5)	133
L.4	Design and construction (refer to Clause 6)	133
L.5	System information	134
L.6	Documentation for enquiries and tenders	134
Annex M (informative)	Electromagnetic compatibility on site	135
Annex N (informative)	Standardization activities of HVDC	136
Bibliography	137
Figure 1	– Schematic representation of superimposed impulse voltage tests	40
Figure 2	– Typical waveform of a short-circuit current in an HVDC system	42
Figure 3	– Examples of classes of contacts	49
Figure 4	– Diagram of connections of a switching device	62
Figure 5	– Test sequence for polarity reversal tests	65
Figure 6	– Diagram of a test circuit for the radio interference voltage test.....	81
Figure 7	– Test location of radiation survey instrument	90
Figure A.1	– Example of HVDC side switchgear arrangement for one pole in an HVDC substation.....	107
Figure D.1	– VSC HVDC under worst-case, pole-pole DC fault.....	110
Figure D.2	– LCC HVDC under worst-case, pole-pole DC fault.....	111
Figure D.3	– Special case LCC HVDC under worst-case, pole-pole DC fault	112
Figure D.4	– HVDC system with DC circuit-breaker under worst-case, pole-pole DC fault.....	113
Figure D.5	– DC circuit-breaker simple model.....	113
Figure D.6	– Equivalent fault current for calculation of rated short time withstand direct current.....	115
Figure G.1	– Arrangement for weatherproofing test.....	121
Figure G.2	– Nozzle for weatherproofing test.....	122
Figure K.1	– Test circuit for superimposed impulse tests using blocking capacitor	130
Figure K.2	– Test circuit for superimposed impulse tests using sphere gap	131
Table 1	– Preferred rated insulation levels.....	38
Table 2	– Direct voltage of auxiliary and control circuits.....	44
Table 3	– Alternating voltage of auxiliary and control circuits	44
Table 4	– Auxiliary contact classes.....	49
Table 5	– Nameplate information.....	54
Table 6	– Test conditions in general case.....	62

Table 7 – Test conditions in case of impulse voltage tests across the isolating distance (or open switching device)	62
Table 8 – Test conditions in case of superimposed impulse voltage tests	63
Table 9 – Test conditions for polarity reversal tests	65
Table 10 – Limits of temperature and temperature rise for various parts, materials and dielectrics of high-voltage switchgear and controlgear	71
Table 11 – Permissible leakage rates for gas systems	78
Table 12 – Application of voltages at the fast transient/burst test	83
Table 13 – Application of voltage at the damped oscillatory wave test	84
Table 14 – Assessment criteria for transient disturbance immunity	85
Table C.1 – Preferred insulation levels for rated voltages lower than 105 kV	109
Table E.1 – List of reference documents for auxiliary and control circuit components	116
Table H.1 – Tolerances on test quantities for type test	123
Table J.1 Drawing list and contents	128

Sample Document

get full document from standards.iteh.ai

INTERNATIONAL ELECTROTECHNICAL COMMISSION

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –**Part 5: Common specifications for direct current
switchgear and controlgear**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC TS 62271-5 has been prepared by IEC technical committee 17: High-voltage switchgear and controlgear. It is a Technical Specification.

The text of this document is based on the following documents:

Draft	Report on voting
17/1136/DTS	17/1143B/RVDTS

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this document is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/standardsdev/publications.

The list of all parts of the IEC 62271 series under the general title, *High-voltage switchgear and controlgear*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "http://webstore.iec.ch" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

Sample Document

get full document from standards.iteh.ai

INTRODUCTION

This Technical Specification has been prepared by TC 17 and it defines common specifications for high-voltage direct current (HVDC) switchgear and controlgear covering both types of air insulated (AIS) and gas insulated (GIS) equipment of HVDC substations. This document includes rules for service conditions, ratings, design and construction requirements. Test requirements and criteria to proof for passing type and routine tests are defined in this document for development and manufacturing of HVDC switchgear.

This specification is applicable for both LCC and VSC HVDC technology.

SC 17A is in the process of preparing documents for the following HVDC switching devices:

- circuit-breakers (IEC TS 62271-313 [1])¹;
- disconnectors and earthing switches (IEC TS 62271-314 [2]);
- transfer switches (IEC TS 62271-315 [3]);
- by-pass switches and paralleling switches (IEC TS 62271-316 [4]).

SC 17C is in the process of preparing a document for DC gas insulated switchgears (IEC TS 62271-318 [5]).

Standardization of direct voltages is the responsibility of TC 8 (System aspects of electrical energy supply).

TC 99 (Insulation co-ordination and system engineering of high voltage electrical power installations above 1,0 kV AC and 1,5 kV DC) defines requirements of DC substations for safety of insulation, equipment, installation and earthing (IEC 61936-2).

TC 115 (High Voltage Direct Current (HVDC) transmission for DC voltages above 100 kV) is responsible for DC transmission system aspects. It is the responsibility of TC 115 to define requirements for different equipment (e. g. switching devices) from system point of view. These definitions are implemented in documents from other TCs. Several Working Groups and Maintenance Teams are preparing documents on reliability, EMC, asset management, system design, DC harmonics, testing, HVDC grids, VSC and LCC converter and insulation coordination for HVDC systems.

¹ Numbers in square brackets refer to the Bibliography.

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 5: Common specifications for direct current switchgear and controlgear

1 Scope

This part of IEC 62271, which is a Technical Specification, applies to DC switchgear and controlgear designed for operation on HVDC transmission systems having direct voltages of 100 kV and above.

This document applies to all high-voltage switchgear and controlgear for indoor and/or outdoor installation except as otherwise specified in the relevant IEC documents for the particular type of switchgear and controlgear.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60038:2009, *IEC standard voltages*

IEC 60050-614:2016, *International Electrotechnical Vocabulary (IEV) – Part 614: Generation, transmission and distribution of electricity – Operation*

IEC 60050-811, *International Electrotechnical Vocabulary (IEV) – Part 811: Electric traction*

IEC 60050-826:2022, *International Electrotechnical Vocabulary (IEV) – Part 826: Electrical installations*

IEC 60060-1, *High-voltage test techniques – Part 1: General definitions and test requirements*

IEC 60068-2-1:2007, *Environmental testing – Part 2-1: Tests – Test A: Cold*

IEC 60068-2-2:2007, *Environmental testing – Part 2-2: Tests – Test B: Dry heat*

IEC 60068-2-17:1994, *Basic environmental testing procedures – Part 2-17: Tests – Test Q: Sealing*

IEC 60068-2-30:2005, *Environmental testing – Part 2-30: Tests – Test Db: Damp heat, cyclic (12 h + 12 h cycle)*

IEC 60071-1:2019, *Insulation co-ordination – Part 1: Definitions, principles and rules*

IEC 60071-2:2018, *Insulation co-ordination – Part 2: Application guidelines*

IEC 60071-11:2022, *Insulation co-ordination – Part 11: Definitions, principles and rules for HVDC system*

IEC 60085:2007, *Electrical insulation – Thermal evaluation and designation*

IEC 60255-21-1:1988, *Electrical relays – Part 21: Vibration, shock, bump and seismic tests on measuring relays and protection equipment – Section One: Vibration tests (sinusoidal)*

IEC 60270, *High-voltage test techniques – Partial discharge measurements*

IEC 60296, *Fluids for electrotechnical applications – Mineral insulating oils for electrical equipment*

IEC 60376, *Specification of technical grade sulphur hexafluoride (SF₆) and complementary gases to be used in its mixtures for use in electrical equipment*

IEC 60417:2006, *Graphical symbols for use on equipment (available at <http://www.graphical-symbols.info/equipment>)*

IEC 60437, *Radio interference test on high-voltage insulators*

IEC 60480, *Specifications for the re-use of sulphur hexafluoride (SF₆) and its mixtures in electrical equipment*

IEC 60512-2-2, *Connectors for electronic equipment – Tests and measurements – Part 2-2: Electrical continuity and contact resistance tests – Test 2b: Contact resistance – Specified test current method*

IEC 60529:1989, *Degrees of protection provided by enclosures (IP Code)*

IEC 60529:1989/AMD1:1999

IEC 60529:1989/AMD2:2013

IEC 60633:2019, *High-voltage direct current (HVDC) transmission – Vocabulary*

IEC TS 60815-4:2016, *Selection and dimensioning of high-voltage insulators intended for use in polluted conditions – Part 4: Insulators for DC systems*

IEC 61000-4-4, *Electromagnetic compatibility (EMC) – Part 4-4: Testing and measurement techniques – Electrical fast transient/burst immunity test*

IEC 61000-4-11, *Electromagnetic compatibility (EMC) – Part 4-11: Testing and measurement techniques – Voltage dips, short interruptions and voltage variations immunity tests for equipment with input current up to 16 A per phase*

IEC 61000-4-17:1999, *Electromagnetic compatibility (EMC) – Part 4-17: Testing and measurement techniques – Ripple on d.c. input power port immunity test*

IEC 61000-4-18, *Electromagnetic compatibility (EMC) – Part 4-18: Testing and measurement techniques – Damped oscillatory wave immunity test*

IEC 61000-4-29, *Electromagnetic compatibility (EMC) – Part 4-29: Testing and measurement techniques – Voltage dips, short interruptions and voltage variations on DC input power port immunity tests*

IEC 61000-6-2, *Electromagnetic compatibility (EMC) – Part 6-2: Generic standards – Immunity standard for industrial environments*

IEC 61000-6-5, *Electromagnetic compatibility (EMC) – Part 6-5: Generic standards – Immunity for equipment used in power station and substation environment*