



IEC TS 62749

Edition 3.0 2026-03

INTERNATIONAL STANDARD

REDLINE VERSION

Assessment of power quality - Characteristics of electricity supplied by public networks

Sample Document

get full document from standards.iteh.ai



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2026 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Secretariat
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search -

webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews, graphical symbols and the glossary. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 500 terminological entries in English and French, with equivalent terms in 25 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	7
2 Normative references	7
3 Terms and definitions	8
4 Recommended values for power quality indices.....	17
4.1 General.....	17
4.2 Frequency deviation.....	19
4.3 Supply voltage deviation	19
4.3.1 General	19
4.3.2 Low voltage systems	19
4.3.3 Medium voltage systems.....	19
4.3.4 High voltage systems.....	20
4.4 Voltage unbalance	20
4.5 Flicker.....	21
4.6 Harmonic and interharmonic voltage	21
4.6.1 General	21
4.6.2 Low voltage systems	21
4.6.3 Medium voltage systems.....	22
4.6.4 High voltage systems.....	24
4.7 Voltage dip	25
4.8 Voltage swell	25
4.9 Voltage interruption.....	25
4.10 Mains communicating voltage	26
4.11 Rapid voltage change	27
4.12 Transient overvoltage	27
4.12.1 Low voltage systems	27
4.12.2 Medium and high voltage systems	28
5 Objectives and methods for power quality assessment	28
5.1 General.....	28
5.2 Site power quality assessment.....	29
5.2.1 General	29
5.2.2 Continuous phenomena	29
5.2.3 For discontinuous phenomena (single event)	31
5.3 System aspect power quality assessment	32
5.3.1 General	32
5.3.2 For continuous phenomena.....	32
5.3.3 For discontinuous phenomena (events)	32
Annex A (informative) Examples of profiles for power quality specification.....	35
A.1 General.....	35
A.2 LV and MV public distribution electricity networks in European countries	35
A.3 LV, MV and HV power supply system in China	37
A.4 Example of a transmission system in Canada	38
A.5 Examples of profiles in Australia	39
A.6 LV, MV and HV power supply system in Russia	40
Annex B (informative) Additional information on power quality assessments	42

B.1	Weekly percentile values assessed on a daily sliding basis.....	42
B.2	Example on system aspect continuous disturbance evaluation.....	43
B.3	Aggregation method used for events.....	43
B.3.1	General.....	43
B.3.2	Time aggregation.....	44
Annex C (informative) Main impact of poor power quality.....		
Annex C (informative)	Power quality issues related to distributed generation and micro-grids.....	49
C.1	General.....	49
C.2	Voltage deviation.....	49
C.3	Harmonics.....	49
C.4	DG magnetic bias (DC current injection).....	49
C.5	Voltage fluctuation and flicker.....	50
C.6	High frequency conducted disturbances.....	50
Annex D (informative)	Methods to maintain and improve power quality.....	51
D.1	General.....	51
D.2	Voltage deviation.....	51
D.3	Harmonics.....	52
D.4	Flicker.....	52
D.5	Voltage unbalance.....	52
D.6	Voltage dip, swell and short time interruption.....	53
Annex E (informative)	Relation between power quality and EMC.....	54
E.1	General.....	54
E.2	Differences between power quality and compatibility levels.....	54
E.3	Example of power quality level versus compatibility level.....	55
Annex F (informative)	Other phenomena.....	58
F.1	General.....	58
F.2	Level behaviour over time.....	58
F.3	Duration.....	58
F.4	Periodicity.....	58
F.5	Bandwidth.....	59
Annex G (informative)	Role of stakeholders for power quality management – Coordination of the parties involved.....	60
G.1	General.....	60
G.2	Network operator – Network user.....	60
G.3	Network user – Equipment supplier.....	60
G.4	Network operator – Equipment supplier.....	61
Bibliography	62
Figure 1	– Mains communicating voltages recommended values in percent of U_N used in public LV networks (or U_C in public MV networks).....	27
Figure 2	– Example for illustrating voltage <i>THD</i> assessment result trends.....	31
Figure 3	– Example showing information of single event assessment.....	32
Figure B.1	– Comparison of two methods of assessing weekly 95 th percentile values.....	42
Figure B.2	– Example for illustrating the differences resulted by time aggregation method.....	44

Figure B.3 – Example of time sequence of voltage dips that can be aggregated in two different ways	45
Figure E.1 – Application points in a LV system (example)	54
Figure E.2 – Relation between disturbance levels (schematic significance only)	55
Figure E.3 – Cumulative distribution of all <i>THD</i> values recorded at 30 points of supply of the LV system, during one week	56
Figure E.4 – Weekly 95 th percentile <i>THD</i> values evaluated at each monitored LV point of supply	57
Table 1 – Classification of electromagnetic phenomena addressed by power quality indices	7
Table 2 – Flicker severity P_{ft} recommended values	21
Table 3 – Recommended values of individual harmonic voltages at the low voltage points of supply for orders up to 50 40 given in percent of the fundamental voltage U_1	22
Table 4 – Recommended values of individual harmonic voltages at the medium voltage points of supply for orders up to 50 40 given in percent of the fundamental voltage U_1	23
Table 5 – Indicative values of individual harmonic voltages at the high voltage points of supply given in percent of the fundamental voltage U_1	24
Table 6 – Site power quality assessment methods	30
Table 7 – Example of single event assessment	31
Table 8 – List of individual events measured at a single monitoring site	33
Table 9 – SARFI-X indices coming out of Table 8	33
Table 10 – Magnitude-duration table format	34
Table A.1 – Examples of profiles in most European countries	35
Table A.2 – Examples of profiles in Spain	36
Table A.3 – Examples of profiles in China	37
Table A.4 – Examples of profiles in Canada	38
Table A.5 – Examples of profiles in Australia	39
Table A.6 – Examples of profiles in Russia	40
Table B.1 – Listing of system power quality evaluation	43

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**Assessment of power quality -
Characteristics of electricity supplied by public networks**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with can participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

This redline version of the official IEC Standard allows the user to identify the changes made to the previous edition IEC TS 62749:2020. A vertical bar appears in the margin wherever a change has been made. Additions are in green text, deletions are in strikethrough red text.

IEC TS 62749 has been prepared by IEC technical committee 8: System aspects of electrical energy supply. It is a Technical Specification.

This third edition cancels and replaces the second edition published in 2020. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) clarification that harmonic orders recommended in this document are up to 40th; 4.6 is modified accordingly;
- b) iteration that this document does not apply for systems operated above 230 kV;
- c) deletion of Annex C;
- d) improvement of 4.10;
- e) update of profiles and addition of new profiles;
- f) modifications to align with EN 50160:2022 and EN 50160:2022/AMD1:2025.

The text of this Technical Specification is based on the following documents:

Draft	Report on voting
8/1779/DTS	8/1800/RVDTS

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this Technical Specification is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

INTRODUCTION

The description of electricity is of fundamental importance within electricity supply systems. In the past, its characteristics depended less on its generation than on the way in which it was transported by networks and being used by the equipment of the multiple users. Faults or other events such as short-circuit and lightning strikes occurring within users' installations or public networks also disturb or degrade it.

Nowadays, smart grid construction and massive deployment of renewable energy sources increase the complexity of power quality management. For more information about power quality issues related to distributed generation and micro-grids, refer to Annex C.

NOTE For more information about role of stakeholders for power quality management, see Annex G.

There is a need for a common set of power quality (PQ) indices and measurement methods in order to allow different system operators to measure and report power quality in a consistent manner.

Regarding the limits or levels of power quality, the situation differs. Historically, the electrical systems in different countries/ or regions have been designed in different ways to cater for national/ or regional variations like different geographic, climatic or commercial conditions, etc. It is thus essential that any set of internationally agreed power quality limits or levels also recognize these differences, which depends namely on the system configuration, the transfer characteristics between the different voltage levels (attenuation or amplification), the actual disturbance levels on the system, etc.

Also, the quality of power is not absolute. Optimizing power quality should be carried out in a cost-effective manner to balance network user power quality requirements and willingness to pay for it with power quality supply costs.

Therefore, some of the objectives recommended hereafter allow for a range of values, or options, while still ensuring the coordination of disturbance levels between different parts of the system or voltage levels.

Then, the requirements to be applied can be expressed by the association of the IEC power quality framework from the normative part of this document and profiles. Examples of profiles are given in Annex A.

1 Scope

This document, which is a Technical Specification, specifies the expected characteristics of electricity at the point of supply of public low, medium and high voltage, 50 Hz or 60 Hz, networks, as well as power quality assessment methods.

This document does not apply for systems operated above 230 kV.

~~NOTE 1~~—The boundaries between the various voltage levels can be different for different countries/ or regions. In the context of this document, the following terms for system voltage are used:

- low voltage (LV) refers to $U_N \leq 1$ kV;
- medium voltage (MV) refers to $1 \text{ kV} < U_N \leq 35$ kV;
- high voltage (HV) refers to $35 \text{ kV} < U_N \leq 230$ kV.

~~NOTE 2~~—Because of existing network structures, in some countries/ or regions, the boundary between medium and high voltage can be different. This document applies to the phenomena listed in Table 1.

Table 1 – Classification of electromagnetic phenomena addressed by power quality indices

Continuous phenomena	Discontinuous phenomena – Events	Other phenomena
Frequency deviation	Supply interruption	Mains communicating voltages
Supply voltage deviation	Voltage dip	
Voltage unbalance	Voltage swell	
Harmonic voltage	Transient overvoltage	
Interharmonic voltage	Rapid voltage change	
Flicker (voltage fluctuation)		

NOTE 1 Specification of related measurement methods can be found in IEC 61000-4-30.

NOTE 2 Specification of the performance of related measuring instruments can be found in the IEC 62586 series.

NOTE 3 For information on power quality phenomena at low voltage direct current (LVDC) network, refer to IEC TR 63282.

While power quality is related to EMC in a number of ways, especially because compliance with power quality requirements depends on the control of cumulative effect of electromagnetic emission from all/ or multiple equipment and/or installations, this document is not an EMC publication (see also Annex E).

2 Normative references

~~The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.~~

~~IEC 60038, IEC standard voltages~~

~~IEC 60364-4-44, Low-voltage electrical installations — Part 4-44: Protection for safety — Protection against voltage disturbances and electromagnetic disturbances~~

~~IEC 60364-5-53, Low-voltage electrical installations — Part 5-53: Selection and erection of electrical equipment — Devices for protection for safety, isolation, switching, control and monitoring~~

~~IEC 61000-2-2:2002, Electromagnetic compatibility (EMC) — Part 2-2: Environment — Compatibility levels for low-frequency conducted disturbances and signalling in public low-voltage power supply systems~~

~~IEC 61000-2-2:2002/AMD1:2017~~

~~IEC 61000-2-2:2002/AMD2:2018~~

~~IEC 61000-2-12, Electromagnetic compatibility (EMC) — Part 2-12: Environment — Compatibility levels for low-frequency conducted disturbances and signalling in public medium-voltage power supply systems~~

~~IEC TR 61000-2-14, Electromagnetic compatibility (EMC) — Part 2-14: Environment — Overvoltages on public electricity distribution networks~~

~~IEC 61000-4-30:2015, Electromagnetic compatibility (EMC) — Part 4-30: Testing and measurement techniques — Power quality measurement methods~~

There are no normative references in this document.

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- IEC Electropedia: available at <https://www.electropedia.org/>
- ISO Online browsing platform: available at <https://www.iso.org/obp>

NOTE Terms are listed in alphabetical order.

3.1 code

collection of rules concerning rights and duties of the parties involved in a certain part of the electric power system

EXAMPLE Grid code, distribution code, code in electric power system.

[SOURCE: IEC 60050-617:2009, 617-03-03, modified – The domain has been removed, the note has been converted to an example, and the words "code in electric power system" has been added to the example.]

3.2 connection agreement

agreement entered between the system operator and a system user which governs the procedure and conditions for connection

[SOURCE: IEC 60050-617:2009, 617-04-03]

3.3 declared supply voltage

U_c

supply voltage agreed by the network operator and the network user

Note 1 to entry: Generally declared supply voltage U_c is the nominal voltage U_N but it may be different according to the agreement between the network operator and the network user.

3.4 electricity

set of the phenomena associated with electric charges and electric currents

Note 1 to entry: In the context of electric power systems, electricity is often described as a product with particular characteristics.

[SOURCE: IEC 60050-121:1998, 121-11-76, modified – The note to entry has been added.]

3.5 electromagnetic environment

totality of electromagnetic phenomena existing at a given location

Note 1 to entry: In general, the electromagnetic environment is time-dependent and its description can need a statistical approach.

[SOURCE: IEC 60050-161:2018, 161-01-01]

3.6 electromagnetic disturbance

electromagnetic phenomenon that can degrade the performance of a device, equipment or system, or adversely affect living or inert matter

Note 1 to entry: An electromagnetic disturbance can be an electromagnetic noise, an unwanted signal or a change in the propagation medium itself.

Note 2 to entry: Electromagnetic disturbance in this document refers to low frequency conducted phenomena.

[SOURCE: IEC 60050-161:2018, 161-01-05, modified – Note 2 to entry has been replaced and Note 3 to entry has been deleted.]

3.7 electromagnetic compatibility

ability of equipment or a system to function satisfactorily in its electromagnetic environment without introducing intolerable electromagnetic disturbances to anything in that environment

[SOURCE: IEC 60050-161:2018, 161-01-07]

3.8 electromagnetic compatibility level compatibility level

specified electromagnetic disturbance level used as a reference level for co-ordination in the setting of emission and immunity limits

Note 1 to entry: By convention, the compatibility level is chosen so that there is only a small probability that it will be exceeded by the actual disturbance level.

[SOURCE: IEC 60050-161:1990, 161-03-10, modified – Note 1 has been shortened and Note 2 has been deleted]

3.9**flagged data**

data that has been marked to indicate that its measurement or its aggregation ~~may~~ can have been affected by interruptions, dips, or swells

[SOURCE: IEC 61000-4-30:2015, 3.5, modified – ~~modified~~ The definition has been reformulated to better understand the term.]

3.10**flicker**

impression of unsteadiness of visual sensation induced by a light stimulus whose luminance or spectral distribution fluctuates with time

Note 1 to entry: Voltage fluctuation cause changes of the luminance of lamps which can create the visual phenomenon called flicker. Above a certain threshold, flicker becomes annoying. The annoyance grows very rapidly with the amplitude of the fluctuation. At certain repetition rates, even very small amplitudes can be annoying.

Note 2 to entry: For the time being, flicker is qualified based on incandescent lamp's behaviour.

[SOURCE: IEC 60050-161:1990, 161-08-13, modified – Notes to entry have been added.]

3.11**flicker severity**

intensity of flicker annoyance evaluated by the following quantities:

- short-term severity (P_{st}) measured over a period of ten minutes;
- long-term severity (P_{lt}) calculated from a sequence of 12 P_{st} -values over a two-hours interval, according to the following expression:

$$P_{lt} = \sqrt[3]{\sum_{i=1}^{12} \frac{P_{sti}^3}{12}}$$

Note 1 to entry: For details of P_{st} and P_{lt} , see IEC 61000-4-15.

3.12**frequency deviation**

difference between power supply frequency ($f_{H,1}$) and nominal frequency (f_N)

[SOURCE: IEC 60050-614:2016, 614-01-10, modified – The words "system frequency at a given instant and its nominal value" has been changed to "power supply frequency ($f_{H,1}$) and nominal frequency (f_N)".]

3.13**group total harmonic distortion****THDG**

$THDG_Y$

ratio of the RMS value of the harmonic groups ($Y_{g,h}$) to the RMS value of the group associated with the fundamental ($Y_{g,1}$):

$$THDG_Y = \sqrt{\sum_{h=2}^{h_{\max}} \left(\frac{Y_{g,h}}{Y_{g,1}} \right)^2}$$

Note 1 to entry: The symbol Y is replaced, as required, by the symbol I for currents or by the symbol U for voltages.

[SOURCE: IEC 61000-4-7:2002 and IEC 61000-4-7:2002/AMD1:2008, 3.3.2, modified – Note 2 has been removed.]

3.14
harmonic frequency

$f_{H,h}$

frequency which is an integer multiple of the power supply (fundamental) frequency

[SOURCE: IEC 61000-4-7: 2002 and IEC 61000-4-7:2002/AMD1:2008, 3.2.1, modified – "fundamental frequency of the power system" has been changed to "power supply (fundamental) frequency", and the formula and note have been removed.]

3.15
harmonic order

h

(integer) ratio of a harmonic frequency ($f_{H,h}$) to the power supply frequency ($f_{H,1}$)

[SOURCE: IEC 60050-161:1990, 161-02-19, modified – "the integral number given by the ratio of the frequency of a harmonic to the fundamental frequency" has been changed to "(integer) ratio of a harmonic frequency ($f_{H,h}$) to the power supply frequency ($f_{H,1}$)".]

3.16
harmonic ratio
HR

ratio of individual harmonic order component (U_h or I_h) to the fundamental component (U_1 or I_1)

3.17
mains communicating system
MCS

system using mains power lines to transmit information signals, either on the public electricity distribution network or within installations of network users

[SOURCE: IEC 61000-2-2:2002 and IEC 61000-2-2:2002/AMD1:2017, 3.1.8, modified – The adjective "electrical" has been deleted in the definition.]

3.18
mains communicating voltage

signal superimposed on the supply voltage for the purpose of transmission of information in the public supply network and to network users' premises

Note 1 to entry: Three types of signals in the public supply network can be classified:

- ripple control signals: superimposed sinusoidal voltage signals in the frequency range 110 Hz to 3 000 Hz;
- power-line-carrier signals: superimposed sinusoidal voltage signals in the frequency range 3 kHz to 148,5 kHz;
- mains marking signals: superimposed short time alterations (transients) at selected points of the voltage waveform.

3.19
system operator
network operator

party responsible for safe and reliable operation of a part of the electric power system in a certain area and for connection to other parts of the electric power system

[SOURCE: IEC 60050-617:2009, 617-02-09]

3.20 nominal frequency

 f_N

value of frequency used to designate or identify a system

3.21 nominal voltage

 U_N

value of voltage used to designate or identify a system

EXAMPLE: Nominal voltage of a system.

[SOURCE: IEC 60050-601:1985, 601-01-21, modified – The symbol has been added and the words "suitable approximate" have been removed from the definition.]

3.22 normal operating conditions

operating conditions of a public electricity supply system typically including all generation variations, load variations and reactive compensation or filter states (e.g. shunt capacitor states), planned outages and planned arrangements during maintenance and construction work, non-ideal operating conditions and normal contingencies under which the considered system has been designed to operate

EXAMPLE Nominal operating conditions of a public electricity supply system

Note 1 to entry: Normal system operating conditions typically exclude exceptional situations such as: conditions arising as a result of a fault or a combination of faults beyond that planned for under the system security standard, unavoidable circumstances (for example: force majeure, exceptional weather conditions and other natural disasters, acts by public authorities, industrial actions), cases where network users significantly exceed their emission limits or do not comply with the connection requirements, and temporary generation or supply arrangements adopted to maintain supply to network users during maintenance or construction work, where otherwise supply would be interrupted.

[SOURCE: IEC TR 61000-3-6:2008, 3.15, modified – The words "of the system or of the disturbing installation" have been replaced by "of a public electricity supply system", "planned" have been added to "arrangements", and "or the disturbing installation" have been deleted; the note to entry has been slightly changed.]

3.23 percentile value

 $U_{x\%}$

value such that x percent (x %) of measurements are smaller than or equal to that value, over a given period

3.24 planning level

level of a particular disturbance in a particular environment, adopted as a reference value for the limits to be set for the emissions from the installations in a particular system, in order to coordinate those limits with all the limits adopted for equipment and installations intended to be connected to the power supply system

Note 1 to entry: Planning levels are considered internal quality objectives to be specified at a local level by those responsible for planning and operating the power supply system in the relevant area.

[SOURCE: IEC TR 61000-3-6:2008, 3.16]

3.25 point of common coupling PCC

point in a public power supply network, electrically nearest to a particular load, at which other loads are, or ~~may~~ can be, connected

Note 1 to entry: These loads can be either devices, equipment or systems, or distinct network user's installations.

[SOURCE: IEC 60050-161:1990, 161-07-15, modified – The words "of a power supply network" have been changed to "in a public power supply network" and "may" has been replaced with "can" in the definition. In Note 1, "customer's" has been changed to "user's" and Note 2 has been deleted.]

3.26 point of supply supply terminal

point in a distribution or transmission network designated as such and contractually fixed, at which electric energy is exchanged between contractual partners

Note 1 to entry: The point of supply can be different from the boundary between the electricity supply system and the user's own installation or from the metering point.

[SOURCE: IEC 60050-617:2009, 617-04-02, modified – The words "or transmission" have been added in the definition and "may" has been changed to "can" in the note to entry.]

3.27 network user power network user

party supplying electric power and energy to, or being supplied with electric power and energy from, a transmission system or a distribution system

~~Note 1 to entry: For example: power network user.~~

[SOURCE: IEC 60050-617:2009, 617-02-07, ~~modified – The note to entry has been added~~]

3.28 power quality

characteristics of the electricity at a given point on an electrical system, evaluated against a set of reference technical parameters

Note 1 to entry: These parameters ~~might~~ can, in some cases, relate to the compatibility between electricity supplied on a network and the loads connected to that network.

Note 2 to entry: In the context of this document, power quality refers to the point of supply and focuses on defining the characteristics of the voltage and frequency.

[SOURCE: IEC 60050-617:2009, 617-01-05, modified – The words "electric current, voltage and frequencies" have been replaced with "electricity". In Note 1 to entry, "electric power system" has been replaced with "network" and Note 2 to entry has been added.]

3.29 power quality indices

technical parameters characterizing the quality of electricity, measured at a given point, relevant for the assessment of the quality of the electricity delivered by a network operator

3.30 profile

specification that supplements a standard by limiting options, in order to serve the needs of users in a geographic area or in an application domain