
**Acoustics — Laboratory measurement
of sound insulation of building
elements —**

**Part 5:
Requirements for test facilities and
equipment**

*Acoustique — Mesurage en laboratoire de l'isolation acoustique des
éléments de construction —*

Partie 5: Exigences relatives aux installations et appareillage d'essai

ISO 10140-5:2021

<https://standards.iteh.ai/catalog/standards/iso/82f1e450-8c0a-4dff-9206-a17b54003862/iso-10140-5-2021>



iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[ISO 10140-5:2021](https://standards.iteh.ai/catalog/standards/iso/82f1e450-8c0a-4dff-9206-a17b54003862/iso-10140-5-2021)

<https://standards.iteh.ai/catalog/standards/iso/82f1e450-8c0a-4dff-9206-a17b54003862/iso-10140-5-2021>



COPYRIGHT PROTECTED DOCUMENT

© ISO 2021

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Contents

Page

Foreword	iv
Introduction	v
1 Scope	1
2 Normative references	1
3 Terms and definitions	2
4 Laboratory test facilities for airborne sound insulation measurements	2
4.1 General.....	2
4.2 Test rooms.....	2
4.2.1 Volume.....	2
4.2.2 Diffusion.....	2
4.2.3 Reverberation time.....	2
4.2.4 Background noise.....	3
4.2.5 Suppression of flanking transmission.....	3
4.3 Test opening.....	3
4.3.1 General.....	3
4.3.2 Full-sized test opening.....	3
4.3.3 Reduced-size test opening.....	5
4.3.4 Specific small-sized test opening.....	6
5 Laboratory test facilities for impact sound insulation measurements	8
5.1 General.....	8
5.2 Receiving room.....	8
5.2.1 Volume.....	8
5.2.2 Further requirements.....	8
5.3 Test opening.....	8
5.3.1 Full-sized test opening.....	8
5.3.2 Frame specification.....	8
6 Equipment	9
6.1 Airborne sound field.....	9
6.2 Impact sound source.....	9
6.3 Measurement system.....	9
Annex A (normative) Estimation of the maximum measurable sound reduction index	11
Annex B (normative) Standard basic elements for measuring the improvement of airborne sound insulation by linings	15
Annex C (normative) Standard floors for measuring the improvement of impact sound insulation by floor coverings	16
Annex D (normative) Qualification procedure for loudspeakers and loudspeaker positions	21
Annex E (normative) Standard tapping machine	25
Annex F (normative) Alternative impact sound sources	27
Annex G (normative) Wooden mock-up floor for measuring the improvement of impact sound insulation by floor coverings	32
Annex H (normative) Specification of heavy and intense rain — Example of a tank with perforated base	33
Annex I (informative) Reference test specimens for rainfall sound measurements	37
Bibliography	39

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 43, *Acoustics*, Subcommittee SC 2, *Building acoustics*, in collaboration with the European Committee for Standardization (CEN) Technical Committee CEN/TC 126, *Acoustic properties of building elements and of buildings*, in accordance with the Agreement on technical cooperation between ISO and CEN (Vienna Agreement).

This second edition cancels and replaces the first edition (ISO 10140-5:2010), which has been technically revised. It also incorporates the Amendment ISO 10140-5:2010/Amd1:2014.

The main changes compared to the previous edition are as follows:

- all references in the text have been updated;
- in [Clause 2](#), the normative references have been updated;
- in [Clause 3](#), the terms and definitions have been added;
- [Annex B](#), [Annex C](#) and [Annex H](#) have been updated.

A list of all parts in the ISO 10140 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

Introduction

ISO 10140 (all parts) concerns laboratory measurement of the sound insulation of building elements (see [Table 1](#)).

ISO 10140-1 specifies the application rules for specific elements and products, including specific requirements for the preparation and mounting of the test specimens, and for the operating and test conditions. ISO 10140-2 and ISO 10140-3 contain the general procedures for airborne and impact sound insulation measurements, respectively, and refer to ISO 10140-4 and this document where appropriate. For elements and products without a specific application rule described in ISO 10140-1, it is possible to apply ISO 10140-2 and ISO 10140-3. ISO 10140-4 contains basic measurement techniques and processes. This document contains requirements for test facilities and equipment. For the structure of ISO 10140 (all parts), see [Table 1](#).

ISO 10140 (all parts) was developed to improve the layout for laboratory measurements, ensure consistency and simplify future changes and additions regarding mounting conditions of test elements in laboratory and field measurements. ISO 10140 (all parts) aims at presenting a well-written and arranged format for laboratory measurements.

ISO 10140-1 is planned to be updated with application rules for other products.

Table 1 — Structure and contents of ISO 10140 (all parts)

Relevant part of ISO 10140	Main purpose, contents and use	Detailed content
ISO 10140-1	It indicates the appropriate test procedure for elements and products. For certain types of element/product, it can contain additional and more specific instructions about quantities and test element size and about preparation, mounting and operating conditions. Where no specific details are included, the general guidelines are according to ISO 10140-2 and ISO 10140-3.	Appropriate references to ISO 10140-2 and ISO 10140-3 and product-related, specific and additional instructions on: <ul style="list-style-type: none"> — specific quantities measured; — size of test element; — boundary and mounting conditions; — conditioning, testing and operating conditions; — additional specifics for test report.
ISO 10140-2	It gives a procedure for airborne sound insulation measurements according to ISO 10140-4 and ISO 10140-5. For products without specific application rules, it is sufficiently complete and general for the execution of measurements. However, for products with specific application rules, measurements are carried out according to ISO 10140-1, if available.	<ul style="list-style-type: none"> — Definitions of main quantities measured — General mounting and boundary conditions — General measurement procedure — Data processing — Test report (general points)
ISO 10140-3	It gives a procedure for impact sound insulation measurements according to ISO 10140-4 and ISO 10140-5. For products without specific application rules, it is sufficiently complete and general for the execution of measurements. However, for products with specific application rules, measurements are carried out according to ISO 10140-1, if available.	<ul style="list-style-type: none"> — Definitions of main quantities measured — General mounting and boundary conditions — General measurement procedure — Data processing — Test report (general points)

Table 1 (continued)

Relevant part of ISO 10140	Main purpose, contents and use	Detailed content
ISO 10140-4	It gives all the basic measurement techniques and processes for measurement according to ISO 10140-2 and ISO 10140-3 or facility qualifications according to ISO 10140-5. Much of the content is implemented in software.	<ul style="list-style-type: none"> — Definitions — Frequency range — Microphone positions — SPL measurements — Averaging, space and time — Correction for background noise — Reverberation time measurements — Loss factor measurements — Low-frequency measurements — Radiated sound power by velocity measurement
ISO 10140-5	It specifies all information needed to design, construct and qualify the laboratory facility, its additional accessories and measurement equipment (hardware).	<p>Test facilities, design criteria:</p> <ul style="list-style-type: none"> — volumes, dimensions; — flanking transmission; — laboratory loss factor; — maximum achievable sound reduction index; — reverberation time; — influence of lack of diffusivity in the laboratory. <p>Test openings:</p> <ul style="list-style-type: none"> — standard openings for walls and floors; — other openings (windows, doors, small technical elements); — filler walls in general. <p>Requirements for equipment:</p> <ul style="list-style-type: none"> — loudspeakers, number, positions; — tapping machine and other impact sources; — measurement equipment. <p>Reference constructions:</p> <ul style="list-style-type: none"> — basic elements for airborne and impact insulation improvement; — corresponding reference performance curves.