
**Acoustics — Laboratory and field
measurement of flanking transmission
for airborne, impact and building
service equipment sound between
adjoining rooms —**

**Part 1:
Frame document**

*Acoustique — Mesurage en laboratoire et sur site des transmissions
latérales du bruit aérien, des bruits de choc et du bruit d'équipement
technique de bâtiment entre des pièces adjacentes —*

Partie 1: Document cadre



Sample Document

get full document from standards.iteh.ai



COPYRIGHT PROTECTED DOCUMENT

© ISO 2017, Published in Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Ch. de Blandonnet 8 • CP 401
CH-1214 Vernier, Geneva, Switzerland
Tel. +41 22 749 01 11
Fax +41 22 749 09 47
copyright@iso.org
www.iso.org

Contents

	Page
Foreword	v
1 Scope	1
2 Normative references	1
3 Terms and definitions	2
4 Quantities to characterize flanking transmission	7
4.1 General	7
4.2 Normalized flanking level difference, $D_{n,f}$, normalized flanking impact sound pressure level, $L_{n,f}$, and normalized flanking equipment sound pressure level, $L_{ne0,f}$	8
4.2.1 General	8
4.2.2 $D_{v,ij,n}$ estimated from measurements of $D_{n,f}$	8
4.3 Vibration reduction index, K_{ij}	8
4.3.1 General	8
4.3.2 K_{ij} for combinations of Type A and B elements	9
4.3.3 Strong coupling between Type A elements	9
4.4 Normalized direction-average vibration level difference, $D_{v,ij,n}$	9
4.4.1 General	9
4.5 Selection of the measurement method	10
5 Instrumentation	10
5.1 General	10
5.2 Verification	11
6 General requirements for test facility and test elements	11
6.1 Laboratory	11
6.2 Field	14
7 Measurement methods	14
7.1 Measurement of $D_{n,f}$, $L_{n,f}$ and $L_{ne0,f}$	14
7.1.1 Generation of sound field in the source room	14
7.1.2 Measurement of the average sound pressure level	16
7.1.3 Measurement of reverberation time and evaluation of the equivalent sound absorption area	18
7.2 Measurement of K_{ij} and $D_{v,ij,n}$	18
7.2.1 General aspects for K_{ij}	18
7.2.2 General aspects for $D_{v,ij,n}$	18
7.2.3 Vibration measurement	19
7.2.4 Generation of vibration on the source element	20
7.2.5 Procedure for Type A and B elements	20
7.2.6 Steady-state excitation	21
7.2.7 Transient excitation	22
7.3 Measurement of the structural reverberation time for Type A elements	22
7.3.1 General	22
7.3.2 Excitation of the test element	22
7.3.3 Measurement and excitation positions	23
7.3.4 Evaluation of the decay curves	23
7.3.5 Lower limits for reliable results caused by filter and detector	24
7.4 Frequency range of measurement	24
8 Influences from other parts of the test facility or the building construction in the field situation	24
8.1 Laboratory installations of test junctions	24

8.2	Criterion to assess flanking transmission for junctions comprised of Type A elements.....	25
8.2.1	General.....	25
8.2.2	Practical considerations.....	25
8.3	Verification procedure for a Type B flanking element that is structurally independent of a separating element.....	25
9	Shielding	26
10	Expression of results	26
Annex A (normative) Assessing the decrease in vibration level with distance		28
Annex B (normative) Calibrated structure-borne sound source		30
Bibliography		34

Sample Document

get full document from standards.iteh.ai

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see the following URL: www.iso.org/iso/foreword.html.

This document was prepared by ISO/TC 43, *Acoustics*, Subcommittee SC 2, *Building acoustics*.

This second edition cancels and replaces the first edition (ISO 10848-1:2006), which has been technically revised with the following changes:

- a) extension to field measurements;
- b) extension to building service equipment;
- c) normalized direction-averaged vibration level difference for junctions between lightweight elements has been introduced;
- d) an assessment method for the decrease in vibration level with distance has been introduced;
- e) transmission function measurements with a calibrated structure-borne sound source has been introduced;
- f) definitions of element types A and B to avoid issues with the terms “heavy” and “light” have been added.

A list of all the parts in the ISO 10848 series can be found on the ISO website.

Sample Document

get full document from standards.iteh.ai

Acoustics — Laboratory and field measurement of flanking transmission for airborne, impact and building service equipment sound between adjoining rooms —

Part 1: Frame document

1 Scope

ISO 10848 (all parts) specifies measurement methods to characterize the flanking transmission of one or several building components. These measurements are performed in a laboratory test facility or in the field.

The performance of the building components is expressed either as an overall quantity for the combination of elements and junction (such as the normalized flanking level difference and/or normalized flanking impact sound pressure level) or as the vibration reduction index of a junction or the normalized direction-average vibration level difference of a junction.

Two approaches are used for structure-borne sound sources in buildings, a normalized flanking equipment sound pressure level and a transmission function that can be used to estimate sound pressure levels in a receiving room due to structure-borne excitation by service equipment in a source room. The former approach assumes that flanking transmission is limited to one junction (or no junction if the element supporting the equipment is the separating element), and the latter considers the combination of direct (if any) and all flanking transmission paths.

This document contains definitions, general requirements for test elements and test rooms, and measurement methods. Guidelines are given for the selection of the quantity to be measured, depending on the junction and the types of building elements involved. Other parts of ISO 10848 specify the application for different types of junction and building elements.

The quantities characterizing the flanking transmission can be used to compare different products, or to express a requirement, or as input data for prediction methods, such as ISO 12354-1 and ISO 12354-2.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 717-1, *Acoustics — Rating of sound insulation in buildings and of building elements — Part 1: Airborne sound insulation*

ISO 717-2, *Acoustics — Rating of sound insulation in buildings and of building elements — Part 2: Impact sound insulation*

ISO 3382-2, *Acoustics — Measurement of room acoustic parameters — Part 2: Reverberation time in ordinary rooms*

ISO 7626-1, *Mechanical vibration and shock — Experimental determination of mechanical mobility — Part 1: Basic terms and definitions, and transducer specifications*

ISO 7626-5, *Vibration and shock — Experimental determination of mechanical mobility — Part 5: Measurements using impact excitation with an exciter which is not attached to the structure*

ISO 10140-4:2010, *Acoustics — Laboratory measurement of sound insulation of building elements — Part 4: Measurement procedures and requirements*

ISO 10140-5:2010, *Acoustics — Laboratory measurement of sound insulation of building elements — Part 5: Requirements for test facilities and equipment*

IEC 61183, *Electroacoustics—Random-incidence and diffuse-field calibration of sound level meters*

IEC 61260 (all parts), *Electroacoustics — Octave-band and fractional-octave-band filters*

IEC 61672-1, *Electroacoustics — Sound level meters elements — Part 1: Specifications*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

3.1 average sound pressure level in a room

L

ten times the common logarithm of the ratio of the space and time average of the sound pressure squared to the square of the reference sound pressure, the space average being taken over the entire room with the exception of those parts where the direct radiation of a sound source or the near field of the boundaries (walls, etc.) is of significant influence

Note 1 to entry: This quantity is expressed in decibels.

Note 2 to entry: If a continuously moving microphone is used, L is determined as follows:

$$L = 10 \lg \left(\frac{\frac{1}{T_m} \int_0^{T_m} p^2(t) dt}{p_0^2} \right)$$

3.2 normalized flanking level difference

$D_{n,f}$

difference in the space and time averaged sound pressure level produced in two rooms by one or more sound sources in one of them, when the transmission only occurs through a specified flanking path and the result is normalized to an equivalent sound absorption area in the receiving room as follows:

$$D_{n,f} = L_1 - L_2 - 10 \lg \frac{A}{A_0}$$

where

L_1 is the average sound pressure level in the source room, in dB;

L_2 is the average sound pressure level in the receiving room, in dB;

A is the equivalent sound absorption area in the receiving room, in m²;

A_0 is the reference equivalent sound absorption area, in m²; $A_0 = 10 \text{ m}^2$

Note 1 to entry: This quantity is expressed in decibels.

Note 2 to entry: For clarity, the term $D_{n,f}$ is used when only one flanking path determines the sound transmission (such as with suspended ceilings) and the term $D_{n,f,ij}$ is used when only one specified transmission path ij out of several paths is considered (such as with structure-borne sound transmission on junctions of three or four connected elements).

3.3

normalized flanking impact sound pressure level

$L_{n,f}$

space and time averaged sound pressure level in the receiving room produced by a tapping machine operating at different positions on a tested element (floor) in the source room, when the transmission only occurs through a specified flanking path and the result is normalized to an equivalent sound absorption area, in the receiving room and is expressed as follows:

$$L_{n,f} = L_2 + 10 \lg \frac{A}{A_0}$$

where

L_2 is the average sound pressure level in the receiving room, in dB;

A is the equivalent sound absorption area in the receiving room, in m²;

A_0 is the reference equivalent sound absorption area, in m²; $A_0 = 10 \text{ m}^2$

Note 1 to entry: This quantity is expressed in decibels.

Note 2 to entry: For clarity, the term $L_{n,f}$ is used when only one flanking path determines the sound transmission (such as with access floors) and the term $L_{n,f,ij}$ is used when only one specified transmission path ij out of several paths is considered (such as with structure-borne sound transmission on junctions of three or four connected elements).

3.4

normalized flanking equipment sound pressure level

$L_{ne0,f}$

space and time averaged sound pressure level in the receiving room produced by a structure-borne sound source injecting a unit power (1 W) at different positions on a tested element in the source room, when the transmission only occurs through a specified flanking path and the result is normalized to an equivalent sound absorption area in the receiving room and is expressed as follows:

$$L_{ne0,f} = L_{2e} + 10 \lg \frac{A}{A_0}$$

where

L_{2e} is the average sound pressure level in the receiving room with a structure-borne sound source injecting 1 W into the tested element, in dB;

A is the equivalent sound absorption area in the receiving room, in m²;

A_0 is the reference equivalent sound absorption area, in m²; $A_0 = 10 \text{ m}^2$

Note 1 to entry: This quantity is expressed in decibels.

Note 2 to entry: For clarity, the term $L_{ne0,f}$ is used when only one flanking path determines the sound transmission (such as with equipment installed on access floors or light façades) and the term $L_{ne0,f,ij}$ is used when only one specified transmission path ij out of several paths is considered (such as with structure-borne sound transmission on junctions of three or four connected elements).

Note 3 to entry: The sound pressure level generated by any equipment, $L_{ne,f,equip}$, can be approximated when the equipment has been characterized using EN 15657 and its averaged installed power $L_{W,equip}$ has been determined from the spatial average single equivalent mobility of the supporting element as described in EN 15657:2009, C.3 and using EN 15657 to give the installed power from the equipment and receiver characteristics.

3.5 transmission function for excitation position k

$D_{TF,k}$

difference between the space and time averaged sound pressure level in the receiving room and the structure-borne sound power level for a source at excitation position k on the source element as follows:

$$D_{TF,k} = L_{av,k} - L_{W,k}$$

where

$L_{av,k}$ is the average sound pressure level in the receiving room, in dB, referenced to 2×10^{-5} Pa;

$L_{W,k}$ is the structure-borne sound power level, in dB, referenced to 10^{-12} W.

Note 1 to entry: This quantity is expressed in decibels.

Note 2 to entry: The transmission function [25] is specific to the building in which it is measured and quantifies the combination of all the transmission paths from the power injected at a source position on an element to a spatial average sound pressure level in a receiving room in a building. In some cases, the transmission function will only correspond to the combination of all the flanking paths, but in some situations, it will be a combination of the direct transmission path and all the flanking paths. The building could either be a laboratory set-up (such as a flanking laboratory with wall and/or floor junctions) or an actual building.

3.6 spatial average transmission function

$D_{TF,av}$

average transmission function from K excitation positions on the source element as follows:

$$D_{TF,av} = 10 \lg \left(\frac{\sum_{k=1}^K 10^{D_{TF,k}/10}}{K} \right)$$

3.7 normalized spatial average transmission function

$D_{TF,av,n}$

spatial average transmission function (3.6) which is normalized to an equivalent sound absorption area in the receiving room that is calculated as follows:

$$D_{TF,av,n} = D_{TF,av} + 10 \lg \frac{A}{A_0}$$

Note 1 to entry: This quantity is expressed in decibels.

Note 2 to entry: Normalized transmission functions can be used in the following ways:

- to assess the accuracy of prediction models such as ISO 12354-1 or ISO 12354-2 which consider a limited number of flanking transmission paths that are either measured according to ISO 10848 (all parts), or estimated according to ISO 12354-1 or ISO 12354-2;
- to create databases of average transmission functions as a simplified prediction tool for different building types;
- to determine the optimum position for service equipment in an existing building.

3.8 structural reverberation time

T_s

time that would be required for the velocity or acceleration level in a structure to decrease by 60 dB after the structure-borne sound source has stopped

Note 1 to entry: This quantity is expressed in seconds.

Note 2 to entry: The definition of T_s with a decrease by 60 dB of the velocity or acceleration level in a structure can be fulfilled by linear extrapolation of shorter evaluation ranges.

3.9

average velocity level

L_v

ten times the common logarithm of the ratio of the time and space averaged mean-square normal velocity of an element to the squared reference velocity as follows:

$$L_v = 10 \lg \left(\frac{\frac{1}{T_m} \int_0^{T_m} v^2(t) dt}{v_0^2} \right)$$

where v_0 is the reference velocity, in m/s; $v_0 = 1 \times 10^{-9}$ m/s

Note 1 to entry: This quantity is expressed in decibels.

Note 2 to entry: The reference velocity preferred in ISO 1683 is 1×10^{-9} m/s, although a common reference value in some countries is still $v_0 = 5 \times 10^{-8}$ m/s.

Note 3 to entry: Instead of the average velocity level, the average acceleration level L_a can be measured. The reference acceleration preferred in ISO 1683 is 1×10^{-6} m/s².

3.10

velocity level difference

$D_{v,ij}$

difference between the *average velocity level* (3.9) of an element i and that of an element j , when only the element i is excited (airborne or structure-borne)

Note 1 to entry: This quantity is expressed in decibels.

3.11

direction-averaged velocity level difference

$\overline{D_{v,ij}}$

arithmetic average of $D_{v,ij}$ and $D_{v,ji}$ as defined as follows:

$$\overline{D_{v,ij}} = \frac{1}{2} (D_{v,ij} + D_{v,ji})$$

where

$D_{v,ij}$ is the difference between the *average velocity level* (3.9) of an element i and that of an element j , when only the element i is excited, in dB;

$D_{v,ji}$ is the difference between the average velocity level of an element j and that of an element i , when only the element j is excited, in dB.

Note 1 to entry: This quantity is expressed in decibels.

3.12

equivalent absorption length of an element

a_j

length of a fictional totally-absorbing junction of an element j when the critical frequency is assumed to be 1 000 Hz, giving the same losses as the total losses of the element j in a given situation as follows:

$$a_j = \frac{2,2\pi^2 S_j}{T_{s,j} c_0 \sqrt{\frac{f}{f_{\text{ref}}}}}$$

where

$T_{s,j}$ is the *structural reverberation time* (3.8) of the element j , in s;

S_j is the surface area of the element j , in m²;

c_0 is the speed of sound in air, in m/s;

f is the frequency, in Hz;

f_{ref} is the reference frequency, in Hz ($f_{\text{ref}} = 1\,000$ Hz).

Note 1 to entry: This quantity is expressed in metres.

3.13

vibration reduction index

K_{ij}
direction-averaged velocity level difference (3.11) between two elements across a junction that is normalised to the junction length and the equivalent sound absorption length of both elements as follows:

$$K_{ij} = \overline{D_{v,ij}} + 10 \lg \left(\frac{l_{ij}}{\sqrt{a_i a_j}} \right)$$

where

$\overline{D_{v,ij}}$ is the direction-averaged velocity level difference between elements i and j , in dB;

l_{ij} is the junction length between elements i and j , in m;

a_i, a_j are the equivalent absorption lengths of elements i and j , in m.

Note 1 to entry: This quantity is expressed in decibels.

Note 2 to entry: K_{ij} can be obtained from measurements of the *velocity level difference* (3.10) in both directions across the junction and the *structural reverberation time* (3.8) of the two elements i and j .

3.14

normalized direction-average vibration level difference

$\overline{D_{v,ij,n}}$
difference in velocity level between elements i and j , averaged over the excitation from i and excitation from j , and normalized to the junction length and the measurement areas on both elements as follows:

$$\overline{D_{v,ij,n}} = \overline{D_{v,ij}} + 10 \lg \left(\frac{l_{ij} l_0}{\sqrt{S_{m,i} S_{m,j}}} \right)$$

where