
**Acoustics — Laboratory and field
measurement of flanking transmission
for airborne, impact and building
service equipment sound between
adjoining rooms —**

**Part 3:
Application to Type B elements
when the junction has a substantial
influence**

*Acoustique — Mesurage en laboratoire et sur le terrain des
transmissions latérales du bruit aérien, des bruits de choc et du bruit
d'équipement technique de bâtiment entre des pièces —*

*Partie 3: Application aux éléments de Type B lorsque la jonction a une
influence importante*



Sample Document

get full document from standards.iteh.ai



COPYRIGHT PROTECTED DOCUMENT

© ISO 2017, Published in Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Ch. de Blandonnet 8 • CP 401
CH-1214 Vernier, Geneva, Switzerland
Tel. +41 22 749 01 11
Fax +41 22 749 09 47
copyright@iso.org
www.iso.org

Contents

	Page
Foreword	iv
1 Scope	1
2 Normative references	1
3 Terms and definitions	2
4 Instrumentation	3
5 Test arrangement	3
5.1 Requirements for the laboratory	3
5.2 Requirements for a building structure in the field situation	4
5.3 Installation of the test junction	4
5.4 Shielding technique	4
6 Test procedures	4
7 Precision	5
8 Expression of results	5
9 Test report	6
Annex A (informative) Measurement of $D_{n,f,ij,l}$ and $L_{n,f,ij,l}$ and $L_{ne0,f,ij,l}$ with sound intensity	7
Bibliography	8

Sample Document

get full document from standards.iteh.ai

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see the following URL: www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 43, *Acoustics*, Subcommittee SC 2, *Building acoustics*.

This second edition cancels and replaces the first edition (ISO 10848-3:2006), which has been technically revised with the following changes:

- a) extension to field measurements;
- b) extension to building service equipment with the introduction of the normalized flanking equipment sound pressure level;
- c) normalized direction-averaged vibration level difference for junctions between lightweight elements has been introduced.

A list of all the parts in the ISO 10848 series can be found on the ISO website.

Acoustics — Laboratory and field measurement of flanking transmission for airborne, impact and building service equipment sound between adjoining rooms —

Part 3:

Application to Type B elements when the junction has a substantial influence

1 Scope

ISO 10848 (all parts) specifies measurement methods to characterize the flanking transmission of one or several building components.

This document specifies laboratory and field measurements of buildings for Type B elements (defined in ISO 10848-1) when the junction has a substantial influence.

Laboratory measurements are used to quantify the performance of the junction with suppressed flanking transmission from the laboratory structure. Field measurements are used to characterize the *in situ* performance and it is not usually possible to suppress unwanted flanking transmission sufficiently; hence, the results can only be considered representative of the performance of that junction when installed in that particular building structure.

This document is referred to in ISO 10848-1:2017, 4.5 as being a supporting part to the frame document and applies to Type B elements that are structurally connected as defined in ISO 10848-1.

The measured quantities can be used to compare different products, or to express a requirement, or as input data for prediction methods, such as ISO 12354-1 and ISO 12354-2.

The relevant quantity to be measured is selected according to ISO 10848-1:2017, 4.5. The performance of the building components is expressed either as an overall quantity for the combination of elements and junction (such as $D_{n,f,ij}$ and/or $L_{n,f,ij}$ and/or $L_{ne0,f,ij}$) or as the normalized direction-average velocity level difference $D_{v,ij,n}$ of a junction. $D_{n,f,ij}$, $L_{n,f,ij}$, $L_{ne0,f,ij}$ and $D_{v,ij,n}$ depend on the actual dimensions of the elements.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 717-1, *Acoustics — Rating of sound insulation in buildings and of building elements — Part 1: Airborne sound insulation*

ISO 717-2, *Acoustics — Rating of sound insulation in buildings and of building elements — Part 2: Impact sound insulation*

ISO 10848-1:2017, *Acoustics — Laboratory and field measurement of flanking transmission for airborne, impact and building service equipment sound between adjoining rooms — Part 1: Frame document*

ISO 12999-1, *Acoustics — Determination and application of measurement uncertainties in building acoustics — Part 1: Sound insulation*