

---

---

**Building environment design —  
Embedded radiant heating and cooling  
systems —**

Part 4:

**Dimensioning and calculation of the  
dynamic heating and cooling capacity  
of Thermo Active Building Systems  
(TABS)**

*Conception de l'environnement des bâtiments — Systèmes intégrés de  
chauffage et de refroidissement par rayonnement —*

*Partie 4: Dimensionnement et calculs relatifs au chauffage  
adiabatique et à la puissance frigorifique pour systèmes d'éléments de  
construction thermoactifs (TABS)*

<https://standards.iteh.ai/catalog/standards/sist/9ad76ecube36/iso-11855-4-2021>



**iTeh Standards**  
**(<https://standards.iteh.ai>)**  
**Document Preview**

[ISO 11855-4:2021](https://standards.iteh.ai/catalog/standards/iso/1046e7a4-5a49-41f5-89dc-9ad76eedbe36/iso-11855-4-2021)

<https://standards.iteh.ai/catalog/standards/iso/1046e7a4-5a49-41f5-89dc-9ad76eedbe36/iso-11855-4-2021>



**COPYRIGHT PROTECTED DOCUMENT**

© ISO 2021

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office  
CP 401 • Ch. de Blandonnet 8  
CH-1214 Vernier, Geneva  
Phone: +41 22 749 01 11  
Email: [copyright@iso.org](mailto:copyright@iso.org)  
Website: [www.iso.org](http://www.iso.org)

Published in Switzerland

# Contents

Page

<b>Foreword</b> .....	<b>iv</b>
<b>Introduction</b> .....	<b>v</b>
<b>1 Scope</b> .....	<b>1</b>
<b>2 Normative references</b> .....	<b>1</b>
<b>3 Terms and definitions</b> .....	<b>1</b>
<b>4 Symbols</b> .....	<b>1</b>
<b>5 The concept of thermally active building surfaces (TABS)</b> .....	<b>4</b>
<b>6 Calculation methods</b> .....	<b>10</b>
6.1 General.....	10
6.2 Rough sizing method.....	13
6.3 Simplified sizing by diagrams.....	13
6.4 Simplified model based on FDM.....	19
6.4.1 Cooling system.....	20
6.4.2 Hydraulic circuit and slab.....	20
6.4.3 Room.....	22
6.4.4 Limits of the method.....	24
6.5 Dynamic building simulation programs.....	25
<b>7 Effects of acoustic ceiling units on the cooling performance of TABS</b> .....	<b>25</b>
<b>8 Input for computer simulations of energy performance</b> .....	<b>25</b>
<b>Annex A (informative) Simplified diagrams</b> .....	<b>27</b>
<b>Annex B (normative) Calculation method</b> .....	<b>33</b>
<b>Annex C (informative) Tutorial guide for assessing the model</b> .....	<b>44</b>
<b>Annex D (informative) Computer program</b> .....	<b>47</b>
<b>Bibliography</b> .....	<b>58</b>

<https://standards.iteh.ai/catalog/standards/iso/1046e7a4-5a49-4115-89dc-9ad76ccdbce56/iso-11855-4-2021>

## Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see [www.iso.org/directives](http://www.iso.org/directives)).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see [www.iso.org/patents](http://www.iso.org/patents)).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see [www.iso.org/iso/foreword.html](http://www.iso.org/iso/foreword.html).

This document was prepared by Technical Committee ISO/TC 205, *Building environment design*, in collaboration with the European Committee for Standardization (CEN) Technical Committee CEN/TC 228, *Heating systems and water based cooling systems in buildings*, in accordance with the Agreement on technical cooperation between ISO and CEN (Vienna Agreement).

This second edition cancels and replaces the first edition (ISO 11855-4:2012), which has been technically revised.

The main changes compared to the previous edition are as follows:

- editorial corrections;
- picture redraws;
- updated Bibliography;
- improved wording.

A list of all parts in the ISO 11855 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at [www.iso.org/members.html](http://www.iso.org/members.html).

## Introduction

The radiant heating and cooling system consists of heat emitting/absorbing, heat supply, distribution, and control systems. The ISO 11855 series deals with the embedded surface heating and cooling system that directly controls heat exchange within the space. It does not include the system equipment itself, such as heat source, distribution system and controller.

The ISO 11855 series addresses an embedded system that is integrated with the building structure. Therefore, the panel system with open air gap, which is not integrated with the building structure, is not covered by this series.

The ISO 11855 series is applicable to water-based embedded surface heating and cooling systems in buildings. The ISO 11855 series is applied to systems using not only water but also other fluids or electricity as a heating or cooling medium. The ISO 11855 series is not applicable for testing of systems. The methods do not apply to heated or chilled ceiling panels or beams.

The object of the ISO 11855 series is to provide criteria to effectively design embedded systems. To do this, it presents comfort criteria for the space served by embedded systems, heat output calculation, dimensioning, dynamic analysis, installation, control method of embedded systems, and input parameters for the energy calculations.

The ISO 11855 series consists of the following parts, under the general title *Building environment design — Embedded radiant heating and cooling systems*:

- Part 1: *Definitions, symbols, and comfort criteria*
- Part 2: *Determination of the design heating and cooling capacity*
- Part 3: *Design and dimensioning*
- Part 4: *Dimensioning and calculation of the dynamic heating and cooling capacity of Thermo Active Building Systems (TABS)*
- Part 5: *Installation*
- Part 6: *Control*
- Part 7: *Input parameters for the energy calculation*

ISO 11855-1 specifies the comfort criteria which should be considered in designing embedded radiant heating and cooling systems, since the main objective of the radiant heating and cooling system is to satisfy thermal comfort of the occupants. ISO 11855-2 provides steady-state calculation methods for determination of the heating and cooling capacity. ISO 11855-3 specifies design and dimensioning methods of radiant heating and cooling systems to ensure the heating and cooling capacity. ISO 11855-4, this document, provides a dimensioning and calculation method to design Thermo Active Building Systems (TABS) for energy saving purposes, since radiant heating and cooling systems can reduce energy consumption and heat source size by using renewable energy. ISO 11855-5 addresses the installation process for the system to operate as intended. ISO 11855-6 shows a proper control method of the radiant heating and cooling systems to ensure the maximum performance which was intended in the design stage when the system is actually being operated in a building. ISO 11855-7 presents a calculation method for input parameters to ISO 52031.



# Building environment design — Embedded radiant heating and cooling systems —

## Part 4:

# Dimensioning and calculation of the dynamic heating and cooling capacity of Thermo Active Building Systems (TABS)

## 1 Scope

This document allows the calculation of peak cooling capacity of Thermo Active Building Systems (TABS), based on heat gains, such as solar gains, internal heat gains, and ventilation, and the calculation of the cooling power demand on the water side, to be used to size the cooling system, as regards the chiller size, fluid flow rate, etc.

This document defines a detailed method aimed at the calculation of heating and cooling capacity in non-steady state conditions.

## 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 11855-1, *Building environment design — Embedded radiant heating and cooling systems — Part 1: Definitions, symbols, and comfort criteria*

ISO 11855-2, *Building environment design — Embedded radiant heating and cooling systems — Part 2: Determination of the design heating and cooling capacity*

## 3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 11855-1 apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <https://www.electropedia.org/>

## 4 Symbols

For the purposes of this document, the symbols in [Table 1](#) apply.

**Table 1 — Symbols**

Symbol	Unit	Quantity
$A_F$	m <sup>2</sup>	Area of the heating/cooling surface area
$A_W$	m <sup>2</sup>	Total area of internal vertical walls (i.e. vertical walls, external façades excluded)
$C$	J/(m <sup>2</sup> ·K)	Specific thermal capacity of the thermal node under consideration