
Cleanrooms and associated controlled environments —

**Part 17:
Particle deposition rate applications**

Salles propres et environnements maîtrisés apparentés —

Partie 17: Applications de taux de dépôt de particules

(<https://standards.iteh.ai>)
Document Preview

[ISO 14644-17:2021](https://standards.iteh.ai/catalog/standards/iso/de26f6c5-905a-4f9a-8233-0138361b4183/iso-14644-17-2021)

<https://standards.iteh.ai/catalog/standards/iso/de26f6c5-905a-4f9a-8233-0138361b4183/iso-14644-17-2021>



iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[ISO 14644-17:2021](https://standards.iteh.ai/catalog/standards/iso/de26f6c5-905a-4f9a-8233-0138361b4183/iso-14644-17-2021)

<https://standards.iteh.ai/catalog/standards/iso/de26f6c5-905a-4f9a-8233-0138361b4183/iso-14644-17-2021>



COPYRIGHT PROTECTED DOCUMENT

© ISO 2021

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Contents

	Page
Foreword	iv
Introduction	v
1 Scope	1
2 Normative references	1
3 Terms and definitions	1
4 Symbols	3
5 Particle deposition rate methodology	4
5.1 General.....	4
5.2 Establishing the particle deposition rate required for control of particle deposition on vulnerable surfaces.....	4
5.3 Particle deposition rate for demonstrating control of particle contamination.....	5
6 Measurement of particle deposition rate	5
7 Particle deposition rate level	6
8 Documentation	7
Annex A (informative) Measurement of particle deposition rate	8
Annex B (informative) Examples of particle deposition rate measurements	12
Annex C (informative) Measurement of the particle obscuration	16
Annex D (informative) Relationship between particle deposition rate and airborne concentration of particles	19
Annex E (informative) Assessment and control of particle deposition	20
Bibliography	25

[ISO 14644-17:2021](https://standards.iteh.ai/catalog/standards/iso/de26f6c5-905a-4f9a-8233-0138361b4183/iso-14644-17-2021)

<https://standards.iteh.ai/catalog/standards/iso/de26f6c5-905a-4f9a-8233-0138361b4183/iso-14644-17-2021>

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 209, *Cleanrooms and associated controlled environments*, in collaboration with the European Committee for Standardization (CEN) Technical Committee CEN/TC 243, *Cleanroom technology*, in accordance with the Agreement on technical cooperation between ISO and CEN (Vienna Agreement).

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

A list of all parts in the ISO 14644 series can be found on the ISO website.

Introduction

Cleanrooms and associated controlled environments are used to control contamination to levels appropriate for accomplishing contamination-sensitive activities. Products and processes that benefit from the control of contamination include those in industries such as aerospace, microelectronics, optics, nuclear, food, healthcare, pharmaceuticals, and medical devices.

ISO 14644-1:2015 considers airborne particles in cleanrooms and classifies cleanroom cleanliness by maximum permitted concentrations, and both ISO 14644-9:2012 and IEST-STD-CC1246E:2013 consider the concentration of surface particles. This document considers the rate of particle deposition onto cleanroom surfaces and is based on VCCN Guideline 9^[5]. The particle deposition rate is important, as the probability of contamination by airborne particles onto contamination sensitive, vulnerable surfaces, such as manufactured products, is directly related to the particle deposition rate.

ISO 14644-3:2019 gives an overview of methods for the determination of deposition of particles, larger or equal to 0,1 μm . In this document, the focus is on the rate that macroparticles larger than 5 μm deposit on surfaces, and the application of this information to controlling contamination in cleanrooms.

Various sizes of particles are generated in cleanrooms by personnel, machinery, tools, and processes, and distributed by air moving about the cleanroom. According to ISO 14644-1, cleanrooms and controlled environments with a particle class of the ISO 5 series, or cleaner, contain zero or very low concentrations of airborne particles larger than 5 μm . However, in operating cleanrooms, many more particles in the size range of 5 μm to 500 μm , and greater, are found on surfaces than suggested by the classification limits of the size of particles given in ISO 14644-1. The main reason for this is that the largest particles in the range of sizes of macroparticles are not counted by particle counters because of deposition losses in sampling tubes, and at the entry to and within particle counters. Also, for the same reason, only a proportion of the smaller particles in the range of sizes is measured. In many cases, large particles cause contamination problems and their presence and potential for deposition onto contamination sensitive, vulnerable surfaces is best determined by measuring the particle deposition rate onto surfaces.

Particles smaller than 5 μm are most likely to be removed from the cleanroom air by the ventilation system but, for particles above 10 μm , more than 50 % is removed from the air by surface deposition. Above 40 μm , more than 90 % is deposited (see Reference [6]). The dominant deposition mechanism of this size of particles has been shown to be gravitational but air turbulence and electrostatic attraction can also cause deposition (see Reference [7]). These deposited particles can be re-dispersed by walking and cleaning actions, but not by air velocities associated with the cleanroom air. It is important that these particles are removed by cleaning.

The presence and redistribution of particles >5 μm in cleanrooms is mostly related to human or mechanical activity. In a cleanroom "at rest", there is likely to be little activity and dispersion of particles, and the concentration of particles larger than 5 μm is close to zero with no significant particle deposition. Therefore, it is only in the "operational" occupancy state that the particle deposition rate should be considered.

The particle deposition rate is an attribute of a cleanroom or clean zone that determines the likely rate of deposition of airborne particles onto cleanroom surfaces, such as product or process area. Using a risk assessment, the acceptable amount of contamination of a vulnerable surface can be defined, and the particle deposition rate can then be obtained that ensures that this amount of contamination is not exceeded.

Methods of measuring the particle deposition rate in a cleanroom or clean zone are given in this document. These are used during the operation of the cleanroom to ensure that the required particle deposition rate is obtained, and for monitoring the cleanroom and clean zones to demonstrate continuous control of airborne contamination. Monitoring the particle deposition rate also enables PDR peaks to be correlated with activities so as to detect sources of contamination, and indicate what changes are required to working procedures to reduce the contamination risk.