
**Mechanical vibration and shock — Cold
provocation tests for the assessment of
peripheral vascular function —**

**Part 1:
Measurement and evaluation of finger
skin temperature**

*Vibrations et chocs mécaniques — Essais de provocation à froid pour
l'évaluation de la fonction vasculaire périphérique —*

*Partie 1: Mesurage et évaluation de la température de la peau des
doigts*

get full document from standards.iteh.ai



Sample Document

get full document from standards.iteh.ai



COPYRIGHT PROTECTED DOCUMENT

© ISO 2016, Published in Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Ch. de Blandonnet 8 • CP 401
CH-1214 Vernier, Geneva, Switzerland
Tel. +41 22 749 01 11
Fax +41 22 749 09 47
copyright@iso.org
www.iso.org

Contents

Page

Foreword	iv
Introduction	v
1 Scope	1
2 Normative references	1
3 Measurement equipment	1
3.1 General.....	1
3.2 Thermometry.....	2
3.2.1 General.....	2
3.2.2 Sensors.....	2
3.2.3 Recorders.....	2
3.2.4 Calibration.....	2
3.3 Thermography.....	2
3.3.1 General.....	2
3.3.2 Remote-sensing techniques.....	2
3.3.3 Data processing.....	2
3.3.4 Calibration.....	3
4 Measurement procedure	3
4.1 Quantity to be measured.....	3
4.2 Conditions of examination.....	3
4.2.1 General.....	3
4.2.2 Examination room.....	3
4.2.3 Time.....	3
4.2.4 Subject preparation.....	4
4.3 Cold provocation.....	4
4.3.1 Cold-water bath.....	4
4.3.2 Water temperature and duration of immersion.....	5
4.3.3 Choice of test hands and fingers.....	5
4.3.4 Waterproof covering.....	5
4.4 Conduct of the test.....	5
4.4.1 General.....	5
4.4.2 Placement of sensors.....	6
4.4.3 Measurement periods.....	6
5 Safety aspects	7
5.1 General.....	7
5.2 Electrical safety.....	7
5.3 Contraindications.....	7
5.4 Informed consent.....	7
5.5 Examiner and medical supervision.....	7
6 Data reporting	7
6.1 General.....	7
6.2 Examination conditions.....	8
6.2.1 Test conditions.....	8
6.2.2 Subject conditions.....	8
6.2.3 Temperature measurement.....	8
6.2.4 Hand cooling.....	8
6.3 Subject characteristics.....	8
6.4 Symptoms and signs during examination.....	8
6.5 Results.....	8
7 Assessment of normative values and limits	8
Bibliography	9

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the WTO principles in the Technical Barriers to Trade (TBT) see the following URL: [Foreword - Supplementary information](#)

The committee responsible for this document is ISO/TC 108, *Mechanical vibration, shock and condition monitoring*, Subcommittee SC 4, *Human exposure to mechanical vibration and shock*.

This second edition cancels and replaces the first edition (ISO 14835-1:2005), of which it constitutes a minor technical revision. The main change is the specification of additional test conditions in [4.3.2](#).

ISO 14835 consists of the following parts, under the general title *Mechanical vibration and shock — Cold provocation tests for the assessment of peripheral vascular function*:

- *Part 1: Measurement and evaluation of finger skin temperature*
- *Part 2: Measurement and evaluation of finger systolic blood pressure*

Introduction

Finger skin temperature (FST) is related indirectly to finger blood flow and reflects the contribution of feed capillaries, nutritive capillaries and arteries. Mechanical, physiologic and pharmacologic effects at any of these levels may affect FST.

Assessing FST over a sufficient observation time can identify the presence and extent of finger vasoconstriction in response to cold provocation produced by appropriate hand cooling.

The changes in FST during hand cooling normally reflect the degree of vasoconstriction and resistance to blood flow caused by cold provocation, and possibly also alterations of this physiological process. The changes in FST after cold provocation reflect different neurovascular processes that control recovery from cold exposure and the return to steady-state circulatory conditions. The measurement of FST during cold provocation is carried out in a well-controlled environment.

FST indicates intra- and inter-individual variability to some extent. The test results of cold provocation are interpreted together with subjective symptoms, signs and history, including vibration exposure.

After having gained experience with the use of ISO 14835-1:2005 over several years, it turned out that cold provocation tests are carried out in some countries using slightly different test parameters. In particular, the test conditions 12 °C water temperature and 5-min immersion duration are not generally used. A survey of ISO/TC 108/SC 4 revealing the current measurement practice of four countries constitutes the background for the development of this second edition of this part of ISO 14835.

The intention is to open the possibility to undertake the tests with specified different test parameters (in particular water temperature and immersion duration) in a clearly defined way in order to make the test results nevertheless comparable. Finally, the overall usage of this International Standard needs to be promoted.

get full document from standards.iteh.ai