
Indoor air —

Part 36:

**Standard method for assessing the
reduction rate of culturable airborne
bacteria by air purifiers using a test
chamber**

Air intérieur —

*Partie 36: Méthode normalisée d'évaluation du taux d'abattement
de bactéries cultivables aéroportées par des purificateurs d'air en
utilisant une chambre d'essai*

ISO 16000-36:2018

<https://standards.iteh.ai/catalog/standards/iso/84bef033-15cb-4877-a826-943dbf6ad56a/iso-16000-36-2018>



iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

ISO 16000-36:2018

<https://standards.iteh.ai/catalog/standards/iso/84bef033-15cb-4877-a826-943dbf6ad56a/iso-16000-36-2018>



COPYRIGHT PROTECTED DOCUMENT

© ISO 2018

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Fax: +41 22 749 09 47
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Contents

Page

Foreword	iv
Introduction	v
1 Scope	1
2 Normative references	1
3 Terms and definitions	1
4 Principle	2
5 Apparatus and materials	2
5.1 Apparatus	2
5.2 Materials	5
5.2.1 Test bacteria	5
5.2.2 Culture media and reagents	5
6 Preparation of the stock cultures and working cultures of the test bacteria	6
6.1 Preparation and maintenance of stock culture	6
6.2 Preparation and maintenance of working cultures of the test bacteria on agar plates	6
6.3 Preparation of working culture suspensions	6
7 Procedures	6
7.1 General	6
7.2 Step 1 — Measurement of the concentration of culturable test bacteria, c_i , without operating the air purifier	7
7.2.1 General	7
7.2.2 Preparation of the air purifier and the test chamber	7
7.2.3 Measurement of bacterial background concentration in the test chamber	7
7.2.4 Nebulizing test bacterial suspension	7
7.2.5 Measurement of the initial concentration of culturable bacteria inside the test chamber after nebulizing	7
7.2.6 Measurement of the concentration of culturable bacteria inside the test chamber after a defined time	8
7.2.7 Post-test actions	8
7.3 Step 2 — Measurement of the concentration of culturable test bacteria, c_t , after operating the air purifier	8
8 Calculation and expression of results	8
8.1 Calculation of the concentration of airborne culturable bacteria	8
8.2 Conditions for a valid test	9
8.3 Reduction rate of bacteria	9
9 Test report	9
10 Quality assurance	10
Annex A (informative) Test chamber	11
Annex B (informative) Natural decay rate according to the operating mode of air purifier	14
Annex C (informative) Homogeneity of airborne culturable bacteria in the test chamber	16
Bibliography	17

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 146, *Air quality*, Subcommittee SC 6, *Indoor air*.

A list of all parts in the ISO 16000 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

This corrected version of ISO 16000-36:2018 incorporates the following corrections:

- In 6.3, the values $1,0 \times 10^3$ to $3,5 \times 10^3$ have been changed to $1,0 \times 10^9$ to $9,0 \times 10^9$;
- In 7.2.5, the values $1,0 \times 10^3$ and $3,2 \times 10^3$ have been changed to $1,0 \times 10^4$ and $3,2 \times 10^4$;
- In 8.2, the values $1,0 \times 10^3$ to $3,2 \times 10^3$ have been changed to $1,0 \times 10^4$ to $3,2 \times 10^4$.