
**Measurement of apparent thermal
conductivity of wet porous building
materials by a periodic method**

*Détermination de la conductivité thermique apparente des matériaux
de construction poreux et mouillés par une méthode périodique*

Sample Document

get full document from standards.iteh.ai



Reference number
ISO 16957:2016(E)

© ISO 2016

Sample Document

get full document from standards.iteh.ai



COPYRIGHT PROTECTED DOCUMENT

© ISO 2016, Published in Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Ch. de Blandonnet 8 • CP 401
CH-1214 Vernier, Geneva, Switzerland
Tel. +41 22 749 01 11
Fax +41 22 749 09 47
copyright@iso.org
www.iso.org

Contents

Page

Foreword	iv
Introduction	v
1 Scope	1
2 Normative references	1
3 Terms and definitions	1
4 Symbols and units	2
5 Determination of thermal conductivity of a wet porous material by non-steady-state method (periodic method)	3
6 Measurement by periodic method	3
6.1 Test procedure.....	3
6.2 Measuring apparatus.....	4
6.2.1 Overall design.....	4
6.2.2 Generator of the sinusoidal or stepwise electric wave.....	4
6.2.3 Heater.....	5
6.2.4 Specimen.....	5
6.3 Specimen preparation and preconditioning.....	5
6.3.1 Initial uniform moisture content and adiabatic and impermeable boundaries.....	5
6.3.2 Embedding and the position of the thermocouples.....	5
6.4 Derivation of thermal diffusivity from measured temperatures (see Annex B).....	5
6.4.1 Solution for heat flow without moisture.....	5
6.4.2 Solution for heat flow with moisture.....	6
6.5 Estimation of measuring uncertainty due to moisture (vapour) movement.....	7
6.6 Thermal conductivity.....	7
7 Test report	7
Annex A (informative) Theoretical background	9
Annex B (informative) Derivation of thermal conductivity from measured temperatures	11
Annex C (informative) Example of measurement by periodic method	17
Bibliography	20

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see the following URL: www.iso.org/iso/foreword.html.

The committee responsible for this document is ISO/TC 163, *Thermal performance and energy use in the built environment*, Subcommittee SC 1, *Test and measurement methods*.

get full document from standards.iteh.ai

Introduction

Most building materials, with the exception of glass and metals, are porous and, thus, absorb moisture due to condensation, rain and water uptake from the ground. The absorbed moisture may damage the materials through, e.g. rotting or frost damage and, thus, may cause their performance to deteriorate. In particular, an increase in the moisture content of insulation material causes a reduction of its thermal resistance, which must be avoided as much as possible to preserve its performance. However, infiltration of rain water into a brick wall or joints of tiles and uptake of ground water into the foundation (footing) are very difficult to avoid. Therefore, it is important to understand the changes in the thermal properties (thermal conductivity and heat capacity) of porous materials due to changes in their moisture content.

ISO 10051 specifies a steady-state method for measuring the thermal conductivity of a moist building material. In the steady-state method, a nonuniform distribution of moisture content in the test piece is inevitable, since the imposed temperature gradient causes moisture transfer. The nonuniform moisture distribution makes it difficult to define which moisture content the measured thermal conductivity corresponds to. ISO 10051 categorizes the moisture distribution in the test piece into several types and estimates the thermal conductivity corresponding to each type.

Since theoretical and experimental research has recently been performed concerning heat and moisture transfer in porous materials (see References [5], [7], [8], [9] and [10]), along with measurements and the construction of a database of hygrothermal properties (see Reference [6]), hygrothermal behaviour can now be predicted with reasonable accuracy.

This International Standard describes a transient method for measuring the thermal conductivity of a wet porous building material and a method of evaluating the measurement uncertainty, on the basis of both theoretical developments for heat and mass transfer and the constructed database of hygrothermal properties. The evaluation of the measurement uncertainty makes possible a simple and, thus, practical method for measuring thermal conductivity.

NOTE Thermal conductivity is one of the necessary hygrothermal properties. Since heat transfer and mass transfer in porous material interact with each other, an exact value of the thermal conductivity must be given in order to examine the validity of the theoretical models. Thus, precisely speaking, the above-mentioned theoretical models have not been validated, and the construction of the model and the measurements of the hygrothermal properties must be carried out in parallel. Nonetheless, it seems reasonable to expect that measurement of the thermal conductivity with an allowable accuracy is possible using a suitable measuring method. This is the basis for the present document.

Sample Document

get full document from standards.iteh.ai

Measurement of apparent thermal conductivity of wet porous building materials by a periodic method

1 Scope

This International Standard describes a method of measuring the thermal conductivity (diffusivity) of a wet porous building material and a method of evaluating the measurement uncertainty.

While ISO 10051 is the current International Standard, based on a steady-state method, this International Standard proposes a method that makes use of a non-steady-state method which uses a small temperature change with a short period as an input. Along with the measurement, an evaluation of the measurement uncertainty is described, which makes possible a simple and practical measuring method.

This International Standard intends to measure the apparent (effective) thermal conductivity, including latent heat transfer caused by vapour movement. The situation in which moisture and/or air movement occur due to convection or gravity is excluded. The application of this International Standard to high moisture content is excluded so that the gravity effect can be neglected. This International Standard can be applied to a porous material heavier than about 100 kg/m^3 , in which radiative heat transfer can be neglected.

This International Standard specifies the following:

- a) a non-steady-state method of measuring thermal conductivity;
- b) an approximation formula for the measurement uncertainty caused by moisture movement and nonuniform moisture distribution (and, thus, a determination of the measuring conditions that satisfy the upper limit of measurement uncertainty);
- c) an estimate of the heat transfer caused by moisture (vapour) movement.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

There are no normative references in this document.

3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 9346, ISO 10051 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>