
**Fire safety engineering — Verification
and validation protocol for building
fire evacuation models**

*Ingénierie de la sécurité incendie — Protocole de vérification et
de validation de modèles d'évacuation dans un bâtiment en cas
d'incendie*

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[ISO 20414:2020](#)

<https://standards.iteh.ai/catalog/standards/iso/aa2f373f-b4e7-479a-98cf-17d746f3f8db/iso-20414-2020>



Reference number
ISO 20414:2020(E)

iTeh Standards

(<https://standards.iteh.ai>)

Document Preview

[ISO 20414:2020](#)

<https://standards.iteh.ai/catalog/standards/iso/aa2f373f-b4e7-479a-98cf-17d746f3f8db/iso-20414-2020>



COPYRIGHT PROTECTED DOCUMENT

© ISO 2020

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Contents

Page

Foreword	iv
Introduction	v
1 Scope	1
2 Normative references	1
3 Terms and definitions	2
4 Documentation	5
4.1 General	5
4.2 Technical documentation	6
4.3 User's manual	8
5 Verification	9
5.1 General	9
5.2 Basic components	11
5.3 Behavioural components	24
5.4 Fire-people interaction components	29
5.5 Building-specific components	31
6 Validation	35
6.1 General	35
6.2 Methods for the analysis of results	36
6.3 Component validation	40
6.4 Global validation	46
7 Review of the theoretical and experimental basis of probabilistic models	47
8 Quality assurance	48
9 Quantification of uncertainty	49
10 Acceptance criteria	51
Annex A (informative) Reporting Template	ISO 20414:2020 52
Annex B (informative) Examples of application	55
Bibliography	64

<https://standards.iec.ch/standard/iso-20414-2020>

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 92, *Fire safety*, Subcommittee SC 04, *Fire safety engineering*.

(<https://standards.iteh.ai>)
Document Preview

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

<https://standards.iteh.ai/catalog/standards/iso/aa2f373f-b4e7-479a-98cf-17d746f3f8db/iso-20414-2020>

Introduction

The objective of fire safety engineering is to assist in the achievement of an acceptable predicted level of fire safety. Part of this work involves the use of calculation methods and models to predict human behaviour in case of a fire. Evacuation analyses are performed to mitigate the adverse effects of a fire on people. The main principles that are necessary for establishing credibility of these evacuation models are verification and validation. This document addresses the procedures for verification and validation of evacuation models. The context of applications addressed in this document is building fires.

Evacuation models are applied to establish the time for an evacuating population to reach a place of safety. Evacuation models are also used to examine evacuation dynamics of different scenarios and to evaluate the effectiveness of procedural solutions.

Evacuation models present different levels of sophistication, ranging from simplified methods (such as capacity analysis or flow calculations) to complex computational agent-based models. Microscopic models represent evacuees in computer models as agents. Each evacuee is represented by an autonomous agent with certain properties, e.g. pre-evacuation time and walking speed. A crowd is built up of a group of agents acting together in a multi-agent-based evacuation model. Agents act according to behavioural rules defined in the model. These rules can represent agent-to-agent or agent-to-environment interactions. The macroscopic approach instead represents a crowd at an aggregate level, generally adopting analogies with other physical systems (e.g. hydraulic flows). In addition, in relation to their modelling assumptions in terms of space representation (coarse or fine network approach, continuous approach or hybrid), evacuation models are capable of representing geometries with a different level of accuracy.

Evacuation models operate at three main levels when they produce results, namely 1) Individual Level, 2) Aggregate Level and 3) Scenario level. The individual level deals with the simulation of the actions performed by each agent. The aggregate level concerns the interactions between agents or the interaction between agents and simulated objects which can influence the local conditions. The scenario level relates to the results that summarize the conditions at the end of the simulation, i.e. the final outcome of the model and the layout in which the evacuation takes place.

Potential users of evacuation models and those who are asked to accept the results need to be assured that these models provide sufficiently accurate predictions of human behaviour in fire. To provide this assurance, evacuation models being considered need to be verified for accuracy and validated for capability to reproduce the phenomena. A rigorous verification and validation process are a key element of quality assurance.

There is no fixed requirement of accuracy that is applicable to all possible applications of evacuation models. The accuracy level depends on the purposes for which an evacuation model is to be used. It is not necessary that all evacuation models demonstrate high accuracy in all their components as long as the error, uncertainty and limits of applicability of the models are known. The accuracy of the evacuation model predictions is also highly dependent on the competency of the user, e.g. model configuration, data input selection, results interpretation.

This document focuses on the predictive accuracy of evacuation models. However, other factors such as ease of use, relevance, completeness and status of development play an important role in the assessment of the use of the most appropriate model for a particular application. The assessment and suitability of evacuation models for the simulation of human behaviour in fire in several contexts of applications is supported by the use of a quality-assurance methodology to ensure that the requirements are being fulfilled. Tests and methods for measuring attributes of the relevant model characteristics are outlined in this document.

This document is complementary to ISO 16730-1, in which the procedures and requirements for verification and validation of calculation methods in fire safety engineering are addressed at a general level. This document should also be used in parallel with the relevant ISO documents in which design scenarios are discussed (ISO 16733-1 and ISO/TS 29761).

This document is intended to have the following users:


- a) Conceptual model developers (individuals or organizations that perform development activities, including requirements analysis, design and testing of components): These users can use this document to document the usefulness of a particular fire evacuation model for building applications. Part of the model development process includes the identification of precision and limitations of applicability, and independent testing.

NOTE Model developers generally have access to more model components than a user, given their work in the model development phase.

- b) Software model developers (individuals or organizations that maintain computer models, supply computer models, and those who evaluate computer model quality as part of quality assurance and quality control): These users can use this document to document the software features and capabilities and to assure users that an appropriate testing protocol is followed to ensure quality of the application tools by documenting the verification and validation of the model pursuant to this document,
- c) Model users (individuals or organizations that use evacuation models to perform a fire safety analysis): These users can use models verified and validated pursuant to this document to assure themselves that they are using an appropriate model for a particular application and that it provides adequate accuracy.
- d) Developers of performance codes and standards: These users can use this document to specify the verification and validation procedure for evacuation models used in fire safety designs for a given set of applications.
- e) Approving bodies/officials (individuals or organizations that review or approve the use of evacuation models): These users can use this document as a basis to ensure that the results submitted show clearly that the evacuation model is used within its applicability limits and has an acceptable level of accuracy.
- f) Educators: These users can use this document to demonstrate the application and acceptability of evacuation models being taught.

General principles are described in ISO 23932-1, which provides a performance-based methodology for engineers to assess the level of fire safety for new or existing built environments. Fire safety is evaluated through an engineered approach based on the quantification of the behaviour of fire and knowledge of the consequences of such behaviour on life safety, property and the environment. ISO 23932-1 provides the process (necessary steps) and essential elements to design a robust performance-based fire safety programme.

ISO 23932-1 is supported by a set of fire safety engineering International Standards on the methods and data required to undertake the steps in a fire safety engineering design as summarized in ISO 23932-1 and shown in [Figure 1](#) (taken from ISO 23932-1). This set of International Standards is referred to as the Global fire safety engineering analysis and information system. This global approach and system of standards provides an awareness of the interrelationships between fire evaluations when using the set of fire safety engineering International Standards.

**Key**

- ^a See also ISO/TR 16576 (Examples).
- ^b See also ISO 16732-1, ISO 16733-1, ISO/TS 29761.
- ^c See also ISO 16732-1, ISO 16733-1, ISO/TS 29761.
- ^d See also ISO/TS 13447, ISO 16730-1, ISO/TR 16730-2 to 5 (Examples), ISO 16734, ISO 16735, ISO 16736, ISO 16737, ISO/TR 16738, ISO 24678-6.
- ^e See also ISO/TR 16738, ISO 16733-1.

Figure 1 — Flow chart of the fire safety engineering process